

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月18日

報表日期: 114年08月18日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.18	8.86	61.79	2.57	15.62	11.81	1.25	70481.53
1	8.77	8.99	56.96	2.99	16.12	11.83	1.25	69693.27
2	8.07	9.40	58.16	3.11	14.10	12.03	1.23	70098.50
3	8.32	10.18	65.93	2.88	14.30	12.34	1.23	68089.66
4	8.31	10.86	55.51	2.61	16.03	11.47	1.24	73298.00
5	3.73	8.45	64.89	3.47	12.00	12.36	1.24	71282.77
6	9.14	9.36	50.26	3.58	12.88	12.53	1.25	66478.59
7	8.40	9.24	60.32	2.95	14.67	12.14	1.25	68255.44
8	9.84	9.17	66.32	3.77	12.62	12.24	1.25	69154.09
9	3.07	9.52	71.41	2.77	13.04	12.54	1.24	64786.52
10	11.27	10.32	53.93	3.31	13.46	11.95	1.23	70844.33
11	7.39	10.43	52.11	3.09	13.33	12.28	1.25	68424.00
12	10.03	10.81	47.29	3.51	13.05	12.32	1.24	68565.29
13	1.33	11.78	52.60	3.45	11.92	13.56	1.23	57446.59
14	0.10	11.27	54.22	2.26	14.04	12.75	1.23	64221.62
15	1.44	9.17	64.73	2.19	14.37	11.95	1.23	69225.66
16	2.64	9.45	57.80	2.43	14.35	12.48	1.22	65245.09
17	1.93	9.08	55.95	1.84	15.44	11.88	1.25	70169.93
18	5.93	9.74	50.79	2.39	14.75	11.82	1.25	70811.81
19	8.92	8.92	51.42	2.49	14.72	11.88	1.25	71294.19
20	8.47	9.03	56.55	2.73	13.96	12.02	1.25	70187.15
21	5.26	8.77	61.53	2.04	15.15	11.71	1.25	71354.11
22	6.58	12.21	58.38	2.03	15.75	11.50	1.25	71788.44
23	6.76	9.78	58.97	2.18	14.95	12.01	1.22	68675.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.45	9.78	57.83	2.78	14.19	12.14	1.24	68744.68
最 大 值	11.27	12.21	71.41	3.77	16.12	13.56	1.26	73298.00
發生時間	10	22	9	8	1	13		4
最 小 值	0.10	8.45	47.29	1.84	11.92	11.47	1.20	57446.59
發生時間	14	5	12	17	13	4		13
零點偏移(率)	-0.22 %	0.00 %	-0.01 %	-0.00 %		-0.02		0.10 %
全幅偏移(率)	0.00 %	-0.65 %	-0.02 %	0.01 %		0.36		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月18日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.94	11.11	58.63	2.49	15.56	11.04	1.04	79842.95
1	10.27	10.62	54.75	2.94	16.97	10.78	1.04	81379.63
2	12.17	9.68	63.34	2.53	16.00	10.98	1.04	78472.83
3	9.69	12.16	58.29	2.61	16.23	10.96	1.04	80393.37
4	12.57	10.81	53.57	2.75	16.08	10.83	1.04	81798.02
5	9.57	10.88	62.41	2.93	15.47	11.18	1.02	79496.39
6	5.66	7.32	52.99	1.94	15.00	10.61	1.05	79310.54
7	7.63	8.83	62.38	2.10	14.75	11.40	1.06	81122.21
8	9.13	8.22	47.01	2.14	16.18	10.67	1.06	82027.80
9	3.08	9.35	55.39	2.69	14.61	11.35	1.06	78830.56
10	9.30	9.10	58.93	3.01	14.26	11.97	1.07	77525.42
11	7.62	9.00	60.18	2.49	14.35	12.04	1.09	79499.69
12	1.03	8.37	61.14	2.27	15.25	11.64	1.05	78487.47
13	0.86	8.45	60.10	2.38	15.13	11.64	1.06	78482.47
14	0.36	8.73	64.23	2.77	14.65	11.74	1.05	76074.03
15	2.07	8.16	57.56	2.62	15.43	11.18	1.06	78320.83
16	2.76	8.16	60.60	2.32	16.01	11.11	1.06	78728.51
17	1.72	7.89	57.23	2.29	16.97	10.82	1.08	82254.08
18	1.03	9.52	60.55	2.24	16.73	10.85	1.07	82583.84
19	0.72	7.91	56.83	2.00	17.02	10.81	1.06	82852.48
20	4.36	8.04	60.62	2.71	16.88	10.85	1.06	82993.04
21	4.39	8.95	58.95	2.86	16.82	10.77	1.06	83547.39
22	4.01	8.12	61.78	1.84	16.85	10.99	1.06	79791.59
23	1.78	8.53	65.29	1.78	17.02	11.48	1.07	76515.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.28	9.08	58.86	2.45	15.84	11.15	1.06	80013.77
最 大 值	12.57	12.16	65.29	3.01	17.02	12.04	1.10	83547.39
發生時間	4	3	23	10	19	11		21
最 小 值	0.36	7.32	47.01	1.78	14.26	10.61	1.02	76074.03
發生時間	14	6	8	23	10	6		14
零點偏移(率)	-0.07 %	-0.02 %	-0.01 %	0.00 %		-0.06		-0.10 %
全幅偏移(率)	0.14 %	0.42 %	-0.13 %	0.15 %		0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

