

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.61	12.40	54.48	1.33	17.12	11.69	1.09	78616.61
1	9.47	12.55	44.10	2.02	16.62	11.33	1.09	81816.73
2	9.70	13.30	46.98	1.70	17.40	11.63	1.09	78738.81
3	9.50	11.90	48.28	2.79	15.06	11.63	1.09	82210.40
4	9.62	12.26	52.66	2.36	15.33	11.80	1.09	80381.00
5	8.41	11.94	49.06	2.95	14.94	11.85	1.13	81321.55
6	9.88	11.77	46.88	2.57	15.07	11.67	1.13	81597.04
7	10.12	12.44	53.09	2.73	14.73	12.21	1.13	77129.17
8	11.00	11.92	45.14	2.34	15.75	11.36	1.13	82735.83
9	9.32	12.07	44.75	2.91	14.46	11.62	1.14	81547.03
10	9.01	12.27	56.58	1.92	15.08	12.04	1.11	76461.49
11	9.65	12.02	48.86	1.58	16.04	11.08	1.11	83835.99
12	10.40	12.99	47.51	2.83	14.69	11.40	1.13	81919.68
13	8.96	13.05	43.41	2.38	14.91	12.13	1.13	75111.75
14	9.52	11.99	57.54	1.54	16.40	11.42	1.13	81054.80
15	9.61	12.02	50.87	2.62	15.10	11.39	1.13	81458.32
16	12.13	12.37	42.74	2.39	13.97	11.82	1.13	79233.66
17	10.26	11.81	43.71	1.52	15.55	11.70	1.11	80175.55
18	9.37	12.20	38.77	1.31	15.47	11.57	1.09	81168.46
19	9.87	11.90	62.41	1.52	16.05	11.41	1.09	82008.03
20	9.66	11.74	66.81	1.13	15.59	11.63	1.09	80323.13
21	11.46	11.14	60.21	1.26	15.97	11.10	1.09	84797.81
22	9.33	11.66	61.38	0.67	16.98	11.45	1.10	80394.37
23	10.80	12.63	38.48	1.78	16.98	10.91	1.10	84689.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.86	12.18	50.20	2.01	15.64	11.58	1.11	80780.29
最大值	12.13	13.30	66.81	2.95	17.40	12.21	1.15	84797.81
發生時間	16	2	20	5	2	7		21
最小值	8.41	11.14	38.48	0.67	13.97	10.91	1.09	75111.75
發生時間	5	21	23	22	16	23		13
零點偏移(率)	-0.07 %	-0.05 %	-0.02 %	0.00 %		-0.14	-0.01	0.40 %
全幅偏移(率)	0.74 %	1.15 %	0.08 %	0.32 %		0.02	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.36	11.54	45.32	0.78	18.31	9.97	1.02	75977.19
1	4.96	11.46	45.16	1.30	18.69	9.79	1.02	77435.78
2	6.53	12.45	39.86	1.38	17.19	10.03	1.02	78120.18
3	5.67	12.95	46.68	1.54	16.31	10.46	1.04	77225.40
4	3.50	12.79	42.91	1.82	15.84	10.42	1.03	77620.55
5	4.60	12.92	45.81	2.10	15.51	10.66	1.03	78010.40
6	3.40	11.67	49.20	2.43	15.17	10.67	1.06	74600.95
7	8.00	11.79	57.53	2.08	15.42	10.75	1.07	78220.29
8	4.22	13.05	44.66	2.07	15.34	11.00	1.06	78365.93
9	1.89	13.00	47.69	1.78	14.71	11.79	1.04	78429.62
10	1.92	13.17	47.65	1.92	14.58	11.77	1.02	77561.38
11	1.58	12.74	45.98	1.88	15.14	11.55	1.02	78481.19
12	1.28	12.61	45.73	1.72	15.14	11.46	1.03	79021.41
13	1.99	12.26	47.13	1.70	15.67	11.07	1.04	78290.64
14	1.06	11.64	44.49	2.09	16.38	10.38	1.06	77226.71
15	2.18	11.84	49.21	1.84	15.85	10.63	1.06	76793.11
16	3.91	11.88	44.36	1.23	15.50	10.42	1.05	74606.89
17	6.09	12.14	40.81	1.21	15.45	10.12	1.03	76452.17
18	6.17	13.11	41.16	1.22	15.18	10.37	1.02	76739.53
19	6.03	11.86	43.69	1.29	16.12	10.02	1.02	78854.40
20	5.96	11.69	40.65	1.19	16.46	9.72	1.02	80133.10
21	6.63	11.77	41.78	0.63	17.42	10.05	1.03	79252.91
22	7.22	11.28	41.91	0.82	16.47	10.13	1.04	79137.86
23	6.85	11.53	42.73	1.29	17.15	10.09	1.05	79936.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.42	12.21	45.09	1.55	16.04	10.56	1.04	77770.58
最大值	8.00	13.17	57.53	2.43	18.69	11.79	1.08	80133.10
發生時間	7	10	7	6	1	9		20
最小值	1.06	11.28	39.86	0.63	14.58	9.72	1.02	74600.95
發生時間	14	22	2	21	10	20		6
零點偏移(率)	-0.13 %	-0.01 %	-0.01 %	-0.01 %		-0.06	-0.01	0.00 %
全幅偏移(率)	-1.54 %	0.07 %	0.24 %	-0.28 %		-0.02	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.88	11.37	55.55	1.90	17.44	9.90	1.43	75740.29
1	9.48	11.58	52.81	1.94	18.43	9.93	1.43	75687.94
2	10.10	11.48	50.42	2.41	16.49	10.01	1.43	74331.34
3	9.30	11.44	48.68	2.23	16.18	9.93	1.42	75174.38
4	9.40	11.66	49.25	2.26	15.78	10.01	1.42	74611.90
5	11.25	11.70	50.88	2.75	15.68	9.94	1.43	74759.61
6	8.91	11.41	48.34	2.37	15.27	9.77	1.42	74874.18
7	7.58	11.00	49.16	2.12	16.71	9.81	1.43	71198.69
8	9.75	10.84	51.48	2.25	16.67	9.61	1.46	75138.77
9	9.00	10.92	49.02	2.31	16.27	9.73	1.46	74276.68
10	9.90	10.92	52.55	2.11	16.33	9.80	1.48	71662.12
11	1.94	11.72	53.39	2.13	15.81	9.83	1.47	73076.57
12	9.19	11.19	43.03	2.14	16.42	9.46	1.47	72714.08
13	9.21	11.88	46.12	2.99	14.81	9.57	1.45	72131.04
14	8.54	11.50	45.34	2.38	16.66	9.66	1.46	73382.03
15	8.67	14.02	38.88	1.93	16.44	9.35	1.46	71960.97
16	9.68	11.77	42.73	2.66	15.88	9.34	1.46	73895.84
17	9.80	10.87	47.33	2.27	15.97	9.49	1.47	73386.46
18	9.61	11.24	40.65	2.31	16.51	9.19	1.47	73426.30
19	9.10	11.00	42.55	2.05	17.58	9.23	1.46	73580.02
20	9.88	11.29	59.76	2.32	17.89	10.00	1.48	80423.04
21	9.08	11.43	48.05	2.36	17.33	9.63	1.48	75783.80
22	9.66	11.02	43.71	2.18	17.04	9.63	1.48	73761.60
23	9.37	11.22	41.29	2.23	17.14	9.41	1.48	73805.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.10	11.44	47.96	2.27	16.53	9.68	1.45	74115.96
最大值	11.25	14.02	59.76	2.99	18.43	10.01	1.48	80423.04
發生時間	5	15	20	13	1	2		20
最小值	1.94	10.84	38.88	1.90	14.81	9.19	1.41	71198.69
發生時間	11	8	15	0	13	18		7
零點偏移(率)	-0.14 %	-0.01 %	-0.04 %	-0.01 %		-0.06	-0.01	0.00 %
全幅偏移(率)	0.02 %	0.02 %	0.02 %	0.02 %		0.06	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								