

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月26日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.06	8.89	36.31	1.19	18.64	11.00	1.02	84343.46
1	4.61	3.48	39.54	1.38	18.56	11.64	1.02	78385.21
2	6.01	1.82	43.87	1.70	16.93	11.76	1.04	76403.03
3	4.44	2.77	59.33	1.07	17.96	11.73	1.04	78771.36
4	2.00	4.11	62.79	1.01	18.06	11.65	1.05	80020.88
5	3.54	8.92	56.93	0.75	20.05	11.18	1.05	82838.37
6	4.56	6.87	45.21	1.47	18.36	11.35	1.04	82192.09
7	7.73	7.95	53.06	2.07	18.11	11.05	1.04	85324.35
8	4.12	6.44	64.71	1.97	17.09	11.63	1.04	81109.40
9	4.92	7.00	52.11	1.96	16.43	11.62	1.02	79799.87
10	2.65	8.86	46.37	1.41	17.86	11.74	1.02	78938.70
11	2.68	7.01	46.99	1.57	18.01	11.55	1.02	81153.61
12	2.86	6.99	41.30	1.55	17.64	11.41	1.03	82366.65
13	2.37	7.10	50.96	1.57	17.39	11.61	1.04	81008.39
14	4.47	6.96	50.64	1.95	16.71	11.79	1.06	79779.72
15	8.84	6.71	48.47	2.50	16.33	11.80	1.06	80047.40
16	6.53	7.09	49.19	2.08	16.30	11.92	1.06	78013.35
17	5.05	4.76	50.27	1.42	17.45	11.31	1.04	83051.52
18	5.46	1.28	57.74	1.22	17.82	11.60	1.02	80246.05
19	4.04	1.31	54.08	1.27	17.86	11.31	1.02	83042.19
20	5.53	1.16	55.74	1.34	18.26	11.25	1.02	82963.30
21	5.31	1.30	50.78	1.69	17.36	11.62	1.02	80828.27
22	5.74	1.29	57.73	1.43	17.89	11.37	1.02	82791.43
23	7.06	1.26	59.65	1.58	17.22	11.85	1.03	79427.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.86	5.06	51.41	1.55	17.68	11.53	1.03	80951.92
最 大 值	8.84	8.92	64.71	2.50	20.05	11.92	1.08	85324.35
發生時間	15	5	8	15	5	16		7
最 小 值	2.00	1.16	36.31	0.75	16.30	11.00	1.02	76403.03
發生時間	4	20	0	5	16	0		2
零點偏移(率)	-0.05 %	-0.00 %	-0.02 %	-0.01 %		-0.11		0.00 %
全幅偏移(率)	0.00 %	-0.52 %	-0.00 %	0.21 %		-0.26		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月26日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.61	2.88	40.36	1.91	18.09	10.51	0.92	83027.65
1	9.41	1.59	50.18	1.32	18.08	10.83	0.91	81960.00
2	8.52	1.91	53.86	1.04	17.63	11.39	0.90	77500.26
3	3.45	2.59	59.21	1.45	17.96	11.31	0.91	77966.53
4	8.33	2.32	58.82	1.32	18.89	10.36	0.90	84657.78
5	8.64	2.44	65.96	1.32	18.70	10.28	0.90	85283.79
6	9.51	2.95	63.21	2.17	16.55	11.67	0.92	74668.00
7	5.28	3.04	61.29	1.96	17.21	11.34	0.94	78301.23
8	7.41	3.04	62.64	1.52	17.96	10.61	0.94	83651.97
9	6.84	5.26	49.40	2.51	15.89	11.07	0.94	81042.06
10	6.92	1.95	62.06	1.67	17.67	10.92	0.94	81016.57
11	7.55	2.19	56.77	1.30	18.21	11.02	0.94	79724.36
12	7.08	1.89	53.72	1.08	18.42	10.76	0.93	81865.64
13	8.60	1.76	53.43	1.96	16.92	11.07	0.91	81019.60
14	4.13	1.82	52.73	2.15	15.78	11.27	0.90	80189.74
15	8.57	3.59	55.53	3.12	14.69	11.58	0.90	78545.67
16	8.27	1.85	65.10	1.18	18.24	10.76	0.91	81573.79
17	7.66	1.92	52.11	1.56	18.55	10.26	0.92	84832.87
18	8.68	1.96	52.34	2.14	17.03	11.01	0.92	80854.02
19	7.84	1.78	51.31	1.14	19.29	10.29	0.94	84564.01
20	8.99	3.66	43.78	1.03	18.36	10.54	0.94	82986.49
21	8.82	1.89	48.57	1.98	17.18	11.04	0.94	80476.03
22	8.44	2.50	54.81	1.23	17.72	10.78	0.94	82279.92
23	8.12	1.90	57.49	0.88	18.42	11.02	0.94	80023.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.74	2.44	55.19	1.62	17.64	10.90	0.92	81167.15
最 大 值	9.51	5.26	65.96	3.12	19.29	11.67	0.96	85283.79
發生時間	6	9	5	15	19	6		5
最 小 值	3.45	1.59	40.36	0.88	14.69	10.26	0.89	74668.00
發生時間	3	1	0	23	15	17		6
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.01 %		-0.06		-0.10 %
全幅偏移(率)	-0.40 %	-0.34 %	-0.46 %	0.04 %		-0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年07月26日

報表日期: 113年07月26日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.07	1.47	49.87	0.68	17.13	11.52	0.92	74740.54
1	1.49	1.93	55.86	0.68	17.56	11.79	0.91	71575.28
2	2.36	1.51	44.43	1.09	16.97	11.25	0.92	77348.14
3	4.61	2.53	54.24	1.69	17.09	11.21	0.92	77806.29
4	2.57	4.17	63.87	0.95	16.99	11.62	0.92	74105.89
5	2.11	3.49	59.97	0.61	18.10	10.84	0.92	79816.69
6	3.90	4.96	60.50	1.07	18.45	10.62	0.92	80972.90
7	4.79	7.14	61.13	0.26	17.26	11.04	0.92	87581.89
8	9.73	6.27	67.26	0.41	17.67	10.85	0.92	79762.46
9	9.16	7.16	55.12	0.35	17.24	10.85	0.92	75776.72
10	8.38	2.72	59.56	0.41	16.91	10.88	0.94	78355.36
11	8.15	2.76	67.75	0.40	16.47	11.18	0.97	73424.42
12	6.44	2.65	59.90	0.21	17.27	10.95	0.99	75353.52
13	8.16	2.75	58.02	0.39	16.46	11.16	0.97	76933.56
14	8.44	3.17	64.33	0.84	14.86	11.73	0.95	75461.29
15	9.21	3.81	64.54	0.75	15.53	11.38	0.92	77397.07
16	10.82	5.76	64.49	1.14	15.01	11.56	0.92	76641.50
17	8.78	2.59	53.18	0.61	16.55	11.30	0.94	77402.52
18	9.55	2.76	55.32	0.50	18.60	10.60	0.98	81179.20
19	9.84	2.60	51.84	0.35	17.47	10.91	0.99	79742.83
20	6.12	2.47	49.83	0.24	17.77	10.76	0.97	80379.01
21	8.95	3.02	52.83	0.41	16.71	11.38	0.96	76634.50
22	16.31	4.19	46.36	0.76	16.30	11.27	0.94	78544.93
23	6.64	2.74	56.91	0.30	16.92	11.52	0.92	75074.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.07	3.53	57.38	0.63	16.97	11.17	0.94	77583.78
最 大 值	16.31	7.16	67.75	1.69	18.60	11.79	0.99	87581.89
發生時間	22	9	11	3	18	1		7
最 小 值	1.49	1.47	44.43	0.21	14.86	10.60	0.90	71575.28
發生時間	1	0	2	12	14	18		1
零點偏移(率)	-0.36 %	-0.00 %	-0.03 %	-0.01 %		-0.17		0.00 %
全幅偏移(率)	0.25 %	-0.10 %	-0.29 %	0.47 %		-0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								