

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月25日

報表日期: 114年09月25日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.89	17.57	59.21	5.72	14.82	11.88	1.25	74671.97
1	6.43	16.77	64.23	5.49	16.35	11.49	1.23	78795.89
2	13.40	16.75	61.22	5.38	14.82	11.66	1.23	78593.95
3	3.69	14.95	67.37	2.70	15.15	11.79	1.24	77725.17
4	8.88	13.54	63.73	2.82	15.73	11.20	1.25	83639.98
5	7.72	19.85	57.44	3.78	14.40	11.78	1.27	74206.64
6	12.11	12.62	56.20	3.12	14.68	11.62	1.26	77910.09
7	10.49	12.81	60.16	2.72	15.39	11.38	1.27	78297.64
8	10.88	13.21	58.96	3.10	14.99	11.25	1.27	79795.69
9	9.54	13.26	47.92	3.00	13.67	11.71	1.27	77369.79
10	11.01	13.63	54.51	3.10	14.25	11.72	1.25	79076.31
11	4.77	13.61	61.23	2.99	14.20	12.04	1.25	75830.13
12	8.94	13.35	55.17	3.74	14.24	11.87	1.25	77369.62
13	7.11	13.41	57.53	2.81	15.87	11.78	1.25	78710.30
14	9.02	13.21	57.58	2.87	15.96	11.61	1.26	79633.66
15	11.89	13.24	52.96	3.45	14.98	11.69	1.25	79582.30
16	7.97	12.97	63.86	2.71	16.16	11.44	1.26	80744.69
17	10.62	12.81	47.26	3.44	14.89	11.37	1.26	82220.80
18	9.85	13.12	61.85	3.23	15.86	11.57	1.26	80040.14
19	7.70	13.74	65.08	3.24	15.05	11.98	1.25	76701.66
20	8.20	13.57	43.34	3.36	14.83	11.53	1.25	81672.49
21	8.56	13.35	70.57	2.71	16.02	11.62	1.25	79765.92
22	12.73	13.51	51.44	3.53	15.12	11.32	1.25	80998.77
23	8.28	13.97	69.23	2.83	15.56	12.11	1.25	73987.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.99	14.12	58.67	3.41	15.12	11.64	1.25	78639.20
最 大 值	13.40	19.85	70.57	5.72	16.35	12.11	1.29	83639.98
發生時間	2	5	21	0	1	23		4
最 小 值	3.69	12.62	43.34	2.70	13.67	11.20	1.21	73987.20
發生時間	3	6	20	3	9	4		23
零點偏移(率)	-0.29 %	0.00 %	-0.04 %	-0.01 %		0.01		0.10 %
全幅偏移(率)	0.87 %	1.95 %	-0.79 %	0.06 %		0.25		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月25日

報表日期: 114年09月25日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.33	15.98	50.72	2.01	16.82	10.60	1.02	84934.97
1	3.22	16.18	54.53	1.74	17.89	10.84	1.02	82448.60
2	3.66	16.14	62.00	1.65	16.78	11.17	1.02	81363.62
3	3.51	13.29	57.31	1.44	16.92	10.94	0.99	82165.00
4	2.92	12.59	53.75	2.07	16.41	10.87	0.99	82262.89
5	5.56	12.70	59.37	2.16	16.32	11.01	1.01	82449.21
6	7.67	12.56	65.57	1.69	16.01	11.33	0.99	79245.96
7	4.36	13.03	49.81	1.46	16.82	10.81	0.99	81927.31
8	3.39	12.45	56.23	1.71	16.71	11.05	1.02	81901.23
9	6.31	12.43	55.85	1.68	16.99	10.96	1.02	83128.92
10	8.28	13.75	52.32	1.63	16.79	10.82	1.00	83569.28
11	3.42	12.65	61.77	1.40	17.36	11.11	0.99	80724.65
12	2.43	12.57	51.03	1.19	17.63	10.90	0.99	79277.02
13	1.82	13.18	55.65	1.43	16.90	11.40	0.98	75570.13
14	2.04	12.83	58.92	1.57	16.98	11.18	0.97	77058.92
15	2.16	13.23	56.33	1.90	16.09	10.98	0.97	79214.89
16	2.16	12.17	50.72	1.14	17.75	10.13	0.97	79728.38
17	2.04	12.99	53.26	0.98	18.48	9.70	0.98	81130.18
18	1.75	12.41	51.23	1.41	17.06	10.20	0.97	77325.89
19	1.76	12.18	54.44	1.63	17.16	9.93	0.97	78407.80
20	2.56	11.65	51.50	0.96	18.71	9.46	0.96	81554.26
21	2.28	11.68	60.78	1.30	17.65	10.18	0.97	82948.79
22	4.40	12.92	69.07	1.19	17.39	11.24	0.98	78126.94
23	3.35	12.45	58.95	0.99	17.84	10.89	0.99	81713.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.52	13.08	56.30	1.51	17.14	10.74	0.99	80757.43
最 大 值	8.28	16.18	69.07	2.16	18.71	11.40	1.02	84934.97
發生時間	10	1	22	5	20	13		0
最 小 值	1.75	11.65	49.81	0.96	16.01	9.46	0.95	75570.13
發生時間	18	20	7	20	6	20		13
零點偏移(率)	-0.13 %	-0.01 %	-0.02 %	-0.01 %		0.00		-0.10 %
全幅偏移(率)	0.09 %	0.65 %	2.51 %	0.16 %		-0.15		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月25日

報表日期: 114年09月25日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.14	15.25	66.28	3.18	16.85	9.94	1.48	79462.15
1	7.70	14.74	64.01	3.18	17.35	9.69	1.48	78936.68
2	10.77	15.14	58.97	3.31	16.82	8.87	1.43	83650.85
3	9.53	14.28	60.44	3.52	13.89	9.89	1.43	73954.27
4	8.51	11.42	59.54	3.27	14.67	9.78	1.43	74492.25
5	12.05	12.16	55.72	3.62	14.70	9.97	1.44	75354.30
6	8.80	10.42	57.47	3.10	15.57	9.25	1.46	78485.88
7	12.13	10.87	58.74	4.10	16.09	9.22	1.46	77179.97
8	9.24	10.91	53.41	4.03	15.48	9.41	1.44	77167.72
9	6.61	12.54	52.33	4.09	14.18	10.12	1.44	73995.34
10	10.19	11.99	53.72	3.20	15.75	9.57	1.41	74007.84
11	7.05	11.10	55.44	2.64	15.87	9.36	1.39	73896.89
12	7.17	11.04	62.88	3.50	17.39	9.35	1.42	76595.17
13	8.03	11.03	62.55	3.41	17.16	9.45	1.43	77270.64
14	9.08	11.13	62.91	3.55	17.52	9.44	1.43	76549.52
15	9.53	11.18	57.61	3.70	16.91	9.62	1.43	74758.75
16	7.28	13.14	43.93	3.54	17.38	8.29	1.42	75153.55
17	9.85	10.05	53.06	3.73	17.62	8.49	1.41	76389.57
18	6.15	10.36	57.30	3.32	16.52	9.06	1.40	74314.66
19	9.18	11.62	52.76	3.54	17.26	9.00	1.45	78337.61
20	8.84	13.90	53.43	3.10	17.57	9.04	1.41	79153.02
21	9.88	12.72	58.32	1.19	17.35	9.36	1.39	79652.05
22	9.30	13.80	66.85	3.10	16.72	9.93	1.40	81081.76
23	10.30	13.53	63.08	3.64	17.54	10.07	1.41	80986.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.01	12.26	57.95	3.36	16.42	9.42	1.43	77117.80
最 大 值	12.13	15.25	66.85	4.10	17.62	10.12	1.48	83650.85
發生時間	7	0	22	7	17	9		2
最 小 值	6.15	10.05	43.93	1.19	13.89	8.29	1.39	73896.89
發生時間	18	17	16	21	3	16		11
零點偏移(率)	-0.44 %	-0.00 %	-0.39 %	-0.01 %		-0.03		0.20 %
全幅偏移(率)	0.53 %	-0.37 %	0.14 %	-0.52 %		0.19		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								