

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月15日

| 項目      | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 6.69     | 6.39     | 54.61    | 3.46     | 13.94    | 12.65    | 1.33     | 69159.03  |
| 1       | 9.35     | 9.73     | 59.19    | 3.29     | 13.96    | 12.36    | 1.33     | 71935.43  |
| 2       | 12.55    | 2.41     | 62.89    | 3.65     | 13.65    | 12.42    | 1.33     | 71730.96  |
| 3       | 12.06    | 7.91     | 58.59    | 4.42     | 12.05    | 12.64    | 1.34     | 71059.71  |
| 4       | 8.55     | 8.72     | 55.32    | 4.19     | 12.10    | 12.68    | 1.36     | 70832.99  |
| 5       | 4.26     | 5.85     | 57.38    | 2.99     | 13.87    | 12.60    | 1.41     | 67993.78  |
| 6       | 5.03     | 6.38     | 59.21    | 2.75     | 14.10    | 12.35    | 1.40     | 71644.79  |
| 7       | 4.48     | 5.87     | 64.03    | 3.14     | 13.62    | 12.67    | 1.41     | 70071.15  |
| 8       | 7.31     | 10.56    | 50.53    | 3.27     | 13.50    | 12.47    | 1.40     | 71208.05  |
| 9       | 5.50     | 5.82     | 62.26    | 2.94     | 13.90    | 12.56    | 1.40     | 70241.13  |
| 10      | 4.33     | 6.21     | 53.62    | 3.51     | 12.66    | 12.60    | 1.39     | 70787.85  |
| 11      | 1.41     | 6.45     | 69.63    | 2.53     | 14.34    | 12.53    | 1.42     | 68732.42  |
| 12      | 1.25     | 3.68     | 60.38    | 2.12     | 15.14    | 12.12    | 1.39     | 71973.40  |
| 13      | 1.40     | 3.90     | 62.78    | 2.13     | 15.20    | 12.33    | 1.38     | 70949.68  |
| 14      | 2.62     | 3.64     | 50.35    | 2.48     | 14.50    | 12.23    | 1.37     | 72223.98  |
| 15      | 3.43     | 3.85     | 54.59    | 2.89     | 13.89    | 12.40    | 1.38     | 71063.98  |
| 16      | 8.09     | 4.21     | 59.18    | 3.24     | 13.39    | 12.55    | 1.39     | 70411.74  |
| 17      | 7.45     | 3.76     | 57.43    | 2.81     | 14.21    | 12.33    | 1.38     | 71733.63  |
| 18      | 8.79     | 3.45     | 65.45    | 2.71     | 14.23    | 12.28    | 1.38     | 72285.98  |
| 19      | 9.29     | 3.13     | 53.98    | 3.06     | 13.68    | 12.40    | 1.38     | 71392.28  |
| 20      | 9.53     | 3.20     | 57.88    | 3.29     | 13.34    | 12.64    | 1.38     | 69986.77  |
| 21      | 11.17    | 8.70     | 48.45    | 4.04     | 12.21    | 12.68    | 1.38     | 70445.41  |
| 22      | 11.40    | 3.79     | 56.27    | 3.41     | 13.67    | 12.46    | 1.38     | 70817.29  |
| 23      | 9.83     | 6.28     | 57.64    | 3.55     | 13.08    | 12.51    | 1.38     | 70813.38  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 6.91     | 5.58     | 57.99    | 3.16     | 13.68    | 12.48    | 1.38     | 70812.28  |
| 最大值     | 12.55    | 10.56    | 69.63    | 4.42     | 15.20    | 12.68    | 1.46     | 72285.98  |
| 發生時間    | 2        | 8        | 11       | 3        | 13       | 4        |          | 18        |
| 最小值     | 1.25     | 2.41     | 48.45    | 2.12     | 12.05    | 12.12    | 1.33     | 67993.78  |
| 發生時間    | 12       | 2        | 21       | 12       | 3        | 12       |          | 5         |
| 零點偏移(率) | -0.34 %  | -0.00 %  | -0.15 %  | -0.00 %  |          | 0.01     | 0.00     | 0.00 %    |
| 全幅偏移(率) | -3.10 %  | -0.77 %  | -0.20 %  | -0.17 %  |          | 0.30     | -0.03    | 0.40 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月15日

| 項目      | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 7.27     | 5.44     | 59.51    | 1.34     | 18.51    | 10.37    | 1.36     | 87476.89  |
| 1       | 8.50     | 5.97     | 52.44    | 1.95     | 17.49    | 10.63    | 1.37     | 85531.34  |
| 2       | 8.25     | 8.86     | 61.25    | 1.98     | 16.73    | 10.76    | 1.38     | 85098.91  |
| 3       | 8.67     | 5.73     | 64.13    | 2.00     | 16.70    | 10.69    | 1.38     | 86738.66  |
| 4       | 7.96     | 5.25     | 57.13    | 1.62     | 18.01    | 10.33    | 1.37     | 88186.12  |
| 5       | 8.78     | 7.35     | 59.44    | 1.86     | 17.21    | 10.67    | 1.36     | 85214.57  |
| 6       | 5.71     | 4.21     | 60.65    | 1.48     | 17.62    | 10.60    | 1.38     | 83283.44  |
| 7       | 8.05     | 3.22     | 58.18    | 1.62     | 17.56    | 10.63    | 1.38     | 85262.82  |
| 8       | 10.53    | 3.55     | 53.57    | 1.96     | 17.16    | 10.68    | 1.38     | 85889.62  |
| 9       | 8.39     | 8.00     | 56.60    | 1.59     | 18.19    | 10.21    | 1.38     | 87257.91  |
| 10      | 8.98     | 1.74     | 57.69    | 1.26     | 19.04    | 10.13    | 1.38     | 87565.98  |
| 11      | 6.51     | 5.02     | 41.36    | 1.68     | 16.92    | 10.42    | 1.39     | 86034.99  |
| 12      | 9.06     | 3.50     | 45.97    | 1.54     | 18.04    | 10.15    | 1.41     | 84226.00  |
| 13      | 9.40     | 2.50     | 55.96    | 1.62     | 17.62    | 10.37    | 1.39     | 86043.76  |
| 14      | 8.88     | 2.95     | 54.96    | 1.70     | 17.89    | 10.38    | 1.40     | 84547.39  |
| 15      | 8.33     | 2.40     | 56.11    | 1.31     | 18.56    | 10.33    | 1.40     | 84689.14  |
| 16      | 12.01    | 3.07     | 42.65    | 1.96     | 17.04    | 10.17    | 1.41     | 85112.89  |
| 17      | 10.67    | 2.61     | 54.23    | 2.09     | 16.34    | 10.43    | 1.41     | 84843.71  |
| 18      | 10.17    | 6.69     | 50.36    | 1.91     | 16.29    | 10.49    | 1.41     | 85059.92  |
| 19      | 10.75    | 2.38     | 51.91    | 1.92     | 16.43    | 10.58    | 1.41     | 83101.90  |
| 20      | 11.50    | 1.88     | 56.47    | 1.97     | 16.09    | 10.62    | 1.41     | 83570.33  |
| 21      | 10.09    | 2.26     | 53.41    | 2.15     | 15.24    | 10.69    | 1.41     | 82434.37  |
| 22      | 9.73     | 1.47     | 59.46    | 1.91     | 15.68    | 10.62    | 1.41     | 83307.06  |
| 23      | 10.30    | 15.13    | 50.89    | 2.52     | 14.12    | 10.88    | 1.41     | 78573.65  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 9.10     | 4.63     | 54.76    | 1.79     | 17.10    | 10.49    | 1.39     | 84960.47  |
| 最大值     | 12.01    | 15.13    | 64.13    | 2.52     | 19.04    | 10.88    | 1.44     | 88186.12  |
| 發生時間    | 16       | 23       | 3        | 23       | 10       | 23       |          | 4         |
| 最小值     | 5.71     | 1.47     | 41.36    | 1.26     | 14.12    | 10.13    | 1.36     | 78573.65  |
| 發生時間    | 6        | 22       | 11       | 10       | 23       | 10       |          | 23        |
| 零點偏移(率) | -0.22 %  | -0.00 %  | -0.15 %  | -0.01 %  |          | -0.01    | 0.00     | 0.00 %    |
| 全幅偏移(率) | 2.61 %   | -0.91 %  | -0.13 %  | -0.01 %  |          | 0.39     | -0.03    | 0.30 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月15日

| 項目      | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 6.68     | 5.87     | 58.21    | 1.67     | 15.81    | 10.97    | 1.74     | 82041.60  |
| 1       | 10.65    | 5.93     | 65.62    | 2.09     | 15.74    | 11.16    | 1.74     | 81443.04  |
| 2       | 9.36     | 6.32     | 55.90    | 1.95     | 15.54    | 10.90    | 1.73     | 84385.51  |
| 3       | 6.83     | 7.67     | 56.66    | 1.63     | 15.97    | 10.78    | 1.75     | 83809.63  |
| 4       | 7.12     | 5.63     | 63.01    | 1.67     | 16.80    | 10.52    | 1.76     | 85063.79  |
| 5       | 5.65     | 5.82     | 56.49    | 1.95     | 14.91    | 11.00    | 1.78     | 82896.73  |
| 6       | 8.54     | 9.05     | 57.36    | 1.66     | 16.05    | 10.58    | 1.78     | 84280.62  |
| 7       | 7.70     | 4.24     | 65.76    | 1.61     | 15.33    | 11.22    | 1.79     | 82482.85  |
| 8       | 7.83     | 3.36     | 55.52    | 1.41     | 16.41    | 10.91    | 1.78     | 84975.74  |
| 9       | 9.57     | 5.33     | 55.36    | 1.47     | 16.27    | 11.21    | 1.76     | 86110.58  |
| 10      | 9.66     | 4.04     | 56.62    | 2.24     | 14.47    | 11.86    | 1.73     | 82348.73  |
| 11      | 2.36     | 3.80     | 67.06    | 1.34     | 15.51    | 12.07    | 1.72     | 78922.56  |
| 12      | 3.97     | 4.50     | 54.61    | 1.12     | 16.00    | 11.26    | 1.72     | 86811.50  |
| 13      | 9.19     | 12.87    | 53.56    | 2.11     | 15.16    | 11.49    | 1.72     | 84794.50  |
| 14      | 9.36     | 2.29     | 54.18    | 1.48     | 15.94    | 11.34    | 1.72     | 85025.89  |
| 15      | 8.09     | 1.96     | 51.87    | 1.53     | 15.79    | 11.41    | 1.72     | 84430.06  |
| 16      | 8.28     | 3.54     | 62.72    | 1.64     | 15.62    | 11.55    | 1.72     | 84422.24  |
| 17      | 10.07    | 5.29     | 55.94    | 1.48     | 16.37    | 10.99    | 1.72     | 86365.61  |
| 18      | 9.26     | 5.02     | 63.30    | 1.66     | 15.72    | 11.39    | 1.72     | 81369.35  |
| 19      | 9.33     | 2.41     | 56.41    | 1.51     | 15.50    | 10.95    | 1.73     | 86115.34  |
| 20      | 11.34    | 2.47     | 60.44    | 2.01     | 14.14    | 11.42    | 1.77     | 82627.80  |
| 21      | 13.86    | 3.53     | 60.41    | 2.50     | 14.20    | 11.39    | 1.77     | 81901.17  |
| 22      | 10.60    | 5.18     | 56.44    | 2.24     | 14.19    | 11.27    | 1.76     | 81810.97  |
| 23      | 10.39    | 6.08     | 59.87    | 2.43     | 13.49    | 11.65    | 1.75     | 82001.19  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 8.57     | 5.09     | 58.47    | 1.77     | 15.46    | 11.22    | 1.74     | 83601.54  |
| 最大值     | 13.86    | 12.87    | 67.06    | 2.50     | 16.80    | 12.07    | 1.80     | 86811.50  |
| 發生時間    | 21       | 13       | 11       | 21       | 4        | 11       |          | 12        |
| 最小值     | 2.36     | 1.96     | 51.87    | 1.12     | 13.49    | 10.52    | 1.71     | 78922.56  |
| 發生時間    | 11       | 15       | 15       | 12       | 23       | 4        |          | 11        |
| 零點偏移(率) | 0.00 %   | -0.00 %  | -0.36 %  | -0.01 %  |          | 0.04     | 0.00     | 0.00 %    |
| 全幅偏移(率) | 1.39 %   | -0.25 %  | -0.08 %  | 0.06 %   |          | 0.44     | -0.03    | 0.20 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |