

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月18日

報表日期: 115年08月18日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO <sub>2</sub> _C | #1-H <sub>2</sub> O | #1-O <sub>2</sub> _C | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|-----------------------|---------------------|----------------------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm                   | %                   | %                    | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00                | 100.00              | 25.00                | 10.00    | 999999.00 |
| 0                 | 7.29     | 11.74    | 61.54    | 1.32                  | 19.58               | 11.17                | 1.24     | 72398.57  |
| 1                 | 9.44     | 11.34    | 42.06    | 1.92                  | 19.46               | 10.69                | 1.23     | 76017.47  |
| 2                 | 10.38    | 11.60    | 49.90    | 2.14                  | 19.30               | 11.10                | 1.21     | 73593.70  |
| 3                 | 8.89     | 11.71    | 59.03    | 2.67                  | 18.28               | 11.20                | 1.21     | 74236.66  |
| 4                 | 9.15     | 12.26    | 62.45    | 3.09                  | 17.56               | 11.57                | 1.22     | 72552.84  |
| 5                 | 7.91     | 12.63    | 48.28    | 2.51                  | 18.79               | 10.92                | 1.20     | 78320.00  |
| 6                 | 9.34     | 12.74    | 66.14    | 2.16                  | 19.97               | 10.98                | 1.20     | 74189.02  |
| 7                 | 10.74    | 12.39    | 54.80    | 2.59                  | 19.70               | 10.63                | 1.20     | 76643.93  |
| 8                 | 7.85     | 12.68    | 63.53    | 2.51                  | 19.04               | 10.70                | 1.21     | 76842.51  |
| 9                 | 9.29     | 13.16    | 49.97    | 2.90                  | 18.01               | 11.48                | 1.20     | 71878.76  |
| 10                | 10.98    | 13.97    | 59.35    | 2.50                  | 19.60               | 10.72                | 1.19     | 76121.66  |
| 11                | 8.30     | 13.02    | 58.27    | 2.39                  | 17.86               | 11.40                | 1.21     | 72263.98  |
| 12                | 10.47    | 13.13    | 55.55    | 2.49                  | 18.06               | 11.32                | 1.21     | 73617.94  |
| 13                | 8.52     | 14.13    | 57.13    | 2.90                  | 17.12               | 11.57                | 1.20     | 71949.30  |
| 14                | 11.09    | 13.31    | 56.56    | 3.92                  | 16.70               | 11.73                | 1.20     | 71125.80  |
| 15                | 8.42     | 13.04    | 58.62    | 3.97                  | 17.31               | 11.48                | 1.20     | 71850.57  |
| 16                | 7.90     | 13.62    | 64.33    | 1.86                  | 18.20               | 11.73                | 1.22     | 69786.63  |
| 17                | 7.86     | 13.19    | 49.10    | 1.89                  | 18.21               | 11.05                | 1.22     | 74823.04  |
| 18                | 9.29     | 12.74    | 61.66    | 2.54                  | 18.91               | 11.01                | 1.20     | 74857.92  |
| 19                | 5.24     | 14.44    | 51.12    | 1.59                  | 17.82               | 12.26                | 1.22     | 66105.20  |
| 20                | 11.86    | 12.88    | 54.31    | 2.47                  | 17.25               | 11.12                | 1.21     | 75118.61  |
| 21                | 8.50     | 13.04    | 55.39    | 3.43                  | 17.06               | 11.30                | 1.21     | 73906.87  |
| 22                | 9.46     | 13.19    | 53.47    | 2.36                  | 16.85               | 11.68                | 1.20     | 71117.96  |
| 23                | 9.99     | 13.77    | 61.80    | 2.04                  | 17.35               | 11.90                | 1.22     | 69201.64  |
| 監測時數              | 24       | 24       | 24       | 24                    | 24                  | 24                   | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0                     | 0                   | 0                    | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24                    | 24                  | 24                   | 24       | 24        |
| 平 均 值             | 9.09     | 12.91    | 56.43    | 2.51                  | 18.25               | 11.28                | 1.21     | 73271.69  |
| 最 大 值             | 11.86    | 14.44    | 66.14    | 3.97                  | 19.97               | 12.26                | 1.25     | 78320.00  |
| 發生時間              | 20       | 19       | 6        | 15                    | 6                   | 19                   |          | 5         |
| 最 小 值             | 5.24     | 11.34    | 42.06    | 1.32                  | 16.70               | 10.63                | 1.12     | 66105.20  |
| 發生時間              | 19       | 1        | 1        | 0                     | 14                  | 7                    |          | 19        |
| 零點偏移(率)           | -0.05 %  | -0.07 %  | -0.01 %  | 0.00 %                |                     | -0.01                | -0.01    | 0.20 %    |
| 全幅偏移(率)           | 1.46 %   | 0.42 %   | 0.58 %   | 1.12 %                |                     | -0.21                | -0.06    | 0.10 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 %              | 100.00 %            | 100.00 %             | 100.00 % | 100.00 %  |
| 備註                |          |          |          |                       |                     |                      |          |           |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月18日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 7.84     | 12.68    | 49.51    | 1.24     | 18.91    | 10.99    | 0.94     | 81295.48  |
| 1                 | 5.27     | 12.65    | 51.38    | 1.83     | 18.91    | 10.95    | 0.94     | 81861.83  |
| 2                 | 6.01     | 12.67    | 51.41    | 1.80     | 19.23    | 11.02    | 0.92     | 81362.34  |
| 3                 | 7.25     | 12.73    | 51.48    | 2.06     | 17.98    | 11.24    | 0.93     | 80775.69  |
| 4                 | 7.00     | 12.63    | 53.00    | 1.84     | 18.14    | 11.15    | 0.92     | 81734.62  |
| 5                 | 5.02     | 12.53    | 61.43    | 2.53     | 18.10    | 11.05    | 0.93     | 82188.64  |
| 6                 | 4.01     | 11.48    | 49.66    | 1.75     | 19.28    | 10.69    | 0.91     | 81029.63  |
| 7                 | 10.35    | 12.29    | 53.42    | 2.35     | 18.98    | 10.75    | 0.91     | 83742.69  |
| 8                 | 7.33     | 12.26    | 51.89    | 1.69     | 19.12    | 10.74    | 0.91     | 83377.10  |
| 9                 | 3.95     | 12.57    | 52.59    | 1.33     | 19.14    | 10.98    | 0.92     | 81386.72  |
| 10                | 3.54     | 13.03    | 43.30    | 2.08     | 18.36    | 11.15    | 0.92     | 80665.02  |
| 11                | 4.67     | 13.01    | 39.54    | 2.19     | 16.75    | 11.51    | 0.92     | 79226.93  |
| 12                | 8.43     | 12.98    | 41.67    | 2.39     | 16.99    | 11.36    | 0.93     | 80070.13  |
| 13                | 3.38     | 12.81    | 42.43    | 3.08     | 16.98    | 11.42    | 0.92     | 80090.98  |
| 14                | 13.85    | 14.85    | 30.25    | 1.79     | 15.54    | 11.88    | 0.90     | 77568.93  |
| 15                | 9.71     | 14.49    | 28.92    | 0.47     | 15.47    | 11.95    | 0.91     | 76701.68  |
| 16                | 8.72     | 13.21    | 58.03    | 0.92     | 16.61    | 11.64    | 0.92     | 78516.50  |
| 17                | 6.81     | 14.16    | 56.64    | 3.31     | 15.82    | 11.63    | 0.92     | 79300.96  |
| 18                | 9.13     | 12.43    | 58.47    | 1.90     | 18.43    | 10.96    | 0.91     | 82022.71  |
| 19                | 3.92     | 12.96    | 55.80    | 2.61     | 17.02    | 11.19    | 0.92     | 81883.24  |
| 20                | 11.05    | 13.23    | 58.16    | 2.64     | 16.08    | 11.49    | 0.92     | 80419.65  |
| 21                | 8.68     | 12.55    | 55.97    | 2.70     | 17.74    | 11.03    | 0.92     | 82232.53  |
| 22                | 4.40     | 12.75    | 52.13    | 3.46     | 16.34    | 11.44    | 0.92     | 80496.82  |
| 23                | 6.70     | 12.74    | 51.71    | 2.47     | 17.39    | 11.19    | 0.92     | 81933.28  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 6.96     | 12.90    | 49.95    | 2.10     | 17.64    | 11.23    | 0.92     | 80828.50  |
| 最 大 值             | 13.85    | 14.85    | 61.43    | 3.46     | 19.28    | 11.95    | 0.96     | 83742.69  |
| 發生時間              | 14       | 14       | 5        | 22       | 6        | 15       |          | 7         |
| 最 小 值             | 3.38     | 11.48    | 28.92    | 0.47     | 15.47    | 10.69    | 0.89     | 76701.68  |
| 發生時間              | 13       | 6        | 15       | 15       | 15       | 6        |          | 15        |
| 零點偏移(率)           | -0.09 %  | -0.01 %  | -0.06 %  | -0.01 %  |          | 0.00     | -0.01    | -0.10 %   |
| 全幅偏移(率)           | -0.72 %  | 0.29 %   | 0.44 %   | 0.45 %   |          | -0.20    | -0.06    | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月18日

報表日期: 115年08月18日

| 項目<br>單位<br>小時\限標 | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 4.66     | 12.14    | 56.73    | 2.75     | 18.99    | 10.56    | 1.28     | 71480.72  |
| 1                 | 6.02     | 12.22    | 50.58    | 2.77     | 20.26    | 10.49    | 1.29     | 74693.81  |
| 2                 | 4.99     | 11.52    | 43.16    | 2.19     | 22.12    | 9.54     | 1.31     | 80329.89  |
| 3                 | 7.90     | 11.90    | 46.88    | 3.00     | 19.39    | 10.31    | 1.29     | 75824.60  |
| 4                 | 5.77     | 11.94    | 51.55    | 2.93     | 19.34    | 10.36    | 1.28     | 77469.42  |
| 5                 | 10.39    | 11.98    | 52.81    | 3.10     | 19.67    | 10.32    | 1.27     | 79259.34  |
| 6                 | 5.01     | 12.14    | 54.97    | 2.96     | 20.94    | 10.19    | 1.26     | 75795.87  |
| 7                 | 4.66     | 12.86    | 54.56    | 2.44     | 20.99    | 9.95     | 1.26     | 84027.94  |
| 8                 | 4.65     | 12.70    | 48.83    | 2.37     | 20.17    | 9.77     | 1.27     | 77127.92  |
| 9                 | 5.65     | 12.69    | 56.12    | 2.50     | 19.81    | 10.05    | 1.29     | 75599.78  |
| 10                | 8.46     | 12.51    | 58.94    | 2.58     | 20.04    | 9.73     | 1.29     | 78991.42  |
| 11                | 8.00     | 12.99    | 53.62    | 2.55     | 19.46    | 10.23    | 1.27     | 75380.92  |
| 12                | 6.32     | 12.26    | 50.98    | 2.57     | 20.07    | 9.56     | 1.27     | 74925.07  |
| 13                | 8.15     | 12.13    | 45.40    | 2.55     | 19.56    | 9.34     | 1.28     | 74831.15  |
| 14                | 8.35     | 12.13    | 48.20    | 2.55     | 19.47    | 9.47     | 1.29     | 73678.99  |
| 15                | 7.00     | 12.94    | 46.42    | 2.33     | 18.18    | 9.77     | 1.29     | 73466.58  |
| 16                | 9.25     | 12.58    | 54.26    | 2.50     | 17.65    | 10.08    | 1.29     | 74224.00  |
| 17                | 6.47     | 12.65    | 54.87    | 2.40     | 17.44    | 9.95     | 1.25     | 73285.61  |
| 18                | 12.34    | 12.48    | 59.56    | 2.86     | 17.95    | 10.28    | 1.28     | 75445.75  |
| 19                | 8.75     | 11.45    | 62.95    | 2.66     | 19.36    | 9.84     | 1.29     | 76463.27  |
| 20                | 11.73    | 11.50    | 63.19    | 3.26     | 19.54    | 9.51     | 1.30     | 75775.50  |
| 21                | 7.22     | 11.29    | 59.64    | 2.70     | 19.48    | 9.62     | 1.31     | 75387.98  |
| 22                | 9.35     | 11.52    | 59.33    | 2.85     | 19.33    | 9.80     | 1.31     | 74162.80  |
| 23                | 9.19     | 12.25    | 52.73    | 2.77     | 19.79    | 9.60     | 1.31     | 75504.11  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 7.51     | 12.20    | 53.59    | 2.67     | 19.54    | 9.93     | 1.28     | 75963.85  |
| 最 大 值             | 12.34    | 12.99    | 63.19    | 3.26     | 22.12    | 10.56    | 1.31     | 84027.94  |
| 發生時間              | 18       | 11       | 20       | 20       | 2        | 0        |          | 7         |
| 最 小 值             | 4.65     | 11.29    | 43.16    | 2.19     | 17.44    | 9.34     | 1.23     | 71480.72  |
| 發生時間              | 8        | 21       | 2        | 2        | 17       | 13       |          | 0         |
| 零點偏移(率)           | -0.05 %  | -0.03 %  | -0.01 %  | -0.02 %  |          | -0.02    | -0.01    | 0.10 %    |
| 全幅偏移(率)           | -0.45 %  | 1.59 %   | 0.89 %   | 1.02 %   |          | 0.12     | 0.00     | 0.10 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |