

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.98	1.72	41.86	3.46	19.42	10.08	1.33	76011.30
1	7.11	1.86	51.59	3.21	17.82	11.05	1.33	71605.87
2	8.94	1.99	57.59	3.36	17.70	11.22	1.33	70830.71
3	8.78	1.79	52.23	3.90	17.44	10.99	1.33	72494.21
4	9.46	1.68	60.69	3.91	17.23	11.24	1.33	70570.07
5	12.35	6.26	52.20	4.47	16.91	11.20	1.33	70280.12
6	10.91	8.00	61.40	4.52	15.55	11.61	1.33	69716.90
7	7.53	3.28	46.55	4.37	15.25	12.02	1.33	67173.54
8	8.90	2.54	43.84	4.15	15.76	11.33	1.31	71350.28
9	6.76	2.31	43.81	3.99	15.48	11.40	1.29	68949.32
10	7.30	1.83	52.04	4.32	17.00	11.06	1.32	71216.25
11	8.72	1.78	57.58	5.38	17.29	11.20	1.29	70366.98
12	10.00	2.89	51.43	4.32	16.18	11.23	1.28	71271.83
13	9.67	1.95	63.87	3.82	16.73	11.28	1.29	71064.94
14	10.08	1.96	55.90	3.81	16.08	11.38	1.30	70927.31
15	10.41	1.87	57.69	3.96	16.27	11.30	1.30	70879.64
16	10.14	3.96	55.67	4.62	15.41	11.63	1.31	69229.38
17	11.14	2.06	52.78	4.70	17.02	10.79	1.33	73421.69
18	8.45	2.09	52.84	4.33	15.68	11.15	1.33	70148.88
19	10.29	1.65	58.16	3.73	16.63	10.89	1.33	71578.89
20	9.00	1.63	50.31	4.22	16.19	11.26	1.31	70365.87
21	8.58	1.53	59.32	3.81	16.54	11.27	1.30	70130.14
22	10.45	1.69	51.07	4.13	15.82	11.27	1.28	71559.82
23	10.11	1.76	55.98	3.91	16.69	11.02	1.28	71841.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.38	2.50	53.60	4.10	16.59	11.20	1.31	70957.74
最大值	12.35	8.00	63.87	5.38	19.42	12.02	1.36	76011.30
發生時間	5	6	13	11	0	7		0
最小值	6.76	1.53	41.86	3.21	15.25	10.08	1.28	67173.54
發生時間	9	21	0	1	7	0		7
零點偏移(率)	-0.02 %	-0.02 %	-0.03 %	-0.01 %		0.08	0.00	0.00 %
全幅偏移(率)	-0.14 %	-0.67 %	0.14 %	-0.72 %		0.10	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.48	3.09	39.99	1.45	19.08	9.25	1.41	82867.56
1	8.06	2.73	59.29	1.42	20.17	9.60	1.40	86407.84
2	9.58	1.59	58.62	1.78	19.31	10.02	1.41	86325.71
3	9.31	1.54	56.76	1.78	19.01	9.90	1.41	87798.41
4	5.50	1.76	37.57	1.15	19.94	10.02	1.39	81189.43
5	5.57	6.30	49.31	1.34	20.34	9.58	1.39	82686.82
6	0.46	7.34	50.36	1.45	17.92	9.94	1.38	76629.37
7	0.35	6.87	49.29	0.99	21.09	9.06	1.40	82635.07
8	2.87	2.23	48.76	1.50	18.80	9.23	1.42	84868.03
9	9.79	4.13	45.16	2.10	19.75	9.29	1.40	83506.16
10	9.79	4.39	59.36	2.09	20.11	9.18	1.40	83559.74
11	7.25	5.17	51.47	2.20	19.52	9.11	1.38	79852.06
12	10.31	2.22	55.96	2.12	19.57	8.94	1.39	83071.79
13	9.65	2.80	58.90	1.84	19.63	9.20	1.40	82259.26
14	10.04	3.15	45.20	2.68	17.95	8.99	1.38	77912.79
15	9.28	2.88	43.37	2.35	18.23	8.87	1.38	79537.17
16	9.82	3.00	55.99	2.36	20.32	8.03	1.38	82805.98
17	9.79	2.20	60.90	2.59	18.08	8.61	1.38	80087.09
18	9.46	2.45	46.84	2.45	17.49	8.92	1.38	78371.82
19	9.45	3.89	49.35	1.88	19.58	8.59	1.38	82268.94
20	9.83	2.09	50.00	2.11	18.46	9.15	1.38	79449.13
21	8.94	5.13	46.70	1.64	19.08	9.11	1.38	82432.23
22	9.82	1.93	54.04	2.23	18.79	8.92	1.38	80393.83
23	10.59	1.30	57.00	2.57	17.81	9.60	1.38	79623.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.00	3.34	51.26	1.92	19.17	9.21	1.39	81939.14
最大值	10.59	7.34	60.90	2.68	21.09	10.02	1.43	87798.41
發生時間	23	6	17	14	7	2		3
最小值	0.35	1.30	37.57	0.99	17.49	8.03	1.38	76629.37
發生時間	7	23	4	7	18	16		6
零點偏移(率)	-0.06 %	-0.12 %	-0.02 %	-0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	0.56 %	-1.23 %	0.20 %	-0.74 %		0.06	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.11	2.80	51.47	3.80	17.37	10.19	1.28	82268.93
1	5.86	2.60	65.03	3.78	19.19	10.50	1.27	79834.57
2	7.43	3.53	39.93	3.93	18.40	10.63	1.28	79834.65
3	6.85	2.49	51.92	4.01	17.18	10.16	1.29	82724.84
4	4.61	2.23	54.19	3.85	17.04	10.82	1.28	78391.99
5	13.80	3.35	50.98	4.70	16.85	10.11	1.28	83851.70
6	8.76	4.90	53.05	3.92	17.05	10.46	1.29	81973.88
7	12.79	7.22	65.48	3.88	16.73	10.38	1.29	73458.68
8	4.93	4.26	62.61	3.26	16.12	10.41	1.29	81020.98
9	8.38	1.97	62.38	3.91	15.76	10.44	1.32	80368.40
10	9.47	2.58	58.16	3.84	16.47	10.35	1.29	80465.85
11	8.15	2.13	64.16	3.48	18.03	9.97	1.33	82968.78
12	8.04	5.07	55.34	3.45	15.65	10.39	1.34	79889.91
13	8.90	1.95	68.22	3.37	16.98	10.73	1.35	79984.34
14	10.63	3.96	60.42	3.79	15.64	10.52	1.32	83084.13
15	11.75	3.53	63.91	4.02	15.04	11.06	1.30	81526.49
16	13.08	1.89	64.32	3.92	16.33	10.23	1.26	83182.08
17	12.63	2.08	58.54	3.53	16.30	10.33	1.31	81247.71
18	10.04	3.32	57.98	3.31	16.39	10.07	1.31	80625.34
19	8.46	4.49	52.31	3.74	15.20	10.19	1.30	77381.57
20	9.17	2.84	56.41	3.34	16.67	9.85	1.30	79516.80
21	7.68	5.89	52.01	4.02	15.25	9.92	1.28	77698.64
22	9.63	2.95	53.26	3.41	15.84	10.00	1.25	77729.82
23	8.19	4.98	56.64	3.83	14.59	10.45	1.25	74702.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.06	3.46	57.45	3.75	16.50	10.34	1.29	80155.50
最大值	13.80	7.22	68.22	4.70	19.19	11.06	1.38	83851.70
發生時間	5	7	13	5	1	15		5
最小值	4.61	1.89	39.93	3.26	14.59	9.85	1.24	73458.68
發生時間	4	16	2	8	23	20		7
零點偏移(率)	-0.01 %	0.00 %	-0.09 %	0.00 %		0.09	0.00	0.00 %
全幅偏移(率)	-0.41 %	0.74 %	-0.06 %	-0.00 %		0.34	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								