

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月07日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	2.13	13.42	45.81	0.59	17.99	11.03	0.99	79399.40
1	2.56	13.71	55.76	1.01	18.92	11.54	1.00	75037.35
2	2.22	12.46	44.80	0.35	18.74	10.62	0.97	82675.21
3	2.13	13.15	53.75	0.80	17.84	11.32	1.00	77835.79
4	2.13	12.27	50.17	0.40	18.31	10.63	0.99	82919.14
5	2.07	12.03	39.47	0.49	18.40	10.39	0.99	84944.21
6	2.69	11.91	43.95	0.46	18.17	10.37	0.99	83377.99
7	2.57	13.77	58.99	0.46	17.53	11.82	1.01	73347.63
8	2.61	14.49	65.60	0.71	17.66	12.17	1.05	70352.51
9	2.40	12.99	38.48	0.82	18.88	10.43	1.00	82876.10
10	2.08	13.44	41.52	1.16	17.08	10.61	0.98	83734.14
11	1.91	12.20	45.09	1.64	16.10	10.78	0.99	82818.16
12	1.82	13.40	50.87	2.07	15.41	11.38	0.98	77478.62
13	1.94	13.20	48.29	0.90	16.63	10.81	0.96	81012.26
14	2.09	13.29	39.76	0.74	17.16	10.67	0.97	81664.83
15	1.86	14.25	41.50	1.32	15.61	11.05	0.97	80733.92
16	1.96	12.12	38.80	0.66	17.21	10.38	0.96	83954.26
17	2.03	12.58	46.19	0.79	17.36	10.53	0.97	82886.36
18	2.18	12.06	49.84	0.60	17.53	10.40	0.97	82154.29
19	2.30	12.72	54.80	1.29	16.60	10.35	0.97	82565.71
20	2.87	12.72	54.16	1.06	16.73	10.32	0.97	80780.77
21	3.05	13.20	55.86	1.05	16.94	10.21	0.98	82025.09
22	5.33	11.84	53.71	0.30	18.87	9.96	0.99	84909.85
23	6.74	12.53	38.68	0.52	17.43	10.62	0.99	83516.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.57	12.91	48.16	0.84	17.46	10.77	0.99	80958.34
最 大 值	6.74	14.49	65.60	2.07	18.92	12.17	1.10	84944.21
發生時間	23	8	8	12	1	8		5
最 小 值	1.82	11.84	38.48	0.30	15.41	9.96	0.95	70352.51
發生時間	12	22	9	22	12	22		8
零點偏移(率)	0.00 %	0.00 %	-0.20 %	0.00 %		-0.07		-0.10 %
全幅偏移(率)	0.58 %	0.49 %	0.13 %	-0.24 %		-0.24		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月07日

報表日期: 114年10月07日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.75	13.45	57.97	0.47	18.15	10.41	1.36	77023.66
1	8.68	13.56	60.13	0.88	19.43	10.05	1.36	79785.35
2	10.58	12.99	59.30	1.01	18.31	9.97	1.36	79681.39
3	10.58	13.44	47.67	0.94	18.94	9.44	1.41	84431.23
4	8.42	12.20	63.83	0.86	17.57	10.46	1.41	74734.25
5	10.40	11.69	54.69	1.37	19.07	9.90	1.42	82710.27
6	6.88	11.96	55.41	0.76	17.87	10.31	1.43	80008.53
7	6.20	12.75	60.76	0.64	18.59	11.02	1.38	76374.23
8	7.96	12.18	38.17	0.62	20.04	9.78	1.41	81773.38
9	12.83	11.68	47.75	1.14	18.76	9.81	1.40	84515.30
10	9.15	13.26	51.18	1.19	16.83	10.51	1.35	82186.12
11	8.57	12.73	49.89	1.42	16.86	10.26	1.38	77259.57
12	8.10	11.82	47.20	1.12	17.56	9.81	1.39	74380.53
13	10.83	14.08	42.96	0.92	17.39	9.78	1.41	75706.91
14	9.97	13.30	46.30	1.20	16.00	10.48	1.40	74447.07
15	7.41	13.15	45.68	0.78	16.70	10.41	1.39	72408.01
16	10.17	12.54	49.34	0.79	16.41	10.60	1.36	80910.34
17	8.09	11.88	53.16	0.75	17.74	9.90	1.36	82519.54
18	10.35	11.44	45.81	1.02	19.61	8.54	1.40	82286.97
19	6.69	12.16	43.87	0.68	19.06	8.22	1.35	80316.54
20	8.74	11.13	52.38	0.97	18.19	8.56	1.35	77469.26
21	8.47	13.28	51.93	0.85	18.69	8.14	1.35	76695.72
22	12.32	12.99	58.00	1.20	18.63	8.89	1.35	81470.55
23	10.33	11.77	52.03	0.89	17.65	9.57	1.36	80794.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.10	12.56	51.48	0.94	18.09	9.78	1.38	79162.07
最 大 值	12.83	14.08	63.83	1.42	20.04	11.02	1.43	84515.30
發生時間	9	13	4	11	8	7		9
最 小 值	6.20	11.13	38.17	0.47	16.00	8.14	1.34	72408.01
發生時間	7	20	8	0	14	21		15
零點偏移(率)	-0.12 %	0.01 %	-0.03 %	0.00 %		-0.04		0.10 %
全幅偏移(率)	0.54 %	-0.14 %	0.13 %	0.92 %		0.39		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								