

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.76	4.55	51.78	1.72	16.21	11.90	1.06	79278.07
1	3.55	5.80	56.86	1.81	16.97	12.21	1.06	75827.38
2	6.16	5.14	41.16	1.79	16.67	11.35	1.06	82856.82
3	5.84	5.50	53.17	1.71	15.64	12.20	1.05	75728.33
4	2.16	5.26	56.91	1.35	16.18	11.97	1.04	78583.50
5	1.68	4.69	61.40	0.82	17.95	11.65	1.06	81079.80
6	4.04	4.70	44.00	1.45	17.00	10.96	1.05	81501.87
7	2.10	4.79	51.15	2.81	13.53	11.50	1.04	77169.39
8	2.67	5.66	58.53	3.17	13.96	11.96	1.06	77908.14
9	1.42	4.63	66.33	1.12	16.75	11.77	1.06	80019.14
10	3.64	4.84	38.32	1.57	16.22	11.46	1.04	82807.83
11	7.82	4.08	59.33	1.86	16.16	11.48	1.07	82297.87
12	10.98	6.76	43.33	2.91	14.59	11.94	1.05	77619.49
13	8.57	4.26	45.85	3.80	14.36	11.79	1.06	79039.32
14	2.12	7.87	58.04	1.80	15.58	11.72	1.06	80248.65
15	6.81	7.96	63.35	1.87	15.70	11.77	1.07	80024.13
16	8.47	6.00	56.09	1.94	15.32	11.74	1.06	80194.91
17	5.16	6.11	46.80	2.69	14.33	11.87	1.05	78726.18
18	3.96	8.33	59.57	1.85	15.13	12.14	1.02	76561.93
19	2.91	7.77	63.98	1.68	15.09	11.78	1.03	80417.29
20	9.21	6.59	60.92	2.15	15.40	11.81	1.04	79414.85
21	9.38	5.88	65.25	1.65	16.21	11.55	1.05	79945.75
22	8.76	6.46	63.76	1.31	16.30	11.74	1.06	79315.85
23	6.12	7.37	56.97	0.89	17.19	11.84	1.07	78604.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.47	5.88	55.12	1.91	15.77	11.75	1.05	79382.13
最大值	10.98	8.33	66.33	3.80	17.95	12.21	1.09	82856.82
發生時間	12	18	9	13	5	1		2
最小值	1.42	4.08	38.32	0.82	13.53	10.96	1.02	75728.33
發生時間	9	11	10	5	7	6		3
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	0.01 %		0.01		0.00 %
全幅偏移(率)	0.00 %	-0.28 %	-0.02 %	0.22 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.93	2.69	59.49	1.07	17.76	11.07	1.05	79033.55
1	3.60	4.67	42.50	2.12	17.03	10.94	1.05	80392.20
2	2.95	4.13	65.43	1.91	15.79	12.39	1.06	70714.21
3	2.71	3.89	38.41	1.41	17.59	11.41	1.06	76836.09
4	2.99	3.45	45.05	2.72	15.49	11.24	1.05	79780.05
5	5.07	3.86	48.48	2.89	15.82	11.21	1.06	79578.93
6	2.92	3.86	44.68	3.46	13.27	11.83	1.04	72771.05
7	4.29	2.66	58.09	2.75	13.43	12.12	1.03	74060.87
8	0.14	1.90	60.90	1.57	13.49	12.13	0.99	74491.52
9	0.45	2.18	57.08	2.28	13.30	12.24	1.00	73424.44
10	1.17	4.04	48.71	2.92	14.29	12.01	1.03	74017.93
11	10.65	5.54	39.54	3.60	15.14	11.31	1.02	79292.33
12	12.28	3.98	57.75	3.46	14.56	11.54	1.03	77681.15
13	6.17	3.40	51.30	2.36	15.34	11.50	1.02	78225.13
14	1.58	3.84	49.67	1.98	15.92	11.38	1.03	78077.14
15	2.48	2.61	49.87	2.38	15.42	11.48	1.04	78025.20
16	2.23	4.22	44.52	2.21	14.77	11.82	1.01	75506.88
17	7.77	4.23	53.16	2.02	15.92	11.47	1.02	77988.22
18	2.29	6.65	47.40	2.89	14.21	11.64	1.02	77446.51
19	4.57	4.35	50.56	2.32	16.20	11.09	1.02	80248.35
20	10.19	3.15	45.46	3.13	15.30	11.21	1.03	79720.30
21	10.00	2.98	47.40	3.31	15.67	11.21	1.03	79504.04
22	8.05	2.82	60.12	2.33	15.62	11.68	1.04	75300.46
23	3.26	4.27	60.98	1.36	17.40	11.67	1.04	74063.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.61	3.72	51.11	2.44	15.36	11.57	1.03	76924.16
最大值	12.28	6.65	65.43	3.60	17.76	12.39	1.06	80392.20
發生時間	12	18	2	11	0	2		1
最小值	0.14	1.90	38.41	1.07	13.27	10.94	0.98	70714.21
發生時間	8	8	3	0	6	1		2
零點偏移(率)	-0.05 %	0.00 %	-0.03 %	-0.03 %		-0.04		-0.10 %
全幅偏移(率)	-0.25 %	0.28 %	0.28 %	0.23 %		-0.23		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.62	2.61	57.87	0.58	17.74	10.65	1.04	80435.37
1	3.42	4.53	54.33	0.70	18.41	10.64	1.03	79130.09
2	2.91	3.98	54.63	0.94	16.07	10.87	1.02	78751.32
3	3.72	4.09	56.79	0.84	16.29	10.89	1.04	78357.74
4	2.72	3.62	55.47	0.92	16.35	10.48	1.04	81619.55
5	5.57	3.64	49.38	1.59	15.22	10.50	1.02	79512.26
6	1.99	4.15	54.29	1.90	14.55	10.91	1.03	78515.29
7	3.08	2.78	59.92	1.93	14.27	11.16	1.04	72444.92
8	5.34	2.99	55.32	2.59	13.76	11.04	1.03	75083.30
9	12.09	3.39	59.44	3.25	13.97	10.76	1.04	77388.17
10	5.67	2.24	57.97	2.84	14.47	11.00	1.03	72823.13
11	9.69	6.33	56.86	2.76	17.36	10.09	1.04	77813.62
12	9.87	6.30	53.85	4.43	16.21	10.33	1.03	75596.79
13	2.01	5.52	54.43	1.68	16.37	10.41	1.04	75056.04
14	2.00	5.85	57.10	1.08	15.23	10.55	1.04	75276.94
15	0.31	5.02	55.99	0.86	15.50	10.59	1.04	75175.52
16	1.34	4.72	55.55	1.28	14.84	10.75	1.01	74332.54
17	4.21	4.72	52.78	1.31	15.09	10.61	1.01	75993.91
18	7.74	3.98	57.76	1.36	15.37	10.72	1.03	76149.80
19	7.89	8.41	55.09	2.19	14.26	10.80	1.04	74917.22
20	9.20	4.03	62.01	1.39	15.44	10.77	1.03	78160.73
21	9.33	5.10	53.14	1.46	15.65	10.62	1.02	76522.98
22	3.85	5.43	49.60	0.62	17.29	10.38	1.02	78106.22
23	1.35	5.62	56.82	0.67	17.09	10.93	1.04	74536.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.96	4.54	55.68	1.63	15.70	10.69	1.03	76737.50
最大值	12.09	8.41	62.01	4.43	18.41	11.16	1.04	81619.55
發生時間	9	19	20	12	1	7		4
最小值	0.31	2.24	49.38	0.58	13.76	10.09	0.99	72444.92
發生時間	15	10	5	0	8	11		7
零點偏移(率)	-0.10 %	0.00 %	-0.01 %	0.01 %		-0.01		-0.10 %
全幅偏移(率)	0.02 %	0.31 %	-0.00 %	0.29 %		-0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								