

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月18日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.27	11.27	64.44	1.98	18.94	10.85	1.10	75587.89
1	8.94	11.19	62.62	1.70	20.37	10.56	1.10	76256.64
2	9.40	11.08	43.99	2.08	19.71	10.56	1.10	76567.96
3	9.38	11.11	50.46	2.11	19.05	10.66	1.11	76961.63
4	9.34	11.34	45.43	2.31	18.01	11.02	1.12	74765.59
5	10.48	12.17	59.52	2.68	20.51	10.21	1.13	75503.49
6	8.74	12.63	51.13	3.45	17.98	11.03	1.13	74715.05
7	7.65	12.87	58.86	3.51	18.64	10.88	1.13	74963.69
8	11.46	13.11	52.80	2.66	19.97	10.65	1.13	76165.94
9	9.33	12.99	52.64	1.85	19.74	10.90	1.11	73787.96
10	10.44	13.00	57.97	1.84	18.44	11.17	1.13	73414.74
11	8.27	12.98	47.90	2.01	17.67	11.25	1.11	73126.34
12	9.86	13.09	53.47	2.10	17.38	11.51	1.12	71478.37
13	10.06	12.81	57.75	1.57	18.83	11.12	1.13	73787.88
14	11.74	13.04	54.95	2.21	17.98	11.23	1.13	73285.23
15	12.88	13.36	55.93	3.23	16.05	11.48	1.11	72638.81
16	9.14	13.11	63.28	1.95	17.21	11.49	1.13	71528.87
17	12.82	13.28	60.47	2.00	16.02	11.77	1.10	70948.60
18	7.81	13.19	61.14	1.47	17.40	11.40	1.11	71975.77
19	9.75	13.14	63.25	1.57	17.53	11.24	1.12	73627.60
20	9.88	12.64	62.78	1.29	19.06	10.93	1.13	74314.20
21	9.40	12.91	58.70	1.64	18.37	10.95	1.13	74796.61
22	12.85	12.89	63.99	1.60	18.36	11.20	1.13	73534.34
23	9.19	12.86	63.18	1.60	18.06	11.23	1.13	73058.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.92	12.59	56.94	2.10	18.39	11.05	1.12	74033.01
最 大 值	12.88	13.36	64.44	3.51	20.51	11.77	1.13	76961.63
發生時間	15	15	0	7	5	17		3
最 小 值	7.65	11.08	43.99	1.29	16.02	10.21	1.10	70948.60
發生時間	7	2	2	20	17	5		17
零點偏移(率)	0.00 %	-0.00 %	-0.06 %	0.01 %		-0.03	-0.01	0.20 %
全幅偏移(率)	-0.60 %	-0.48 %	1.01 %	-0.27 %		-0.13	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月18日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月18日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.97	11.54	52.09	2.35	17.86	10.06	1.31	76681.40
1	8.61	12.07	49.99	4.05	19.46	9.66	1.30	76525.98
2	9.63	11.17	43.54	1.17	19.22	9.40	1.29	75908.62
3	9.96	11.51	45.77	0.97	18.07	9.50	1.29	74154.22
4	9.01	11.44	52.43	0.97	17.46	10.07	1.30	73736.24
5	10.03	11.40	49.62	0.93	17.88	9.83	1.31	73475.60
6	9.91	11.11	49.66	0.96	17.87	9.73	1.30	72830.86
7	4.10	24.40	51.42	4.10	20.36	9.16	1.25	73119.05
8	9.41	10.78	55.35	2.16	19.23	9.75	1.26	80579.02
9	9.18	11.58	58.38	1.67	19.02	10.19	1.28	76091.62
10	10.30	11.56	58.44	1.68	17.93	10.30	1.25	75204.28
11	9.04	11.70	57.51	1.57	16.37	10.62	1.23	72282.19
12	9.19	11.60	57.36	1.61	17.28	10.32	1.23	73932.20
13	10.57	12.22	58.14	1.60	17.54	10.35	1.23	73357.26
14	9.66	13.00	64.46	1.66	17.16	10.62	1.23	74589.07
15	9.42	12.58	60.33	2.54	16.85	10.84	1.25	71075.65
16	12.21	12.86	60.22	3.64	16.87	10.49	1.27	73779.59
17	9.63	12.19	63.96	3.21	16.58	10.57	1.24	72321.14
18	10.99	12.06	65.80	3.32	16.46	10.76	1.23	74177.26
19	5.53	13.37	66.58	2.50	16.58	10.60	1.26	73479.34
20	7.96	11.02	51.66	1.22	18.12	9.67	1.27	75017.84
21	9.76	11.65	57.28	1.17	17.49	10.53	1.27	74143.38
22	11.34	11.96	58.13	1.16	17.97	10.73	1.27	76168.19
23	7.63	11.99	56.01	1.13	18.24	10.73	1.29	76318.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.29	12.36	56.01	1.97	17.83	10.19	1.27	74539.51
最 大 值	12.21	24.40	66.58	4.10	20.36	10.84	1.33	80579.02
發生時間	16	7	19	7	7	15		8
最 小 值	4.10	10.78	43.54	0.93	16.37	9.16	1.21	71075.65
發生時間	7	8	2	5	11	7		15
零點偏移(率)	-0.02 %	0.00 %	-0.31 %	-0.01 %		-0.01	-0.01	0.00 %
全幅偏移(率)	-0.33 %	-0.37 %	0.59 %	0.11 %		0.24	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								