

## P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年11月25日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.17	11.49	65.21	2.11	15.40	12.00	1.34	76672.08
1	15.90	12.52	57.42	3.01	15.61	11.14	1.34	84470.51
2	17.42	15.34	43.75	3.72	14.99	11.64	1.34	80758.81
3	10.81	12.15	54.59	2.27	14.88	10.77	1.34	88015.02
4	7.18	14.82	59.67	2.27	14.18	12.94	1.32	69776.81
5	13.18	11.19	51.44	3.57	16.68	10.90	1.29	80518.49
6	9.67	11.14	38.56	2.59	14.77	11.04	1.29	86043.10
7	12.55	11.52	51.55	2.37	16.35	11.13	1.27	83563.97
8	5.93	12.87	49.58	2.27	14.75	11.63	1.28	80764.82
9	5.77	11.92	46.69	1.68	15.51	11.54	1.28	81292.65
10	7.17	12.23	43.13	2.62	14.71	11.96	1.29	80186.36
11	4.63	13.21	63.48	1.48	13.68	12.73	1.29	73221.34
12	2.95	13.34	45.67	1.68	14.05	11.54	1.29	82877.35
13	6.94	14.45	40.58	1.92	13.94	11.62	1.32	82523.09
14	2.98	12.55	43.16	1.55	13.82	11.98	1.30	79215.72
15	2.49	12.20	43.30	1.68	14.04	11.75	1.29	80429.63
16	6.33	12.23	54.45	1.47	14.92	12.02	1.29	77381.51
17	11.21	11.16	42.27	2.30	15.51	10.82	1.29	87090.78
18	10.93	11.65	45.74	3.15	14.63	11.14	1.29	85838.94
19	11.30	12.61	37.82	1.97	14.49	11.28	1.30	84156.11
20	12.51	13.16	33.64	2.03	15.01	11.11	1.31	85474.04
21	9.27	13.88	41.71	1.88	16.55	10.67	1.32	87764.81
22	12.78	11.37	50.68	3.75	13.42	11.27	1.33	85978.52
23	6.72	11.38	62.49	1.72	15.61	11.28	1.31	83477.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.95	12.52	48.61	2.29	14.90	11.50	1.30	81978.83
最 大 值	17.42	15.34	65.21	3.75	16.68	12.94	1.34	88015.02
發生時間	2	2	0	22	5	4		3
最 小 值	2.49	11.14	33.64	1.47	13.42	10.67	1.27	69776.81
發生時間	15	6	20	16	22	21		4
零點偏移(率)	0.00 %	-0.01 %	-0.04 %	-0.01 %		0.02	-0.01	0.20 %
全幅偏移(率)	0.21 %	0.62 %	-0.47 %	0.30 %		0.20	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								



