

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.76	3.02	69.02	1.68	16.63	12.20	1.31	71450.58
1	1.53	8.16	49.58	0.94	19.61	10.99	1.31	76983.45
2	9.26	5.95	56.84	1.95	18.91	10.01	1.31	87146.35
3	8.69	8.22	55.72	2.68	15.48	11.10	1.32	81037.67
4	8.29	9.76	56.76	2.00	16.29	11.55	1.32	77536.07
5	4.96	3.40	54.04	1.66	16.79	11.36	1.34	76079.60
6	3.29	6.99	54.58	1.00	17.59	10.72	1.34	77255.39
7	8.74	6.19	57.53	1.32	17.70	10.58	1.34	84219.09
8	6.22	3.72	64.53	1.54	17.18	11.46	1.33	80711.02
9	1.99	7.08	59.15	1.19	17.77	11.97	1.30	77898.57
10	0.71	6.61	58.43	0.93	17.19	11.58	1.32	81724.85
11	1.94	6.25	55.51	1.30	16.28	11.55	1.34	80187.55
12	0.12	5.80	41.02	2.14	15.20	11.98	1.31	74844.65
13	2.47	3.14	60.54	1.46	16.36	12.37	1.31	73978.16
14	3.60	7.56	47.50	2.04	16.79	11.73	1.33	80055.21
15	3.17	2.92	58.95	1.26	17.10	11.87	1.31	77818.64
16	0.61	3.46	55.88	1.65	16.55	11.82	1.31	80199.52
17	4.72	4.06	53.29	2.07	16.20	11.81	1.30	79675.54
18	5.73	5.94	49.26	2.31	15.92	11.76	1.30	81046.08
19	1.09	3.08	63.15	1.00	17.52	11.73	1.30	78635.27
20	0.72	3.08	54.00	0.96	18.25	10.99	1.32	81327.26
21	0.48	3.41	58.95	0.84	17.83	11.33	1.32	78663.69
22	0.51	3.91	51.26	1.43	17.12	11.07	1.33	80747.42
23	0.59	3.17	65.84	0.87	17.35	12.15	1.34	72103.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.42	5.20	56.31	1.51	17.07	11.49	1.32	78805.22
最 大 值	9.26	9.76	69.02	2.68	19.61	12.37	1.34	87146.35
發生時間	2	4	0	3	1	13		2
最 小 值	0.12	2.92	41.02	0.84	15.20	10.01	1.29	71450.58
發生時間	12	15	12	21	12	2		0
零點偏移(率)	-0.07 %	0.00 %	-0.12 %	-0.01 %		-0.04		0.20 %
全幅偏移(率)	0.00 %	-0.03 %	0.23 %	0.34 %		0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年05月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.03	3.44	49.48	3.37	17.90	10.37	1.05	85377.10
1	10.19	2.28	49.91	2.71	17.23	10.44	1.05	86338.89
2	6.70	3.69	60.83	2.55	16.69	10.54	1.05	86124.39
3	10.06	1.45	65.04	2.72	15.30	10.91	1.05	84673.32
4	9.14	2.59	52.84	2.22	17.01	10.60	1.05	84590.73
5	10.12	3.41	53.99	2.37	16.09	10.75	1.05	83365.80
6	9.75	3.10	56.26	2.25	17.89	10.26	1.04	81697.60
7	9.17	1.45	67.10	2.59	17.62	9.98	1.05	86128.21
8	11.99	5.02	52.82	2.90	16.15	10.79	1.05	81119.60
9	12.99	5.47	51.95	3.15	15.93	10.48	1.04	84392.22
10	9.94	4.32	53.40	3.91	14.77	11.28	1.03	82144.57
11	12.37	2.22	55.16	2.95	14.62	11.78	1.04	79310.31
12	10.94	1.72	56.97	2.54	15.04	11.74	1.03	80450.32
13	10.09	1.92	58.38	2.82	15.15	11.87	1.02	80395.71
14	校正	校正	校正	校正	替代	校正	1.03	85884.24
15	10.15	4.12	55.86	2.82	15.14	11.51	1.04	80081.07
16	11.07	5.93	49.14	2.46	16.04	10.79	1.04	79099.28
17	10.32	3.71	51.88	1.91	17.18	10.51	1.04	82417.00
18	12.35	9.34	54.00	3.44	15.57	10.45	1.04	84937.35
19	9.59	7.07	60.90	4.00	14.35	11.06	1.04	81265.12
20	13.36	3.54	59.91	3.14	15.64	10.51	1.03	83206.40
21	13.35	1.60	59.00	2.38	17.40	9.84	1.03	84009.27
22	10.25	4.21	63.12	2.97	15.69	10.46	1.02	82261.44
23	12.88	1.31	66.32	2.18	16.31	10.68	1.03	82758.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	24
平 均 值	10.64	3.60	56.71	2.80	16.12	10.77	1.04	83001.19
最 大 值	13.36	9.34	67.10	4.00	17.90	11.87	1.06	86338.89
發生時間	20	18	7	19	0	13		1
最 小 值	6.70	1.31	49.14	1.91	14.35	9.84	1.02	79099.28
發生時間	2	23	16	17	19	21		16
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.08 %		-0.11		-0.10 %
全幅偏移(率)	0.14 %	-0.41 %	-0.02 %	0.16 %		-0.07		0.00 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月05日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.01	3.46	63.19	2.55	18.89	9.49	1.48	84322.79
1	8.61	7.47	57.66	3.02	17.55	10.07	1.48	81197.22
2	9.24	2.15	59.54	2.95	16.29	10.14	1.48	80140.37
3	9.17	5.21	67.31	3.50	16.07	9.87	1.48	80109.22
4	7.86	2.90	67.99	3.01	16.30	9.65	1.47	82444.94
5	8.96	8.77	60.85	2.99	15.46	10.47	1.48	81343.00
6	6.79	4.37	59.66	2.48	16.33	10.24	1.48	81193.39
7	1.66	3.78	54.83	1.88	17.19	9.92	1.48	84153.82
8	4.78	3.67	61.38	2.28	17.28	9.58	1.51	79013.51
9	6.52	1.67	64.59	2.65	15.81	10.30	1.49	78561.17
10	5.54	2.48	66.56	2.31	16.46	10.26	1.48	75470.70
11	2.55	5.43	58.45	2.03	16.84	9.86	1.49	76953.72
12	7.70	7.96	59.35	2.43	16.51	9.82	1.50	75784.40
13	2.38	2.84	62.29	1.93	16.47	10.40	1.50	71785.75
14	2.82	4.47	58.72	1.88	17.34	9.99	1.48	74047.80
15	4.91	4.17	63.63	2.16	16.95	10.55	1.48	79198.22
16	2.48	2.55	49.54	1.86	17.44	9.89	1.47	79051.80
17	4.88	7.01	51.95	2.35	16.47	9.73	1.46	79148.52
18	3.62	1.53	65.72	1.96	16.81	10.23	1.46	76492.87
19	2.40	6.45	65.25	1.90	17.74	9.38	1.46	79133.13
20	4.88	9.35	50.75	2.15	18.18	9.28	1.46	80264.28
21	6.11	1.54	55.55	1.81	16.96	9.67	1.48	78453.82
22	3.60	1.99	61.02	1.85	19.04	9.08	1.48	76704.12
23	5.32	7.90	55.57	2.65	19.58	8.73	1.48	82283.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.45	4.55	60.06	2.36	17.08	9.86	1.48	79052.17
最 大 值	9.24	9.35	67.99	3.50	19.58	10.55	1.53	84322.79
發生時間	2	20	4	3	23	15		0
最 小 值	1.66	1.53	49.54	1.81	15.46	8.73	1.46	71785.75
發生時間	7	18	16	21	5	23		13
零點偏移(率)	-0.05 %	-0.00 %	-0.02 %	0.00 %		-0.01		-0.20 %
全幅偏移(率)	0.02 %	0.90 %	0.68 %	0.69 %		-0.04		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								