

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.51	10.79	58.07	3.63	13.40	12.66	1.34	69357.23
1	2.35	6.70	58.96	3.31	14.48	13.19	1.35	63856.25
2	1.54	4.13	69.79	2.82	15.21	12.73	1.35	67449.11
3	3.60	5.70	54.12	2.56	15.41	12.07	1.33	72740.53
4	3.57	10.03	56.53	3.28	13.73	12.44	1.34	70856.70
5	6.21	7.99	71.03	2.92	14.74	12.22	1.42	72465.48
6	7.76	3.65	60.06	2.71	15.30	11.92	1.40	73863.29
7	6.55	7.42	46.23	3.36	13.90	12.37	1.39	70892.81
8	6.48	5.05	62.41	3.18	14.33	12.41	1.39	70657.49
9	8.13	4.72	60.36	3.33	13.93	12.44	1.38	71482.97
10	7.79	5.90	53.26	3.67	13.42	12.55	1.35	70939.96
11	8.31	10.08	49.73	4.16	12.59	12.65	1.34	70347.97
12	7.18	5.94	61.97	4.25	12.64	12.82	1.37	68433.95
13	8.87	6.67	49.73	4.88	11.53	12.99	1.39	67760.41
14	11.71	8.15	57.54	4.57	12.45	12.84	1.38	69341.96
15	10.64	8.71	57.47	4.51	12.55	12.75	1.40	69333.12
16	9.54	5.62	60.60	4.44	12.77	12.88	1.39	68139.12
17	10.23	8.28	58.82	4.34	12.10	12.79	1.38	69531.54
18	9.51	5.42	50.84	4.51	12.62	13.12	1.38	66879.78
19	10.34	1.82	70.73	3.42	14.00	12.44	1.37	70945.91
20	9.04	3.30	50.23	4.16	12.67	12.72	1.37	69296.49
21	9.70	5.38	60.27	3.99	13.18	12.59	1.35	70374.11
22	9.53	3.24	72.25	3.31	14.01	12.33	1.34	72584.12
23	11.68	6.71	51.80	4.22	12.62	12.67	1.33	69815.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.78	6.31	58.45	3.73	13.48	12.61	1.37	69889.41
最大值	11.71	10.79	72.25	4.88	15.41	13.19	1.46	73863.29
發生時間	14	0	22	13	3	1		6
最小值	1.54	1.82	46.23	2.56	11.53	11.92	1.33	63856.25
發生時間	2	19	7	3	13	6		1
零點偏移(率)	-0.12 %	0.00 %	-0.01 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	-0.10 %	-0.38 %	-0.14 %	-0.04 %		0.24	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.29	3.43	57.46	1.21	18.96	10.44	1.46	84361.33
1	6.82	4.54	48.37	1.17	19.95	10.01	1.46	87966.98
2	6.61	4.54	55.30	1.65	17.68	10.42	1.44	86542.01
3	7.05	8.15	51.37	1.91	17.17	10.28	1.43	85702.35
4	5.97	6.66	57.07	1.54	18.07	10.32	1.42	83944.58
5	9.41	8.53	52.52	1.80	18.14	10.02	1.41	86970.24
6	8.63	9.02	69.81	1.43	18.64	10.10	1.40	92961.48
7	5.90	3.37	51.35	1.55	17.90	10.07	1.41	83851.89
8	7.96	3.93	42.35	2.16	16.61	10.36	1.40	82648.45
9	8.52	3.97	52.28	2.84	14.84	11.34	1.39	81448.88
10	9.65	3.33	59.61	3.21	14.14	11.53	1.38	79846.84
11	4.93	3.28	55.48	2.20	15.92	11.20	1.37	83738.25
12	6.27	3.58	55.63	2.42	15.65	11.34	1.38	85014.82
13	8.04	4.05	59.36	2.76	14.97	11.43	1.38	84101.18
14	9.35	3.97	60.44	2.82	16.25	11.10	1.38	86643.89
15	9.60	3.22	50.20	3.57	15.12	11.28	1.38	79868.09
16	9.14	2.94	55.92	3.37	13.98	11.62	1.38	81379.46
17	9.04	2.92	62.61	2.34	15.85	10.86	1.38	84973.89
18	8.30	3.25	65.87	1.86	17.26	10.87	1.41	84296.37
19	10.34	3.15	60.76	2.29	15.93	10.91	1.41	84714.82
20	9.38	4.10	62.56	2.27	15.37	11.12	1.41	83782.92
21	10.04	3.73	68.93	2.09	16.49	10.87	1.39	85413.85
22	10.51	3.26	66.82	1.95	16.53	10.79	1.38	86233.47
23	7.19	4.91	64.56	1.73	16.91	10.83	1.36	85328.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.12	4.41	57.78	2.17	16.60	10.80	1.40	84655.62
最大值	10.51	9.02	69.81	3.57	19.95	11.62	1.47	92961.48
發生時間	22	6	6	15	1	16		6
最小值	4.93	2.92	42.35	1.17	13.98	10.01	1.36	79846.84
發生時間	11	17	8	1	16	1		10
零點偏移(率)	-0.08 %	-0.00 %	-0.08 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	2.27 %	-0.31 %	-0.15 %	0.26 %		0.26	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

