

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.79	4.41	57.30	2.21	14.77	11.54	1.31	77941.30
1	6.48	2.43	64.05	3.07	16.51	11.88	1.31	75952.56
2	9.94	3.69	56.46	3.54	15.34	11.63	1.30	81642.71
3	8.42	2.46	65.45	3.78	14.37	12.12	1.31	78265.64
4	7.25	6.71	58.36	2.53	16.62	11.72	1.31	79919.89
5	9.35	2.86	42.54	2.75	16.69	11.18	1.29	82071.80
6	3.25	4.23	54.86	2.55	15.97	11.82	1.29	77923.35
7	3.95	2.78	62.05	2.60	18.30	10.91	1.29	82683.54
8	5.55	3.98	54.23	3.90	15.10	11.39	1.29	79931.50
9	6.74	9.42	48.06	4.26	16.27	11.25	1.29	81476.05
10	0.25	13.46	61.61	2.39	18.35	10.99	1.29	80054.08
11	2.78	9.89	50.21	3.65	17.58	11.02	1.29	84441.41
12	3.24	6.25	66.83	3.35	17.31	11.16	1.31	83607.53
13	4.05	10.13	54.36	4.20	15.04	11.76	1.29	80187.80
14	3.94	1.88	68.85	3.82	15.50	11.74	1.29	80433.99
15	4.27	5.46	55.74	4.17	14.18	11.90	1.30	79244.04
16	9.58	2.82	67.00	2.99	15.95	11.49	1.31	81320.57
17	5.26	3.60	63.03	2.42	15.57	11.55	1.31	80775.99
18	7.10	2.60	59.26	1.84	16.61	11.34	1.30	82441.87
19	10.11	2.84	56.50	2.42	15.33	11.57	1.29	82015.12
20	7.66	2.75	62.10	2.00	15.47	11.66	1.30	80956.39
21	10.16	6.26	56.68	2.53	14.77	11.73	1.31	80873.24
22	8.02	2.89	59.11	2.16	15.55	11.52	1.31	81759.91
23	6.03	6.51	58.27	3.14	14.30	11.81	1.31	78887.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.34	5.01	58.45	3.01	15.89	11.53	1.30	80616.98
最 大 值	10.16	13.46	68.85	4.26	18.35	12.12	1.32	84441.41
發生時間	21	10	14	9	10	3		11
最 小 值	0.25	1.88	42.54	1.84	14.18	10.91	1.29	75952.56
發生時間	10	14	5	18	15	7		1
零點偏移(率)	-0.05 %	-0.02 %	-0.03 %	-0.01 %		-0.02		0.20 %
全幅偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月05日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.28	2.35	52.16	1.98	17.39	10.35	1.04	83979.57
1	7.25	2.62	57.72	2.44	17.53	10.33	1.04	84293.20
2	6.17	4.50	52.10	2.44	17.54	10.08	1.06	85002.25
3	5.46	5.05	62.28	1.86	18.14	10.43	1.06	81276.33
4	8.67	3.15	58.44	2.47	17.74	9.52	1.06	87787.00
5	10.16	1.88	58.53	3.20	16.16	10.52	1.06	83082.97
6	3.93	1.07	53.01	1.63	18.05	10.05	1.04	83199.82
7	3.46	3.24	48.84	1.87	17.76	9.97	1.04	84931.95
8	7.92	2.07	65.02	0.98	19.73	9.73	1.04	88129.98
9	8.82	2.69	70.70	1.58	19.32	9.83	1.05	88481.17
10	5.44	1.90	52.99	1.44	18.81	10.43	1.05	83235.20
11	2.77	5.38	51.61	1.95	17.04	10.40	1.05	83103.85
12	1.06	2.05	64.42	1.82	16.34	10.92	1.05	82414.82
13	7.60	4.51	68.88	1.53	17.76	10.27	1.05	85986.82
14	5.73	2.49	65.73	1.50	17.97	10.21	1.05	83145.16
15	5.65	6.80	61.82	2.06	17.07	10.23	1.04	78870.36
16	3.74	4.71	50.12	2.32	16.86	10.53	1.04	84350.63
17	2.34	1.90	58.28	2.27	15.58	11.12	1.06	82374.63
18	7.43	2.36	59.92	2.86	15.37	10.96	1.06	83047.18
19	11.13	2.87	67.86	2.41	17.42	10.53	1.06	85385.08
20	4.75	2.13	63.39	2.17	16.81	10.91	1.06	82320.91
21	6.82	1.49	52.15	2.05	18.16	9.92	1.05	88458.58
22	9.10	1.07	58.70	2.18	17.94	10.17	1.05	86485.99
23	7.00	1.59	48.20	1.94	17.78	10.03	1.05	81861.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.24	2.91	58.45	2.04	17.51	10.31	1.05	84216.89
最 大 值	11.13	6.80	70.70	3.20	19.73	11.12	1.08	88481.17
發生時間	19	15	9	5	8	17		9
最 小 值	1.06	1.07	48.20	0.98	15.37	9.52	1.03	78870.36
發生時間	12	6	23	8	18	4		15
零點偏移(率)	-0.11 %	-0.00 %	-0.50 %	-0.04 %		-0.04		-0.20 %
全幅偏移(率)	0.14 %	-0.29 %	0.90 %	-0.36 %		-0.07		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

