

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.07	6.03	54.28	3.14	14.25	12.37	1.40	69486.23
1	3.42	5.79	70.44	2.48	15.42	12.54	1.40	67203.52
2	3.75	6.91	62.76	3.09	14.18	12.62	1.41	67514.60
3	4.84	4.84	53.93	3.00	14.71	12.28	1.40	70706.48
4	3.71	8.05	67.56	3.47	13.38	12.97	1.41	65937.38
5	0.83	3.38	55.42	2.14	16.20	11.36	1.41	67305.87
6	10.56	2.34	54.63	3.66	14.51	11.33	1.37	73041.92
7	9.26	2.67	47.57	3.97	12.95	11.96	1.36	71378.04
8	8.92	8.36	46.16	4.02	13.60	12.26	1.37	70094.59
9	10.75	1.28	65.79	3.68	13.92	11.98	1.39	72436.08
10	10.24	7.61	47.78	4.65	12.55	12.87	1.40	66696.87
11	10.21	4.42	47.93	4.42	13.16	12.74	1.41	67942.31
12	8.71	4.08	63.90	4.76	12.23	13.07	1.41	65497.54
13	7.65	2.51	67.80	3.77	13.61	12.79	1.43	67564.49
14	6.95	3.41	56.98	4.14	13.19	12.94	1.44	65934.17
15	6.00	2.45	64.04	3.33	14.46	12.14	1.43	71088.70
16	8.10	7.01	48.76	4.96	11.87	12.90	1.40	66196.03
17	9.55	5.00	60.16	5.19	11.53	13.16	1.39	65818.08
18	9.90	1.63	72.63	4.96	11.89	13.10	1.39	66203.50
19	7.38	1.09	61.65	4.54	12.27	12.98	1.39	66564.70
20	3.16	2.34	63.83	4.83	11.88	13.46	1.39	63363.06
21	4.55	2.04	62.23	4.16	12.69	12.88	1.38	67018.21
22	5.62	2.45	61.95	4.65	11.80	13.06	1.38	66322.04
23	2.09	7.69	64.00	4.09	12.96	13.09	1.39	65541.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.76	4.31	59.26	3.96	13.30	12.62	1.40	67785.64
最大值	10.75	8.36	72.63	5.19	16.20	13.46	1.46	73041.92
發生時間	9	8	18	17	5	20		6
最小值	0.83	1.09	46.16	2.14	11.53	11.33	1.36	63363.06
發生時間	5	19	8	5	17	6		20
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	3.30 %	-0.25 %	-0.94 %	0.21 %		0.24	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.54	5.04	40.24	1.40	16.64	10.20	1.41	63017.15
1	4.13	1.31	66.99	1.47	16.99	11.55	1.42	57804.23
2	0.26	1.66	69.25	1.65	16.45	12.11	1.51	53777.16
3	2.36	2.31	58.80	1.16	17.69	10.56	1.43	64628.34
4	7.70	2.76	52.28	1.50	17.18	10.70	1.43	64555.49
5	7.15	1.57	63.69	1.43	17.26	10.70	1.43	63142.07
6	10.56	4.79	54.08	2.16	15.27	11.23	1.39	62812.18
7	10.71	2.36	61.34	1.78	16.57	10.98	1.36	63055.26
8	9.41	0.86	62.58	1.67	17.07	10.74	1.36	62011.00
9	7.48	1.97	53.81	1.30	18.12	10.12	1.37	63864.52
10	11.19	5.78	52.44	1.79	16.84	10.19	1.37	64264.03
11	8.23	7.53	47.24	1.52	17.57	9.94	1.35	61928.26
12	8.46	0.66	55.10	1.53	17.03	10.26	1.35	62691.55
13	7.22	3.29	57.55	1.52	16.83	10.52	1.35	61565.20
14	8.96	7.69	58.51	1.69	15.85	10.63	1.36	62945.34
15	10.12	3.89	62.01	1.92	16.13	10.59	1.37	62142.83
16	7.58	2.38	56.74	2.11	15.55	10.66	1.39	62808.15
17	3.96	0.60	65.13	1.38	17.00	10.66	1.41	63612.38
18	4.40	1.37	60.25	1.47	16.69	10.59	1.39	64965.33
19	5.90	1.44	66.87	1.66	16.57	10.98	1.38	62443.53
20	5.61	2.71	63.37	1.33	17.56	10.46	1.38	65436.42
21	6.51	2.46	61.51	1.56	16.88	10.26	1.38	65232.39
22	2.03	2.00	51.23	2.22	14.91	12.21	1.37	44174.47
23	0.79	4.05	53.56	1.30	17.10	10.53	1.38	59550.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.59	2.94	58.11	1.60	16.74	10.72	1.39	61767.84
最大值	11.19	7.69	69.25	2.22	18.12	12.21	1.61	65436.42
發生時間	10	14	2	22	9	22		20
最小值	0.26	0.60	40.24	1.16	14.91	9.94	1.34	44174.47
發生時間	2	17	0	3	22	11		22
零點偏移(率)	-0.01 %	-0.00 %	-0.02 %	0.00 %		-0.07	0.00	0.00 %
全幅偏移(率)	0.40 %	0.02 %	-0.54 %	0.28 %		0.09	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.88	6.42	54.66	1.01	15.38	11.19	1.85	83856.99
1	1.73	3.80	69.04	0.66	18.60	10.71	1.85	84635.46
2	3.08	5.75	47.91	0.63	17.40	10.54	1.85	85734.99
3	4.08	3.89	59.56	0.84	17.19	10.63	1.85	85793.22
4	9.98	5.00	54.37	1.14	16.78	10.79	1.85	86992.77
5	9.82	3.24	59.44	1.23	16.00	11.00	1.85	85039.68
6	9.36	5.56	58.61	1.34	15.76	11.10	1.85	85468.25
7	8.25	4.14	61.18	1.67	16.57	10.95	1.85	89043.98
8	6.56	17.12	64.34	3.15	17.84	10.23	1.83	83944.83
9	2.98	5.17	57.70	1.35	15.92	10.61	1.82	84604.25
10	3.33	4.26	57.52	1.71	14.89	11.24	1.82	83743.97
11	8.42	10.21	56.21	2.50	13.99	11.27	1.84	84043.84
12	8.48	2.17	71.88	2.05	15.19	11.76	1.84	81566.26
13	5.27	1.61	62.72	1.71	14.73	11.68	1.83	82117.55
14	6.21	1.51	64.12	1.77	15.00	11.41	1.85	82644.84
15	8.87	3.87	59.67	1.97	14.50	11.45	1.85	81307.95
16	1.58	9.25	69.02	2.78	12.72	12.11	1.85	77476.78
17	0.12	5.53	62.72	2.34	13.53	11.74	1.84	79873.11
18	0.15	4.77	71.60	2.03	14.33	12.02	1.85	78151.15
19	0.56	2.67	65.15	1.73	14.73	11.70	1.85	78070.06
20	0.59	3.98	65.48	1.76	14.90	11.88	1.85	79007.57
21	0.46	8.66	61.21	2.48	13.68	12.60	1.85	73858.07
22	2.18	7.00	54.89	2.11	14.52	11.96	1.85	77820.37
23	3.81	6.14	62.86	1.81	14.50	11.54	1.85	80176.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.70	5.49	61.33	1.74	15.36	11.34	1.84	82290.52
最大值	9.98	17.12	71.88	3.15	18.60	12.60	1.87	89043.98
發生時間	4	8	12	8	1	21		7
最小值	0.12	1.51	47.91	0.63	12.72	10.23	1.81	73858.07
發生時間	17	14	2	2	16	8		21
零點偏移(率)	-0.59 %	-0.00 %	-0.02 %	0.00 %		-0.26	0.00	0.00 %
全幅偏移(率)	3.02 %	0.15 %	-0.76 %	0.61 %		0.10	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								