

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.97	11.92	53.44	1.54	18.47	11.00	1.32	81512.64
1	9.21	12.71	59.99	1.48	19.85	11.73	1.29	74286.28
2	10.76	11.32	54.90	2.43	19.38	10.50	1.29	85324.75
3	12.72	11.93	55.84	3.86	15.46	11.66	1.33	80041.62
4	8.97	12.23	62.19	2.43	16.47	11.82	1.33	77746.66
5	11.61	12.52	49.20	1.61	15.64	12.08	1.30	78114.02
6	10.09	12.39	47.13	1.16	18.44	10.74	1.29	84110.67
7	8.82	11.68	46.48	1.57	15.69	11.47	1.30	80364.18
8	11.53	12.15	53.42	1.38	16.24	11.83	1.29	77419.82
9	9.30	11.74	45.01	1.00	17.56	11.14	1.30	81852.11
10	8.67	12.36	66.92	0.65	18.79	11.30	1.31	79102.12
11	10.63	11.18	61.12	1.32	17.83	10.71	1.29	83991.84
12	9.25	12.01	63.30	1.44	15.64	11.76	1.30	77572.85
13	11.52	11.87	64.33	1.36	16.30	11.60	1.29	77392.09
14	9.77	11.52	63.23	0.87	17.85	11.07	1.29	81554.81
15	9.45	11.64	55.76	1.01	16.92	11.34	1.29	80089.86
16	10.09	11.34	46.03	1.31	17.93	10.86	1.29	83038.12
17	12.82	12.09	48.40	1.78	17.22	11.20	1.29	81054.35
18	6.76	12.33	50.87	1.59	18.10	11.69	1.30	76089.75
19	9.45	11.98	43.16	1.36	18.00	11.14	1.30	80883.75
20	8.64	11.98	39.62	1.81	17.61	11.26	1.32	80679.89
21	9.97	12.13	47.47	1.97	17.49	11.67	1.32	77863.88
22	9.41	11.44	38.54	1.81	17.07	11.14	1.31	82529.52
23	9.07	12.95	59.72	1.43	17.66	12.26	1.32	72408.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.85	11.98	53.17	1.59	17.40	11.37	1.30	79792.68
最大值	12.82	12.95	66.92	3.86	19.85	12.26	1.34	85324.75
發生時間	17	23	10	3	1	23		2
最小值	6.76	11.18	38.54	0.65	15.46	10.50	1.28	72408.85
發生時間	18	11	22	10	3	2		23
零點偏移(率)	-0.09 %	-0.06 %	-0.19 %	0.00 %		-0.06	-0.01	0.30 %
全幅偏移(率)	-1.09 %	-0.89 %	-0.49 %	-1.54 %		-0.10	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.58	11.51	38.38	0.71	18.66	9.83	1.02	80230.36
1	8.59	11.94	51.43	0.90	19.78	10.22	1.02	80912.38
2	13.45	12.47	55.16	2.04	17.16	10.50	1.02	79831.93
3	9.15	12.71	49.98	1.69	17.36	10.48	1.02	79817.54
4	9.90	13.07	47.64	1.97	17.45	10.57	1.02	80208.35
5	9.79	12.10	48.18	1.52	17.41	10.71	1.02	79259.29
6	9.08	12.05	58.69	2.36	16.65	10.72	1.02	79658.61
7	9.55	11.86	56.85	1.66	17.07	10.53	1.02	79261.84
8	10.44	11.58	50.62	1.65	17.19	10.20	1.02	79183.95
9	9.35	11.54	59.38	1.02	18.57	9.96	1.04	80535.10
10	10.00	12.18	62.91	1.17	19.06	10.05	1.02	79344.90
11	9.00	12.00	53.83	1.05	19.86	9.61	1.04	81866.59
12	11.82	11.94	57.14	1.16	19.17	10.21	1.04	82304.49
13	7.92	12.22	42.56	1.30	18.88	10.23	1.05	80921.30
14	11.56	11.70	55.40	0.99	19.14	10.10	1.03	81133.93
15	7.90	12.04	66.44	1.24	18.51	10.57	1.02	81534.49
16	11.75	11.67	55.01	0.86	19.35	10.15	1.02	84335.90
17	8.84	11.62	36.54	0.53	19.80	9.81	1.03	81530.84
18	10.07	12.48	46.49	1.02	18.71	10.42	1.02	74783.19
19	8.21	13.67	46.81	1.31	19.44	9.94	1.01	79787.33
20	11.18	12.36	42.44	0.41	20.30	9.49	1.02	84982.66
21	8.34	12.27	48.72	0.93	18.86	9.83	1.03	82020.85
22	10.62	12.25	47.86	1.90	17.46	10.46	1.03	77184.25
23	8.97	11.88	41.14	1.20	18.85	10.04	1.03	77350.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.79	12.13	50.82	1.27	18.53	10.19	1.03	80332.54
最大值	13.45	13.67	66.44	2.36	20.30	10.72	1.06	84982.66
發生時間	2	19	15	6	20	6		20
最小值	7.90	11.51	36.54	0.41	16.65	9.49	0.99	74783.19
發生時間	15	0	17	20	6	20		18
零點偏移(率)	-0.14 %	0.01 %	-0.05 %	-0.02 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-1.44 %	-0.18 %	-0.07 %	-0.39 %		-0.15	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.96	11.72	41.74	0.69	19.80	9.74	1.43	72418.87
1	10.52	11.31	43.76	0.65	21.20	9.40	1.44	80648.64
2	9.40	11.58	49.10	0.81	20.08	9.61	1.44	75343.89
3	9.58	12.22	49.47	0.75	17.58	9.85	1.43	73589.94
4	10.61	11.66	49.43	0.81	17.79	9.75	1.43	72978.79
5	9.93	11.70	47.96	0.76	17.29	9.90	1.43	73273.03
6	9.19	13.04	52.04	0.83	17.86	9.70	1.43	76912.26
7	3.47	11.68	55.08	1.89	17.02	10.24	1.42	75996.45
8	10.37	11.46	51.70	2.00	20.06	9.33	1.43	77005.74
9	9.37	11.38	65.81	2.10	19.81	9.39	1.43	80305.92
10	9.35	11.98	60.97	1.85	17.86	10.35	1.42	73811.18
11	7.72	12.02	65.97	1.74	17.61	10.61	1.42	73152.06
12	9.58	11.83	64.48	1.97	18.05	10.40	1.39	72799.72
13	8.38	12.27	70.77	1.92	18.24	10.74	1.42	71652.61
14	8.02	12.08	52.44	1.71	19.46	9.49	1.42	75254.81
15	7.82	11.75	55.41	1.72	18.75	9.96	1.36	71562.19
16	7.96	11.74	45.87	1.71	19.77	9.42	1.38	75148.84
17	10.47	11.52	55.23	2.11	19.74	9.62	1.39	73531.35
18	8.16	14.44	47.23	1.86	21.29	9.10	1.38	73480.84
19	8.28	10.35	35.43	3.24	20.55	8.54	1.38	74601.76
20	5.13	8.24	60.57	0.37	17.38	10.27	1.41	66780.79
21	7.63	11.53	61.40	0.38	18.21	10.06	1.39	69634.80
22	7.49	11.70	50.32	0.38	19.32	9.75	1.39	73662.29
23	9.05	11.69	38.32	0.83	18.31	9.93	1.40	72761.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.52	11.70	52.94	1.38	18.88	9.80	1.41	74012.85
最大值	10.61	14.44	70.77	3.24	21.29	10.74	1.46	80648.64
發生時間	4	18	13	19	18	13		1
最小值	3.47	8.24	35.43	0.37	17.02	8.54	1.36	66780.79
發生時間	7	20	19	20	7	19		20
零點偏移(率)	-0.09 %	-0.11 %	-0.09 %	-0.01 %		-0.18	-0.01	0.00 %
全幅偏移(率)	-1.50 %	-0.60 %	1.11 %	0.49 %		0.08	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								