

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.22	5.89	54.69	1.03	19.11	11.19	1.03	74494.74
1	7.46	5.87	57.08	0.74	20.02	11.56	1.04	71790.12
2	4.81	7.02	59.19	0.97	19.10	11.91	1.06	70151.47
3	7.56	5.68	54.29	0.87	19.16	11.16	1.05	75455.37
4	6.70	5.63	54.43	0.69	20.39	10.53	1.04	78877.34
5	9.99	6.88	55.45	1.92	18.33	11.27	1.05	86327.97
6	8.08	5.60	60.85	1.29	18.16	11.58	1.05	72224.15
7	8.38	5.77	58.87	1.64	17.00	11.87	1.05	71199.63
8	7.56	5.41	56.28	1.53	17.59	11.67	1.06	72688.43
9	7.38	5.59	66.10	0.96	18.76	11.71	1.06	71732.31
10	3.44	5.46	60.49	0.82	18.98	11.57	1.06	72511.13
11	4.89	5.31	63.33	0.75	19.55	11.28	1.07	73766.79
12	5.11	8.00	55.03	1.59	17.50	11.97	1.06	70183.21
13	9.01	7.07	61.56	1.76	17.71	11.81	1.03	71414.77
14	7.74	5.43	53.98	1.92	17.08	11.72	1.04	72672.27
15	3.50	5.87	68.10	1.09	18.53	11.70	1.03	71838.13
16	8.07	5.51	45.43	1.66	17.43	11.31	1.02	75351.45
17	7.54	6.51	49.78	1.20	18.82	11.38	1.03	73895.66
18	5.66	5.50	44.00	1.54	17.34	11.57	1.06	73048.83
19	5.82	4.99	50.85	1.26	18.41	11.43	1.04	73706.22
20	9.78	2.62	42.99	2.51	15.57	11.88	1.02	71151.54
21	10.03	2.99	47.42	1.67	17.17	11.78	1.02	70929.99
22	8.74	6.49	49.41	1.28	17.43	11.65	1.02	71911.66
23	8.89	7.65	61.39	0.82	18.58	11.38	1.03	73627.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.27	5.78	55.46	1.31	18.24	11.54	1.04	73372.96
最大值	10.03	8.00	68.10	2.51	20.39	11.97	1.11	86327.97
發生時間	21	12	15	20	4	12		5
最小值	3.44	2.62	42.99	0.69	15.57	10.53	1.01	70151.47
發生時間	10	20	20	4	20	4		2
零點偏移(率)	-0.12 %	-0.05 %	-0.06 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	-0.74 %	0.73 %	-0.03 %	-0.01 %		0.12		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.18	5.54	42.40	1.57	18.45	10.61	1.03	81547.77
1	0.51	4.30	32.94	2.02	20.34	9.66	1.03	87318.42
2	1.26	3.81	39.29	1.83	20.69	9.82	1.03	85246.68
3	4.00	6.18	49.59	1.45	20.36	9.61	1.02	87903.80
4	6.35	18.48	42.12	1.48	21.20	9.00	1.02	91154.58
5	6.48	4.42	54.83	2.50	18.10	10.42	1.03	83597.68
6	1.50	4.47	53.81	2.30	17.31	10.30	1.03	89614.39
7	2.41	3.75	57.99	2.60	17.01	10.49	1.02	83653.36
8	6.24	5.56	58.52	2.28	17.66	10.38	1.03	84486.73
9	9.18	8.52	65.17	2.25	16.53	11.34	1.04	79625.56
10	7.90	9.11	51.62	2.57	15.89	10.98	1.02	85344.26
11	9.54	14.48	51.87	2.70	16.01	10.99	1.00	84869.75
12	7.20	8.06	60.99	2.35	16.41	11.39	1.02	81012.98
13	3.15	6.23	53.45	1.89	16.24	11.29	1.01	82234.85
14	2.63	9.58	59.32	2.66	14.57	11.34	0.99	83669.40
15	4.54	7.66	55.80	2.68	15.06	11.31	0.99	83544.61
16	7.68	3.19	57.14	2.42	15.18	11.38	1.00	83320.32
17	3.47	3.93	53.69	1.76	15.84	11.49	1.02	81647.70
18	0.19	3.37	53.84	1.64	17.17	10.71	1.00	85954.54
19	0.52	3.55	59.60	1.90	17.21	10.17	1.02	87717.17
20	8.67	11.16	59.44	3.24	16.49	10.23	1.01	85409.16
21	9.11	2.40	53.12	2.97	16.77	10.09	1.02	86967.38
22	9.04	7.64	58.85	1.82	17.35	10.18	1.03	86011.36
23	8.79	8.84	61.56	1.46	17.57	10.58	1.02	83027.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.02	6.84	53.62	2.18	17.31	10.57	1.02	84786.67
最大值	9.54	18.48	65.17	3.24	21.20	11.49	1.05	91154.58
發生時間	11	4	9	20	4	17		4
最小值	0.18	2.40	32.94	1.45	14.57	9.00	0.99	79625.56
發生時間	0	21	1	3	14	4		9
零點偏移(率)	-0.04 %	-0.08 %	-0.03 %	-0.00 %		0.02		-0.20 %
全幅偏移(率)	-0.72 %	-0.23 %	0.07 %	0.20 %		-0.17		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.61	5.61	51.58	1.18	16.04	11.14	1.01	77400.18
1	2.61	3.50	60.50	1.05	16.62	11.23	1.02	76649.14
2	3.66	5.99	54.42	1.06	19.01	10.57	1.02	80628.88
3	6.15	3.41	46.98	1.11	16.86	10.80	1.01	81190.28
4	7.66	3.23	29.55	1.36	18.23	10.14	1.01	83621.74
5	8.73	5.42	46.95	1.32	17.47	10.32	1.02	80783.98
6	6.97	10.79	48.47	1.39	16.24	10.72	1.02	78583.89
7	10.69	8.65	44.16	2.40	15.13	10.29	1.00	81338.54
8	6.84	2.15	50.25	1.47	16.94	10.44	0.99	75240.33
9	校正	校正	校正	校正	替代	校正	0.99	86648.53
10	7.27	6.96	46.50	1.43	17.73	10.16	0.99	80457.51
11	9.53	9.70	44.86	2.26	15.68	10.28	0.99	75153.98
12	9.07	4.83	45.65	1.88	16.90	10.05	1.03	74394.63
13	9.87	8.09	45.50	2.53	15.18	10.17	0.99	73635.48
14	8.47	8.31	44.54	2.93	14.69	10.27	0.98	72540.01
15	7.95	6.07	46.78	2.61	14.42	10.62	0.97	73362.48
16	9.97	7.46	51.15	3.08	13.54	10.71	0.98	74588.34
17	6.83	11.89	49.31	2.97	13.89	10.55	0.98	75414.55
18	3.35	6.06	44.95	1.74	15.82	10.11	0.99	77807.51
19	5.53	4.16	53.62	1.57	16.51	10.36	1.01	83176.04
20	8.88	4.06	50.06	2.16	15.63	10.59	0.99	78410.80
21	9.45	5.50	36.09	1.92	17.87	9.53	0.98	81829.52
22	9.08	2.57	45.93	1.88	15.97	10.21	0.98	76677.08
23	9.24	11.38	49.24	1.65	17.39	10.10	0.99	80846.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	24
平均值	7.41	6.34	47.26	1.87	16.25	10.41	1.00	78349.15
最大值	10.69	11.89	60.50	3.08	19.01	11.23	1.10	86648.53
發生時間	7	17	1	16	2	1		9
最小值	2.61	2.15	29.55	1.05	13.54	9.53	0.97	72540.01
發生時間	0	8	4	1	16	21		14
零點偏移(率)	-0.01 %	-0.05 %	-0.03 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	-0.02 %	-0.77 %	-0.70 %	0.22 %		0.17		0.00 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %
備註								