

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月24日

| 項目      | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 7.59     | 12.63    | 50.13    | 1.97     | 18.35    | 11.60    | 1.29     | 77298.04  |
| 1       | 6.86     | 12.08    | 55.20    | 2.12     | 20.11    | 10.63    | 1.29     | 83891.59  |
| 2       | 6.38     | 11.93    | 45.02    | 2.92     | 17.50    | 10.91    | 1.29     | 84262.62  |
| 3       | 9.63     | 11.50    | 60.56    | 2.89     | 17.68    | 11.10    | 1.29     | 82894.12  |
| 4       | 9.01     | 11.66    | 57.83    | 2.87     | 17.88    | 11.19    | 1.29     | 81889.17  |
| 5       | 7.66     | 11.46    | 46.05    | 2.84     | 17.17    | 11.17    | 1.29     | 84400.14  |
| 6       | 5.34     | 11.55    | 47.51    | 2.15     | 18.06    | 11.10    | 1.29     | 82373.52  |
| 7       | 8.28     | 11.63    | 40.20    | 3.29     | 18.37    | 10.91    | 1.29     | 83594.61  |
| 8       | 11.89    | 11.36    | 48.96    | 3.40     | 18.20    | 10.85    | 1.29     | 84168.62  |
| 9       | 6.50     | 11.51    | 50.76    | 3.65     | 15.88    | 11.34    | 1.30     | 82080.43  |
| 10      | 12.58    | 11.47    | 53.19    | 2.65     | 17.03    | 11.22    | 1.32     | 82588.62  |
| 11      | 8.08     | 11.64    | 51.12    | 3.26     | 17.03    | 11.32    | 1.30     | 81153.31  |
| 12      | 8.21     | 12.22    | 57.48    | 3.00     | 16.44    | 11.65    | 1.29     | 78780.80  |
| 13      | 8.57     | 12.56    | 48.91    | 2.78     | 16.10    | 12.12    | 1.29     | 72942.31  |
| 14      | 9.62     | 12.06    | 54.13    | 1.81     | 17.58    | 11.36    | 1.29     | 80352.92  |
| 15      | 10.33    | 11.99    | 50.13    | 2.44     | 16.66    | 11.66    | 1.30     | 78642.69  |
| 16      | 8.68     | 11.68    | 44.47    | 2.18     | 18.14    | 11.14    | 1.29     | 80409.62  |
| 17      | 10.35    | 10.90    | 45.48    | 3.65     | 18.25    | 10.57    | 1.30     | 85820.53  |
| 18      | 11.33    | 11.48    | 45.93    | 1.97     | 16.34    | 11.16    | 1.31     | 82920.77  |
| 19      | 7.70     | 11.67    | 48.80    | 1.42     | 15.44    | 11.61    | 1.31     | 78995.66  |
| 20      | 9.52     | 11.50    | 48.47    | 1.71     | 15.79    | 11.25    | 1.29     | 81369.93  |
| 21      | 11.45    | 11.77    | 43.44    | 1.96     | 17.04    | 10.97    | 1.29     | 83600.53  |
| 22      | 7.71     | 12.16    | 47.28    | 1.18     | 17.97    | 11.30    | 1.30     | 79873.44  |
| 23      | 9.50     | 11.59    | 41.21    | 1.99     | 17.85    | 11.04    | 1.31     | 82689.86  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 8.87     | 11.75    | 49.26    | 2.50     | 17.37    | 11.22    | 1.30     | 81541.41  |
| 最大值     | 12.58    | 12.63    | 60.56    | 3.65     | 20.11    | 12.12    | 1.33     | 85820.53  |
| 發生時間    | 10       | 0        | 3        | 9        | 1        | 13       |          | 17        |
| 最小值     | 5.34     | 10.90    | 40.20    | 1.18     | 15.44    | 10.57    | 1.28     | 72942.31  |
| 發生時間    | 6        | 17       | 7        | 22       | 19       | 17       |          | 13        |
| 零點偏移(率) | -0.09 %  | 0.00 %   | -0.06 %  | -0.01 %  |          | -0.18    | -0.01    | 0.20 %    |
| 全幅偏移(率) | -0.63 %  | 1.35 %   | 0.11 %   | 1.51 %   |          | -0.02    | 0.04     | 0.20 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月24日

| 項目      | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 8.84     | 7.71     | 52.52    | 0.81     | 17.03    | 11.79    | 0.81     | 78535.00  |
| 1       | 10.05    | 9.21     | 54.14    | 1.78     | 16.98    | 11.79    | 0.81     | 78660.38  |
| 2       | 8.97     | 7.91     | 54.91    | 1.22     | 16.47    | 11.84    | 0.81     | 78687.28  |
| 3       | 7.87     | 8.05     | 57.55    | 0.68     | 17.84    | 11.54    | 0.83     | 77378.87  |
| 4       | 10.58    | 8.14     | 61.84    | 1.06     | 18.43    | 11.15    | 0.83     | 79210.57  |
| 5       | 8.90     | 9.47     | 47.19    | 1.22     | 17.74    | 11.56    | 0.81     | 76124.96  |
| 6       | 10.46    | 12.33    | 64.37    | 1.35     | 17.24    | 12.64    | 0.80     | 70661.86  |
| 7       | 11.14    | 12.47    | 64.24    | 0.79     | 18.88    | 11.70    | 0.80     | 71658.96  |
| 8       | 8.04     | 12.51    | 61.06    | 1.35     | 17.08    | 12.31    | 0.82     | 71207.72  |
| 9       | 11.48    | 10.72    | 53.83    | 0.66     | 18.75    | 11.24    | 0.82     | 77572.13  |
| 10      | 10.16    | 8.74     | 48.36    | 1.66     | 17.41    | 11.27    | 0.83     | 79586.80  |
| 11      | 12.17    | 9.03     | 49.78    | 1.92     | 17.41    | 11.31    | 0.83     | 79409.27  |
| 12      | 8.29     | 7.97     | 48.38    | 2.03     | 17.17    | 11.18    | 0.83     | 80098.54  |
| 13      | 7.74     | 7.44     | 51.04    | 1.95     | 17.17    | 11.42    | 0.83     | 77504.23  |
| 14      | 11.06    | 8.70     | 50.64    | 1.72     | 17.43    | 11.42    | 0.83     | 78071.59  |
| 15      | 9.68     | 8.56     | 56.27    | 1.83     | 17.47    | 11.39    | 0.82     | 77921.12  |
| 16      | 8.27     | 26.69    | 57.29    | 2.37     | 15.75    | 11.79    | 0.81     | 77607.27  |
| 17      | 9.01     | 8.09     | 58.93    | 3.00     | 14.37    | 12.18    | 0.79     | 76845.51  |
| 18      | 12.08    | 7.28     | 54.30    | 2.25     | 15.38    | 12.28    | 0.80     | 76342.43  |
| 19      | 8.04     | 8.76     | 44.61    | 1.99     | 15.64    | 12.27    | 0.80     | 76023.22  |
| 20      | 11.12    | 8.88     | 45.96    | 1.96     | 16.00    | 12.14    | 0.81     | 77086.82  |
| 21      | 9.63     | 8.30     | 49.98    | 2.28     | 15.03    | 12.32    | 0.81     | 75868.68  |
| 22      | 9.06     | 7.77     | 51.62    | 2.07     | 14.88    | 12.38    | 0.81     | 75721.64  |
| 23      | 8.62     | 8.34     | 52.02    | 1.42     | 16.17    | 12.24    | 0.82     | 75055.35  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 9.64     | 9.71     | 53.78    | 1.64     | 16.82    | 11.80    | 0.82     | 76785.01  |
| 最大值     | 12.17    | 26.69    | 64.37    | 3.00     | 18.88    | 12.64    | 0.87     | 80098.54  |
| 發生時間    | 11       | 16       | 6        | 17       | 7        | 6        |          | 12        |
| 最小值     | 7.74     | 7.28     | 44.61    | 0.66     | 14.37    | 11.15    | 0.79     | 70661.86  |
| 發生時間    | 13       | 18       | 19       | 9        | 17       | 4        |          | 6         |
| 零點偏移(率) | -0.14 %  | -0.00 %  | -0.08 %  | -0.00 %  |          | -0.09    | -0.06    | -0.10 %   |
| 全幅偏移(率) | 0.33 %   | 1.34 %   | -0.01 %  | 0.73 %   |          | -0.17    | 0.31     | -0.20 %   |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月24日

| 項目      | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 8.22     | 11.70    | 57.24    | 3.35     | 19.20    | 9.98     | 1.32     | 80559.01  |
| 1       | 8.67     | 12.34    | 57.20    | 3.59     | 19.82    | 10.42    | 1.31     | 78686.57  |
| 2       | 11.26    | 11.93    | 55.69    | 3.44     | 17.62    | 10.54    | 1.31     | 77175.71  |
| 3       | 9.71     | 11.91    | 52.76    | 3.36     | 17.36    | 10.55    | 1.31     | 74775.08  |
| 4       | 9.69     | 12.14    | 52.75    | 3.33     | 17.33    | 10.49    | 1.31     | 76375.87  |
| 5       | 9.65     | 11.83    | 48.58    | 3.38     | 18.04    | 10.09    | 1.31     | 75914.73  |
| 6       | 7.94     | 11.96    | 42.27    | 3.33     | 19.13    | 9.67     | 1.31     | 75828.10  |
| 7       | 6.40     | 11.39    | 41.01    | 2.99     | 19.25    | 9.96     | 1.31     | 74744.73  |
| 8       | 10.62    | 11.44    | 45.77    | 2.98     | 18.05    | 9.95     | 1.32     | 77103.85  |
| 9       | 9.88     | 11.09    | 47.05    | 3.08     | 17.90    | 9.52     | 1.33     | 77063.63  |
| 10      | 9.15     | 11.07    | 47.41    | 2.98     | 18.22    | 9.54     | 1.31     | 75767.77  |
| 11      | 10.75    | 11.36    | 49.30    | 3.23     | 16.82    | 9.73     | 1.31     | 74569.22  |
| 12      | 10.91    | 11.31    | 49.31    | 3.26     | 18.36    | 9.32     | 1.32     | 76481.19  |
| 13      | 6.04     | 11.14    | 38.81    | 2.58     | 17.46    | 8.89     | 1.33     | 71611.15  |
| 14      | 7.70     | 8.51     | 35.63    | 3.05     | 19.51    | 7.45     | 1.29     | 74913.04  |
| 15      | 9.81     | 7.57     | 47.06    | 0.79     | 17.36    | 8.77     | 1.31     | 72717.83  |
| 16      | 14.93    | 11.16    | 47.02    | 2.32     | 17.16    | 9.48     | 1.31     | 76733.18  |
| 17      | 5.91     | 12.81    | 46.10    | 2.16     | 15.34    | 10.48    | 1.31     | 72143.62  |
| 18      | 10.66    | 11.30    | 38.07    | 1.49     | 18.14    | 9.30     | 1.31     | 76072.72  |
| 19      | 7.47     | 12.24    | 47.28    | 1.43     | 16.60    | 10.44    | 1.31     | 77399.60  |
| 20      | 10.32    | 11.41    | 37.20    | 1.45     | 17.70    | 9.59     | 1.31     | 75991.17  |
| 21      | 11.03    | 11.73    | 45.65    | 1.75     | 17.97    | 10.16    | 1.31     | 74901.43  |
| 22      | 8.00     | 11.67    | 49.68    | 1.46     | 18.37    | 10.29    | 1.32     | 75184.81  |
| 23      | 8.79     | 11.23    | 43.64    | 2.14     | 19.29    | 9.64     | 1.34     | 77551.47  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 9.31     | 11.34    | 46.77    | 2.62     | 18.00    | 9.76     | 1.31     | 75844.39  |
| 最大值     | 14.93    | 12.81    | 57.24    | 3.59     | 19.82    | 10.55    | 1.35     | 80559.01  |
| 發生時間    | 16       | 17       | 0        | 1        | 1        | 3        |          | 0         |
| 最小值     | 5.91     | 7.57     | 35.63    | 0.79     | 15.34    | 7.45     | 1.27     | 71611.15  |
| 發生時間    | 17       | 15       | 14       | 15       | 17       | 14       |          | 13        |
| 零點偏移(率) | -0.02 %  | 0.00 %   | -0.29 %  | -0.01 %  |          | -0.07    | -0.01    | 0.10 %    |
| 全幅偏移(率) | 0.15 %   | -0.09 %  | -0.03 %  | -0.01 %  |          | -0.03    | 0.00     | 0.10 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |