

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.88	3.08	39.20	1.19	16.25	11.29	1.26	85041.58
1	10.65	3.00	37.86	1.48	15.80	11.48	1.26	83136.75
2	7.49	3.57	62.83	2.29	13.88	12.45	1.26	73477.89
3	4.47	5.46	58.56	1.79	14.79	12.13	1.28	79712.18
4	7.93	7.55	56.00	3.01	12.93	12.16	1.25	80351.90
5	10.30	4.89	57.49	2.89	13.80	12.12	1.25	79795.62
6	9.78	3.69	53.66	2.51	14.34	12.11	1.25	80352.52
7	10.20	6.72	64.58	2.11	14.56	12.12	1.25	79928.81
8	8.97	2.75	56.46	2.23	13.84	12.38	1.27	78711.91
9	11.77	2.31	47.41	2.07	14.58	11.92	1.29	81617.32
10	8.13	3.23	43.29	2.76	13.99	12.14	1.28	80205.20
11	10.32	2.43	40.84	3.23	13.65	12.29	1.27	79135.67
12	7.20	4.60	58.54	2.38	14.56	12.61	1.29	75118.24
13	10.47	2.13	48.18	2.14	15.33	11.75	1.29	80663.36
14	12.61	3.09	43.48	1.75	15.49	11.54	1.29	82589.43
15	6.71	3.30	55.55	1.86	15.59	11.82	1.30	80164.98
16	9.07	3.09	63.18	2.03	15.90	11.54	1.32	83252.85
17	6.25	5.55	50.53	2.58	14.59	11.98	1.31	79584.61
18	3.72	3.33	56.06	2.27	14.91	12.25	1.30	76085.29
19	4.89	4.46	50.58	1.25	14.89	12.22	1.29	77918.55
20	10.59	2.99	53.95	1.40	15.70	11.46	1.29	83707.45
21	8.78	3.29	52.44	1.90	15.06	11.64	1.29	81483.82
22	12.76	2.93	48.16	2.61	14.98	11.68	1.29	81123.18
23	8.98	4.52	56.15	1.46	15.48	11.65	1.30	80278.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.87	3.83	52.29	2.13	14.79	11.95	1.28	80143.23
最大值	12.76	7.55	64.58	3.23	16.25	12.61	1.34	85041.58
發生時間	22	4	7	11	0	12		0
最小值	3.72	2.13	37.86	1.19	12.93	11.29	1.25	73477.89
發生時間	18	13	1	0	4	0		2
零點偏移(率)	0.00 %	-0.00 %	-0.01 %	-0.01 %		-0.05		0.30 %
全幅偏移(率)	0.00 %	0.53 %	0.24 %	0.16 %		0.00		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.16	2.46	39.64	2.25	15.25	10.14	1.09	79984.99
1	7.29	1.19	44.29	2.35	16.12	10.27	1.10	78759.56
2	5.97	1.30	63.80	3.10	14.46	10.56	1.09	76681.13
3	6.51	2.02	59.89	2.49	14.52	10.57	1.07	74802.88
4	7.29	5.55	57.02	3.20	13.55	10.57	1.06	76309.30
5	6.65	1.30	60.86	2.92	12.72	11.13	1.07	79320.33
6	2.65	1.36	61.85	1.73	13.73	11.20	1.09	80659.34
7	8.51	1.39	59.93	2.49	13.69	11.17	1.09	80495.57
8	8.61	1.25	65.35	2.46	13.04	11.43	1.10	78421.84
9	10.55	4.25	64.93	2.58	12.84	11.46	1.12	78607.89
10	9.55	4.35	66.70	2.46	13.16	11.43	1.11	77204.63
11	9.12	7.57	54.83	2.20	14.24	11.14	1.07	75599.76
12	6.84	3.19	53.06	2.15	14.44	10.68	1.09	78114.21
13	7.66	2.67	59.62	2.50	13.53	11.19	1.10	77984.96
14	7.18	3.27	54.28	2.26	13.37	11.22	1.10	76114.75
15	7.06	2.02	45.30	2.51	13.87	10.94	1.10	76204.78
16	8.32	3.10	57.21	2.40	14.30	11.00	1.10	74724.83
17	7.17	2.29	64.81	1.99	14.41	11.51	1.10	70760.95
18	6.48	2.25	57.44	2.04	14.04	10.83	1.10	74345.23
19	8.33	2.77	49.05	2.41	13.92	10.99	1.10	77406.42
20	7.68	2.14	49.16	2.08	14.27	11.05	1.10	76100.06
21	8.06	2.38	51.30	2.35	13.36	11.16	1.10	74792.98
22	8.02	3.47	44.94	2.20	15.03	10.95	1.10	73638.87
23	8.07	6.30	44.53	1.95	15.68	10.40	1.10	75756.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.49	2.91	55.41	2.38	14.06	10.96	1.09	76782.98
最大值	10.55	7.57	66.70	3.20	16.12	11.51	1.13	80659.34
發生時間	9	11	10	4	1	17		6
最小值	2.65	1.19	39.64	1.73	12.72	10.14	1.06	70760.95
發生時間	6	1	0	6	5	0		17
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	0.78 %	0.29 %	0.32 %	0.17 %		0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.01	2.15	45.84	2.09	14.97	9.82	1.52	76215.81
1	13.11	2.31	46.03	3.96	15.91	9.77	1.52	76385.88
2	7.82	2.93	46.91	3.50	14.08	10.04	1.50	73952.38
3	7.46	3.33	42.89	3.35	13.93	10.04	1.48	74143.63
4	9.69	3.20	46.74	2.49	16.17	9.74	1.49	76664.03
5	10.45	6.02	47.27	3.07	14.26	9.92	1.50	75813.30
6	7.63	6.00	53.06	1.71	13.35	10.08	1.50	73680.41
7	10.56	13.05	49.07	4.00	12.89	10.08	1.50	68388.53
8	10.87	4.71	48.21	4.35	13.29	10.31	1.51	71502.59
9	7.20	4.12	51.32	2.67	12.80	10.42	1.51	70939.80
10	10.61	1.52	52.95	2.37	13.67	10.16	1.50	72130.94
11	7.84	5.27	52.39	2.00	15.52	9.83	1.51	75568.48
12	7.22	4.42	48.60	2.68	15.65	9.73	1.51	75964.19
13	9.49	4.49	44.70	2.21	14.45	9.87	1.50	75863.60
14	8.71	2.90	42.91	2.03	14.60	10.00	1.50	74374.54
15	7.99	4.33	42.35	2.02	14.32	10.01	1.50	72967.93
16	7.84	4.78	39.03	1.56	16.19	9.83	1.51	73187.92
17	8.19	4.49	50.75	1.92	15.82	9.55	1.52	75529.93
18	7.69	4.22	52.15	1.86	14.70	10.01	1.52	74280.11
19	11.14	2.45	53.10	2.75	15.02	10.16	1.52	75731.28
20	8.10	7.23	48.89	1.87	14.68	9.98	1.51	73166.91
21	8.91	3.07	49.38	1.16	15.81	9.67	1.51	75601.57
22	7.87	2.42	48.66	1.34	14.75	9.80	1.52	74614.27
23	8.87	2.37	45.59	1.71	14.68	9.90	1.52	73772.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.84	4.24	47.87	2.44	14.65	9.95	1.51	74185.01
最大值	13.11	13.05	53.10	4.35	16.19	10.42	1.52	76664.03
發生時間	1	7	19	8	16	9		4
最小值	7.01	1.52	39.03	1.16	12.80	9.55	1.48	68388.53
發生時間	0	10	16	21	9	17		7
零點偏移(率)	-0.06 %	-0.05 %	-0.11 %	-0.08 %		0.00		0.10 %
全幅偏移(率)	0.02 %	0.20 %	-0.02 %	0.11 %		0.20		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								