

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.95	3.57	63.84	2.46	18.45	11.32	1.36	74928.67
1	6.67	3.73	57.30	2.72	18.72	11.80	1.37	71197.58
2	2.56	3.29	71.56	2.58	18.24	11.92	1.36	70821.90
3	4.49	3.57	50.69	3.77	15.86	12.99	1.34	68324.50
4	1.70	4.31	68.93	3.04	16.72	12.76	1.33	66825.17
5	4.60	4.36	43.72	2.67	17.98	11.59	1.33	65046.32
6	8.01	3.64	58.63	2.94	17.62	11.76	1.30	72268.64
7	10.52	3.75	47.96	3.06	17.51	11.74	1.30	72158.71
8	9.58	3.63	51.83	3.41	16.13	12.08	1.32	70347.46
9	5.81	4.07	65.01	2.76	17.94	12.04	1.34	69671.60
10	5.15	3.93	52.87	2.64	18.05	11.71	1.33	71721.85
11	9.38	4.20	50.89	3.19	17.08	11.88	1.35	71094.11
12	9.44	3.39	58.97	3.03	17.23	11.80	1.37	71889.20
13	9.13	3.55	47.11	3.20	16.87	12.13	1.37	70747.62
14	12.51	3.89	43.20	4.22	15.52	12.70	1.35	71283.97
15	14.09	10.63	51.07	4.63	15.44	12.36	1.33	71358.28
16	8.22	4.93	52.69	4.29	15.82	12.36	1.33	71301.11
17	9.25	4.38	42.94	3.82	15.61	12.25	1.33	71739.98
18	12.41	3.42	57.64	3.29	16.76	11.92	1.33	72765.78
19	10.78	4.30	55.87	2.93	17.54	11.60	1.33	75065.85
20	3.39	3.84	51.60	2.60	18.17	11.48	1.33	74367.17
21	4.31	3.47	58.44	2.47	18.72	11.40	1.33	74918.33
22	6.18	3.91	42.97	3.22	16.24	12.07	1.33	72440.85
23	9.29	4.69	54.05	3.23	17.07	11.97	1.30	72722.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.64	4.19	54.16	3.17	17.14	11.98	1.34	71458.61
最大值	14.09	10.63	71.56	4.63	18.72	12.99	1.49	75065.85
發生時間	15	15	2	15	1	3		19
最小值	1.70	3.29	42.94	2.46	15.44	11.32	1.29	65046.32
發生時間	4	2	17	0	15	0		5
零點偏移(率)	-0.13 %	-0.00 %	-0.03 %	-0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	-3.76 %	-0.59 %	-0.27 %	-0.03 %		-0.10	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.59	4.87	55.70	1.36	19.24	11.02	1.37	74851.47
1	1.94	6.98	33.04	1.05	20.75	9.91	1.38	82630.38
2	5.49	5.01	22.56	1.91	20.65	9.58	1.38	84970.61
3	7.13	4.85	30.49	1.81	20.34	9.98	1.39	85127.93
4	8.70	4.74	32.12	2.41	20.96	9.31	1.41	87043.24
5	9.76	4.45	37.77	2.62	19.97	9.45	1.41	84874.66
6	9.87	12.33	39.41	3.29	17.47	10.20	1.39	79543.37
7	7.51	3.97	59.36	2.57	18.64	10.82	1.39	75797.05
8	6.07	4.07	59.58	1.85	19.52	10.86	1.41	78281.04
9	9.15	6.90	39.80	2.16	20.26	10.19	1.41	83510.27
10	10.20	5.15	39.28	2.65	18.91	10.11	1.40	85072.93
11	9.49	4.90	48.43	2.70	16.92	10.42	1.39	81005.13
12	8.71	3.92	54.92	2.54	17.23	10.63	1.37	81213.21
13	10.86	6.09	50.02	3.10	15.86	10.55	1.36	79149.39
14	11.27	6.92	49.44	3.11	16.45	10.57	1.37	79309.70
15	17.37	6.60	55.47	4.63	16.15	10.97	1.40	80083.10
16	8.62	6.85	55.02	9.96	16.17	11.17	1.42	80023.28
17	15.42	5.65	55.43	7.32	17.02	10.98	1.40	80524.22
18	8.25	4.01	49.90	1.60	19.83	10.35	1.39	85220.62
19	9.88	6.05	42.84	2.04	19.37	10.08	1.41	88034.62
20	9.39	8.23	55.19	2.38	18.04	10.56	1.41	83801.40
21	10.34	4.70	49.91	2.70	18.26	9.99	1.40	82485.84
22	10.12	5.62	45.45	2.63	18.53	10.02	1.39	81942.39
23	9.31	4.82	45.81	2.49	17.94	10.05	1.38	80553.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.98	5.74	46.12	2.95	18.52	10.32	1.39	81877.07
最大值	17.37	12.33	59.58	9.96	20.96	11.17	1.43	88034.62
發生時間	15	6	8	16	4	16		19
最小值	0.59	3.92	22.56	1.05	15.86	9.31	1.36	74851.47
發生時間	0	12	2	1	13	4		0
零點偏移(率)	0.00 %	-0.01 %	-0.10 %	-0.00 %		-0.08	0.00	0.00 %
全幅偏移(率)	-0.02 %	-0.41 %	-0.06 %	0.15 %		-0.19	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.68	3.27	55.75	2.58	17.62	10.37	1.43	83228.14
1	6.45	2.62	59.05	2.65	18.49	10.58	1.44	84708.30
2	5.38	2.47	63.44	2.69	18.67	10.55	1.43	82728.71
3	6.27	4.11	52.99	2.55	17.83	10.48	1.43	83927.04
4	4.49	3.08	65.93	2.60	18.09	10.80	1.43	81110.58
5	5.42	6.10	55.91	2.79	19.47	10.14	1.43	87951.16
6	8.68	7.33	54.43	2.75	17.95	10.35	1.43	86167.65
7	10.82	4.72	60.58	2.92	17.08	10.73	1.44	88275.20
8	7.82	2.32	63.62	2.54	18.16	11.03	1.44	81511.42
9	5.93	3.44	46.79	2.27	17.13	10.89	1.43	83229.46
10	6.68	2.83	60.38	2.69	15.68	11.21	1.43	80734.55
11	9.51	3.67	53.92	2.73	15.48	10.86	1.43	80495.33
12	5.81	1.82	67.06	2.69	15.31	11.30	1.44	78436.86
13	4.94	2.37	55.45	2.56	15.58	10.86	1.45	82957.33
14	6.00	2.93	64.88	2.72	15.32	11.20	1.43	81067.31
15	12.64	4.12	58.83	3.36	14.82	11.26	1.43	81954.39
16	7.80	4.45	59.70	3.79	14.03	11.42	1.43	76781.81
17	8.87	4.70	60.74	2.80	16.01	10.86	1.43	81717.42
18	9.11	2.99	57.48	2.63	16.52	10.65	1.46	84850.53
19	7.97	2.02	63.86	2.38	17.62	10.80	1.46	83235.72
20	15.20	5.23	50.75	2.65	16.14	10.89	1.47	82349.41
21	14.38	2.61	60.59	3.98	15.68	11.12	1.47	83216.67
22	10.99	3.99	58.77	2.94	15.67	10.90	1.44	81451.31
23	7.46	3.03	55.50	2.50	16.04	10.70	1.44	82654.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.18	3.59	58.60	2.78	16.68	10.83	1.44	82697.52
最大值	15.20	7.33	67.06	3.98	19.47	11.42	1.49	88275.20
發生時間	20	6	12	21	5	16		7
最小值	4.49	1.82	46.79	2.27	14.03	10.14	1.43	76781.81
發生時間	4	12	9	9	16	5		16
零點偏移(率)	-0.11 %	-0.01 %	-0.25 %	-0.01 %		-0.04	0.00	0.00 %
全幅偏移(率)	-0.04 %	-0.60 %	-0.63 %	0.12 %		-0.07	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								