

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.14	11.70	47.61	2.28	15.87	12.66	1.09	73537.72
1	9.05	12.37	39.61	2.58	14.39	12.98	1.09	71862.05
2	8.14	11.93	48.38	2.52	15.03	12.73	1.09	73721.65
3	7.62	12.45	56.75	2.64	14.84	13.05	1.09	70965.52
4	10.98	11.41	58.11	2.29	16.12	12.41	1.06	76166.37
5	17.68	14.58	50.69	4.63	13.61	12.61	1.07	80876.40
6	7.01	14.74	49.68	2.76	14.18	12.86	1.08	73440.25
7	7.32	14.53	49.50	2.82	13.73	12.81	1.09	74640.75
8	10.95	14.02	48.24	3.52	13.59	12.82	1.09	73675.84
9	8.30	12.13	45.22	3.16	13.26	12.96	1.07	71941.43
10	9.11	11.66	50.06	2.99	13.98	12.81	1.07	73690.29
11	10.20	11.86	50.32	3.03	13.59	12.95	1.09	72741.68
12	8.05	12.29	45.27	3.14	13.18	12.91	1.07	72620.45
13	5.42	12.19	44.47	3.01	13.22	12.81	1.08	73328.38
14	8.13	11.53	47.59	2.68	14.41	12.51	1.07	75700.35
15	9.49	11.45	54.55	2.86	14.10	12.56	1.08	75396.29
16	10.09	11.44	57.67	3.80	14.41	12.45	1.07	74673.92
17	13.64	12.15	55.78	4.18	14.54	12.36	1.05	74914.52
18	9.43	11.98	57.85	3.79	13.99	12.48	1.07	74829.77
19	11.01	11.92	57.58	2.60	13.29	12.62	1.06	72181.11
20	5.27	11.11	57.63	1.72	15.61	12.18	1.09	77800.97
21	12.69	11.15	44.07	3.40	14.99	12.34	1.09	75284.20
22	3.82	11.10	59.05	2.24	15.71	12.28	1.09	75338.16
23	9.22	11.10	57.29	3.69	14.99	12.34	1.08	75739.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.37	12.20	51.37	3.01	14.36	12.65	1.08	74377.83
最大值	17.68	14.74	59.05	4.63	16.12	13.05	1.09	80876.40
發生時間	5	6	22	5	4	3		5
最小值	3.82	11.10	39.61	1.72	13.18	12.18	1.04	70965.52
發生時間	22	22	1	20	12	20		3
零點偏移(率)	-0.09 %	-0.09 %	-0.32 %	-0.21 %		-0.14	-0.01	0.30 %
全幅偏移(率)	-0.81 %	1.22 %	0.84 %	0.56 %		-0.11	0.04	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.01	12.61	52.41	1.76	16.63	11.33	1.04	75923.88
1	8.90	12.42	52.35	1.31	17.42	11.13	1.02	77974.21
2	9.18	12.78	43.90	1.24	18.06	11.34	1.02	78100.01
3	9.52	13.43	49.87	1.30	17.42	11.89	1.02	74249.66
4	8.99	12.70	46.40	2.31	16.41	11.45	1.03	78089.15
5	8.68	12.35	45.79	2.66	16.35	11.03	1.03	82039.10
6	3.81	10.36	60.60	1.74	16.56	11.24	1.02	79104.71
7	6.51	11.90	57.39	1.22	17.72	10.60	1.02	83875.12
8	6.67	13.16	49.69	2.46	16.88	10.95	1.02	81571.55
9	6.44	12.55	60.47	1.76	16.14	11.36	1.02	79316.73
10	8.18	12.29	41.19	1.19	16.95	11.06	1.03	78296.77
11	6.52	12.31	45.31	1.40	15.82	11.20	1.02	80537.33
12	6.85	14.39	47.28	2.44	13.84	11.72	1.03	76387.39
13	7.77	12.67	53.57	1.66	15.64	11.53	1.03	77370.71
14	7.60	12.61	52.10	1.40	15.69	11.49	1.05	78021.32
15	8.68	12.31	52.60	1.90	16.67	11.05	1.03	79785.22
16	6.76	11.99	52.33	0.90	17.67	10.57	1.02	82236.68
17	8.49	12.41	59.06	1.16	16.35	11.21	1.03	79756.77
18	11.44	12.69	67.70	1.38	15.94	11.34	1.03	79129.76
19	7.59	12.59	62.59	1.15	16.28	11.32	1.04	78525.30
20	6.80	11.98	61.81	0.34	18.92	10.17	1.02	84305.32
21	8.55	12.29	56.40	0.73	17.05	10.97	1.02	78891.15
22	13.37	12.16	63.77	0.85	16.44	11.04	1.05	81030.99
23	6.64	12.60	60.32	0.58	16.82	11.33	1.06	78370.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.04	12.48	53.95	1.45	16.65	11.18	1.03	79287.04
最大值	13.37	14.39	67.70	2.66	18.92	11.89	1.10	84305.32
發生時間	22	12	18	5	20	3		20
最小值	3.81	10.36	41.19	0.34	13.84	10.17	1.02	74249.66
發生時間	6	6	10	20	12	20		3
零點偏移(率)	-0.13 %	0.01 %	-0.05 %	-0.01 %		-0.12	-0.01	-0.10 %
全幅偏移(率)	0.62 %	1.71 %	0.09 %	0.28 %		-0.30	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.34	11.15	53.50	2.10	17.62	9.96	1.31	73144.95
1	10.22	11.32	48.05	2.30	16.89	10.06	1.32	71815.25
2	5.48	11.24	51.31	2.12	18.53	9.88	1.35	71744.39
3	6.72	11.13	48.06	2.20	17.12	9.96	1.36	71967.97
4	9.20	11.54	47.67	2.44	17.32	9.80	1.36	72711.22
5	5.72	11.74	38.07	2.43	17.66	9.55	1.34	68433.82
6	11.26	10.91	41.78	2.85	16.98	9.58	1.35	71030.02
7	8.82	10.90	49.33	2.77	18.55	9.55	1.37	73437.81
8	12.01	10.94	41.48	3.26	17.36	9.09	1.37	74349.97
9	9.28	11.33	46.48	2.22	16.82	9.84	1.32	71125.13
10	6.60	10.96	50.01	2.24	16.66	9.76	1.35	70607.93
11	9.43	10.87	51.18	2.34	17.33	9.62	1.37	72308.07
12	7.83	10.95	56.61	2.34	16.62	9.82	1.32	70992.67
13	11.34	10.82	58.42	2.85	15.89	9.65	1.36	71152.63
14	10.61	10.86	57.44	2.23	17.10	9.75	1.36	70329.16
15	8.48	10.86	54.79	2.31	17.08	9.40	1.36	71830.44
16	10.74	10.77	44.68	2.63	16.62	9.34	1.31	71605.19
17	4.64	11.12	52.47	1.72	17.30	9.85	1.31	68260.20
18	15.23	10.63	69.16	3.22	17.70	9.36	1.36	78038.32
19	6.02	11.38	63.73	2.52	15.72	10.22	1.36	70753.74
20	5.04	10.97	55.40	1.82	17.74	9.58	1.35	73406.92
21	10.62	11.91	51.37	2.77	18.98	9.02	1.35	72559.66
22	6.46	11.95	56.76	3.16	19.01	8.46	1.32	76772.91
23	8.97	10.50	53.35	2.59	18.11	9.29	1.32	75431.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.54	11.11	51.71	2.48	17.36	9.60	1.34	72242.09
最大值	15.23	11.95	69.16	3.26	19.01	10.22	1.40	78038.32
發生時間	18	22	18	8	22	19		18
最小值	4.34	10.50	38.07	1.72	15.72	8.46	1.31	68260.20
發生時間	0	23	5	17	19	22		17
零點偏移(率)	-0.12 %	-0.00 %	-0.04 %	-0.00 %		-0.11	-0.01	0.00 %
全幅偏移(率)	0.82 %	-0.94 %	0.07 %	0.83 %		0.12	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								