

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.45	7.51	50.93	0.86	18.74	11.74	1.02	75381.50
1	3.43	13.84	63.44	0.68	20.32	12.26	1.09	70013.99
2	6.18	8.13	42.91	1.15	18.70	11.32	1.05	78987.26
3	8.11	6.83	45.84	1.75	17.21	11.63	1.05	77898.87
4	7.85	9.18	50.08	1.45	18.11	11.43	1.05	78581.63
5	9.97	10.30	43.62	2.35	16.00	11.94	1.02	73399.39
6	8.38	6.79	46.99	2.32	16.24	11.88	1.03	75139.14
7	7.37	8.15	58.88	0.91	18.38	11.48	1.05	77151.99
8	7.88	9.60	44.03	1.90	16.33	11.81	1.01	73701.22
9	8.67	8.02	43.07	1.66	18.12	11.23	1.01	76868.44
10	9.78	8.66	45.99	1.71	18.08	11.20	1.05	77275.16
11	7.85	9.73	49.33	1.55	16.84	11.97	1.01	71532.58
12	7.31	8.26	58.31	1.04	18.78	11.53	1.02	74396.83
13	6.05	8.31	46.62	0.77	19.39	11.03	1.02	77243.26
14	7.81	9.61	41.61	1.63	17.02	11.37	1.02	76231.35
15	6.57	10.45	43.69	2.07	16.23	11.78	1.03	72586.85
16	5.28	7.08	60.32	0.84	18.23	11.26	1.04	75440.56
17	10.22	7.90	35.16	1.91	16.80	11.14	1.03	77409.16
18	9.22	8.40	27.95	2.27	16.51	11.37	1.04	75813.40
19	7.83	7.18	42.24	1.69	16.88	11.53	1.05	75004.48
20	4.56	8.09	63.26	0.68	18.55	11.57	1.06	77134.27
21	3.20	9.00	42.35	0.53	19.50	10.94	1.04	81407.08
22	1.63	9.99	58.21	0.53	19.05	11.26	1.00	79288.80
23	2.16	7.52	50.80	0.71	19.88	11.01	0.99	80526.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.82	8.69	48.15	1.37	17.91	11.49	1.03	76183.91
最大值	10.22	13.84	63.44	2.35	20.32	12.26	1.33	81407.08
發生時間	17	1	1	5	1	1		21
最小值	1.63	6.79	27.95	0.53	16.00	10.94	0.99	70013.99
發生時間	22	6	18	21	5	21		1
零點偏移(率)	-0.05 %	0.00 %	-0.00 %	-0.01 %		-0.02		0.00 %
全幅偏移(率)	0.02 %	0.20 %	0.41 %	0.23 %		-0.06		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.39	4.28	52.16	1.71	18.60	10.31	1.00	85203.47
1	7.93	5.96	45.09	2.45	17.71	10.50	1.01	84275.97
2	9.04	3.72	59.91	2.85	16.70	10.47	1.02	86150.88
3	4.12	4.72	53.21	3.27	15.92	10.91	1.00	83042.59
4	3.81	8.48	54.64	2.61	16.82	10.76	0.99	83529.73
5	5.19	3.87	58.06	2.85	16.74	10.74	0.99	83592.73
6	2.59	4.09	54.63	2.78	15.53	10.94	0.97	80400.03
7	5.40	3.31	57.62	2.37	17.10	10.60	0.99	83794.68
8	2.48	3.58	46.28	2.57	16.72	10.66	0.99	83931.38
9	3.09	3.17	57.35	2.37	16.71	10.52	0.98	84759.25
10	2.59	4.38	47.12	2.55	15.92	10.89	0.99	82649.19
11	6.76	3.66	54.36	2.49	17.42	10.48	1.00	83830.58
12	5.99	3.58	53.86	2.83	17.64	10.34	1.00	85152.00
13	11.40	9.93	46.88	4.51	16.55	10.55	0.99	83970.61
14	7.36	2.35	53.18	2.97	15.03	10.75	0.99	82952.25
15	4.55	5.18	60.75	2.40	14.28	10.86	0.98	81155.61
16	9.64	2.56	50.28	2.55	16.00	10.58	0.99	83321.41
17	9.51	5.12	61.05	2.77	15.58	10.58	0.99	85454.72
18	9.80	7.25	47.66	2.55	16.17	10.72	0.98	83811.87
19	8.10	3.23	59.59	1.99	16.31	10.78	0.99	83369.31
20	4.65	6.10	50.65	1.72	18.07	10.37	0.97	84486.65
21	0.22	6.86	53.85	1.29	18.45	10.18	0.98	86257.28
22	0.21	6.79	49.94	1.41	18.24	10.44	0.98	84516.13
23	0.46	6.38	47.98	1.85	18.02	10.38	0.99	84917.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.43	4.94	53.17	2.49	16.76	10.60	0.99	83938.56
最大值	11.40	9.93	61.05	4.51	18.60	10.94	1.02	86257.28
發生時間	13	13	17	13	0	6		21
最小值	0.21	2.35	45.09	1.29	14.28	10.18	0.97	80400.03
發生時間	22	14	1	21	15	21		6
零點偏移(率)	0.00 %	0.00 %	-0.03 %	0.00 %		0.01		-0.20 %
全幅偏移(率)	0.28 %	-0.48 %	-0.63 %	-0.07 %		-0.29		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.09	5.34	59.28	1.37	16.39	10.88	0.99	80753.65
1	7.43	7.21	51.01	1.37	16.57	11.43	0.99	75766.19
2	6.95	5.24	49.03	1.61	16.11	10.92	1.01	80566.07
3	8.20	8.50	40.99	1.68	16.81	10.60	1.01	80072.31
4	9.23	7.80	44.08	1.58	16.91	10.75	1.02	81645.51
5	6.90	6.57	43.68	1.25	16.33	10.97	0.99	78211.27
6	6.81	8.59	44.62	1.40	16.10	10.89	1.00	78736.25
7	9.54	4.58	44.98	1.82	15.43	11.13	1.02	76932.56
8	6.18	4.15	44.37	1.36	16.61	10.95	1.02	79184.61
9	5.70	5.53	41.55	1.37	16.24	10.82	1.05	76956.33
10	5.47	6.08	39.40	1.81	14.75	10.89	1.01	74395.62
11	4.33	9.43	38.58	1.99	14.28	10.96	1.03	73449.06
12	4.03	6.35	36.70	1.32	15.56	10.71	1.06	74302.36
13	8.68	7.79	39.73	2.11	14.60	11.05	1.06	74065.41
14	8.31	3.48	40.22	2.21	14.53	10.97	1.03	75038.16
15	8.87	4.13	42.30	2.63	13.76	10.79	0.99	74519.92
16	8.09	5.54	43.97	2.76	15.14	10.33	0.99	74057.11
17	9.81	5.67	39.80	2.54	15.51	10.15	0.99	75890.41
18	9.18	4.21	33.88	1.63	15.93	10.47	1.03	73401.55
19	8.91	9.02	50.73	1.19	18.52	9.84	1.05	83099.70
20	5.06	6.91	41.35	1.09	16.92	10.41	1.04	79159.93
21	4.05	5.87	32.93	0.71	18.73	10.16	0.99	80599.66
22	6.11	5.07	40.97	1.04	18.14	9.81	0.99	81816.15
23	6.74	8.46	35.20	1.16	18.01	9.94	1.00	79510.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.19	6.31	42.47	1.62	16.16	10.66	1.01	77588.78
最大值	9.81	9.43	59.28	2.76	18.73	11.43	1.07	83099.70
發生時間	17	11	0	16	21	1		19
最小值	4.03	3.48	32.93	0.71	13.76	9.81	0.99	73401.55
發生時間	12	14	21	21	15	22		18
零點偏移(率)	-0.06 %	-0.04 %	-0.04 %	-0.01 %		-0.01		-0.10 %
全幅偏移(率)	0.00 %	0.22 %	-0.33 %	0.16 %		0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								