

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月04日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.68	10.29	54.24	1.71	15.04	12.37	1.01	77221.66
1	9.71	5.17	54.23	1.46	16.94	11.82	1.02	79585.81
2	9.68	1.61	31.73	1.86	15.78	11.69	1.02	83042.84
3	7.62	5.05	42.77	2.28	14.42	11.99	1.02	81691.00
4	9.27	5.37	53.36	1.78	15.85	11.91	1.02	81172.71
5	12.19	5.67	57.46	2.35	15.24	11.95	1.01	82140.46
6	9.51	4.71	57.31	1.97	14.88	11.98	1.02	80969.06
7	5.86	6.91	57.01	1.11	15.37	12.23	1.02	78515.67
8	8.07	6.88	51.07	1.23	16.82	11.79	1.02	81223.68
9	3.06	4.95	54.47	0.36	17.61	11.84	1.00	79689.27
10	6.53	4.95	50.57	0.46	16.99	11.56	1.01	82508.22
11	6.00	4.77	50.90	0.83	16.58	11.78	0.97	80602.35
12	4.98	4.59	66.85	0.66	16.69	11.86	1.00	79611.39
13	8.66	4.37	56.22	0.49	17.32	11.39	0.98	82871.58
14	8.77	4.35	50.38	0.76	17.12	11.50	0.99	81976.07
15	3.41	7.59	63.10	1.13	16.09	12.37	1.02	75792.34
16	0.52	9.10	63.68	0.73	16.48	12.70	1.02	72695.55
17	3.41	7.14	49.22	0.71	18.03	10.94	0.97	86219.43
18	6.68	7.24	57.22	1.16	15.97	12.05	0.97	78417.59
19	4.59	6.57	45.16	0.62	17.36	11.38	0.97	83043.50
20	5.54	6.06	45.89	0.85	16.72	11.37	0.97	83937.48
21	7.03	6.04	47.85	0.78	16.45	11.59	0.97	82099.52
22	10.01	6.40	55.79	0.70	16.86	11.68	1.00	81159.71
23	6.75	7.69	59.61	0.79	16.10	12.49	0.98	75351.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.94	5.98	53.17	1.12	16.36	11.84	1.00	80480.75
最 大 值	12.19	10.29	66.85	2.35	18.03	12.70	1.06	86219.43
發生時間	5	0	12	5	17	16		17
最 小 值	0.52	1.61	31.73	0.36	14.42	10.94	0.97	72695.55
發生時間	16	2	2	9	3	17		16
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	-0.01 %		-0.10		0.10 %
全幅偏移(率)	0.00 %	1.96 %	-0.13 %	0.47 %		0.30		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 113年05月04日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	9.44	4.45	54.41	2.45	16.18	11.55	1.07	78456.69
1	11.02	5.40	56.60	2.88	16.04	11.70	1.08	77010.27
2	9.40	3.49	31.22	4.14	13.96	11.90	1.06	77002.30
3	9.13	3.95	40.28	2.93	15.35	11.41	1.08	80940.77
4	7.86	4.12	50.55	3.16	15.74	12.07	1.08	74687.16
5	11.54	4.22	42.10	3.88	16.28	11.07	1.07	81313.53
6	14.40	4.05	45.93	3.19	17.40	10.92	1.06	84540.96
7	9.27	3.06	39.16	2.72	15.57	11.50	1.05	78914.09
8	7.93	3.87	44.42	2.51	16.29	11.49	1.04	78313.32
9	3.90	4.72	62.42	1.41	16.97	12.02	1.03	72597.60
10	2.49	4.47	50.51	1.81	16.71	12.04	1.05	73196.85
11	8.25	3.88	44.64	1.92	17.52	10.68	1.06	83928.45
12	11.38	5.42	49.17	2.59	17.25	10.60	1.04	84504.44
13	8.49	2.92	52.26	1.79	18.18	10.63	1.06	82664.06
14	9.93	3.82	48.02	1.34	20.11	9.99	1.05	85471.47
15	11.16	4.10	42.87	2.68	18.00	10.52	1.04	84744.99
16	7.77	3.17	51.82	2.19	18.41	10.46	1.05	84005.41
17	9.06	4.08	51.68	1.54	19.23	10.29	1.06	84773.00
18	8.86	2.75	50.86	2.38	16.73	11.06	1.06	81341.82
19	9.31	3.16	55.17	2.09	16.87	11.09	1.06	81018.44
20	9.64	3.77	54.87	1.85	17.14	11.10	1.06	80215.18
21	9.65	3.90	49.50	2.13	17.05	11.04	1.04	81109.26
22	8.91	4.03	49.20	1.69	16.95	11.12	1.05	80470.24
23	9.03	4.06	51.32	1.85	16.90	11.27	1.05	79546.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.08	3.95	48.71	2.38	16.95	11.15	1.06	80448.62
最 大 值	14.40	5.42	62.42	4.14	20.11	12.07	1.10	85471.47
發生時間	6	12	9	2	14	4		14
最 小 值	2.49	2.75	31.22	1.34	13.96	9.99	1.02	72597.60
發生時間	10	18	2	14	2	14		9
零點偏移(率)	-0.02 %	-0.00 %	-0.01 %	-0.06 %		-0.06		-0.10 %
全幅偏移(率)	0.14 %	1.70 %	-0.24 %	0.37 %		0.15		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年05月04日

報表日期: 113年05月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.24	6.15	60.84	1.04	16.11	11.21	0.99	76625.00
1	4.30	6.35	59.94	1.02	16.81	10.92	0.99	79360.61
2	3.46	7.38	59.63	2.11	14.81	11.70	1.00	75325.18
3	2.32	3.01	58.48	2.11	15.57	10.83	0.99	81525.13
4	3.54	1.47	60.94	1.30	17.75	10.66	0.99	80695.97
5	2.57	2.41	57.24	1.25	17.23	10.88	0.99	79625.05
6	5.22	9.83	57.63	1.94	15.65	11.00	0.99	79537.30
7	5.55	5.75	52.51	1.28	17.74	10.67	1.03	79895.09
8	4.45	8.39	58.13	0.83	18.56	10.53	1.04	80861.02
9	7.32	5.24	58.69	1.10	18.30	10.39	1.04	82320.31
10	2.00	6.14	55.50	0.99	17.10	11.99	1.07	70381.38
11	3.01	4.57	49.30	0.76	18.76	10.01	1.05	84447.42
12	6.01	5.97	56.20	1.45	16.56	10.55	1.06	81293.78
13	5.87	2.82	64.17	0.99	18.22	10.53	1.04	80627.00
14	1.31	2.96	54.90	0.57	19.85	9.93	1.03	83454.99
15	3.33	3.59	56.95	0.80	18.08	10.15	1.04	81144.92
16	5.57	4.29	60.95	1.00	18.86	9.92	1.06	82722.77
17	4.30	5.10	57.19	0.81	18.70	10.12	1.04	81936.59
18	1.40	6.29	56.84	0.65	18.17	10.38	1.03	80077.08
19	1.39	3.55	44.32	0.51	19.16	9.55	1.00	81374.22
20	1.60	4.03	54.55	0.62	18.62	9.95	1.03	83730.03
21	3.11	4.62	61.22	0.83	17.56	10.34	1.03	81256.33
22	6.42	4.95	59.87	1.08	16.64	10.69	1.04	78654.21
23	1.01	4.59	56.23	0.51	17.44	10.78	1.04	78675.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.72	4.98	57.18	1.06	17.59	10.57	1.03	80231.12
最 大 值	7.32	9.83	64.17	2.11	19.85	11.99	1.09	84447.42
發生時間	9	6	13	2	14	10		11
最 小 值	1.01	1.47	44.32	0.51	14.81	9.55	0.99	70381.38
發生時間	23	4	19	19	2	19		10
零點偏移(率)	-0.02 %	-0.02 %	-0.01 %	-0.03 %		-0.05		-0.10 %
全幅偏移(率)	14.34 %	1.74 %	-0.47 %	0.41 %		0.41		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								