

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.02	12.89	52.93	2.74	17.55	11.19	1.29	80804.26
1	7.15	13.01	53.46	2.44	19.00	11.11	1.29	80610.95
2	11.65	12.88	49.55	1.79	18.43	11.04	1.29	80399.99
3	7.83	13.28	40.66	1.86	17.98	10.96	1.29	82282.76
4	14.52	13.45	53.33	3.32	17.37	11.19	1.29	81937.35
5	4.35	13.35	57.12	1.09	17.97	11.64	1.30	76224.04
6	10.19	12.53	46.10	3.56	17.16	10.97	1.30	82286.50
7	11.48	13.04	46.39	3.09	16.92	11.32	1.31	81522.72
8	5.72	13.41	50.20	1.53	17.05	11.79	1.31	75623.54
9	10.87	12.41	47.18	3.37	17.66	10.97	1.29	84436.35
10	11.36	12.88	52.95	2.77	17.82	11.34	1.29	79670.28
11	12.12	12.79	46.59	3.94	15.87	11.49	1.29	80525.19
12	4.53	13.05	48.59	2.45	15.95	11.70	1.28	77643.81
13	8.87	12.78	49.09	1.97	17.50	11.30	1.29	79469.83
14	8.46	12.79	52.54	1.85	18.06	11.22	1.29	76683.91
15	8.70	12.69	60.76	1.71	18.54	11.01	1.28	80849.25
16	9.60	11.82	43.47	2.39	18.47	10.67	1.27	85045.14
17	9.31	13.20	41.90	2.49	17.73	10.85	1.29	84314.15
18	4.87	12.44	54.60	2.51	16.15	11.66	1.29	78170.61
19	6.94	11.85	51.15	2.49	18.51	10.98	1.29	81796.31
20	9.08	11.93	44.30	3.39	18.65	10.65	1.28	84495.59
21	8.60	11.38	47.49	2.71	18.75	10.72	1.28	84054.87
22	8.03	11.93	43.17	3.21	17.67	10.86	1.29	83410.76
23	9.09	12.59	54.95	1.61	18.19	11.65	1.29	76460.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.89	12.68	49.52	2.51	17.71	11.18	1.29	80779.92
最大值	14.52	13.45	60.76	3.94	19.00	11.79	1.31	85045.14
發生時間	4	4	15	11	1	8		16
最小值	4.35	11.38	40.66	1.09	15.87	10.65	1.25	75623.54
發生時間	5	21	3	5	11	20		8
零點偏移(率)	-0.10 %	-0.08 %	-0.02 %	0.00 %		-0.23	-0.01	0.30 %
全幅偏移(率)	1.09 %	1.54 %	0.31 %	1.15 %		-0.06	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.84	10.65	56.66	1.41	16.92	11.82	0.79	75212.68
1	8.83	9.17	50.23	2.25	16.29	11.71	0.79	78007.07
2	11.17	7.77	57.14	1.38	16.91	11.26	0.79	78748.28
3	11.21	8.32	58.61	1.31	16.94	11.40	0.81	78026.11
4	9.16	8.97	57.56	0.83	18.22	11.14	0.81	80487.33
5	10.49	7.56	58.61	1.27	17.27	11.34	0.81	78683.36
6	8.13	7.31	47.00	2.58	15.48	12.05	0.83	80391.83
7	9.61	7.87	54.10	1.36	16.99	11.31	0.83	77045.68
8	10.99	7.12	51.03	1.67	16.21	11.44	0.82	77081.61
9	12.79	7.62	42.86	1.74	16.60	11.40	0.81	77386.44
10	14.41	8.86	44.42	2.11	15.93	11.77	0.83	78897.25
11	8.20	8.69	38.21	1.32	16.41	11.46	0.83	76915.74
12	7.97	7.50	47.32	0.88	17.52	10.88	0.83	80215.24
13	15.13	8.19	40.50	2.12	16.11	11.62	0.82	77956.74
14	7.95	8.26	41.07	1.27	15.84	12.04	0.81	77408.82
15	9.73	8.56	52.14	1.19	16.24	11.92	0.82	77936.86
16	9.00	8.77	41.95	1.38	15.71	11.91	0.83	77181.25
17	7.52	8.01	51.74	1.93	15.10	12.13	0.83	77156.51
18	8.81	8.98	44.42	1.47	16.01	11.99	0.81	76041.34
19	9.98	7.80	51.88	0.95	16.61	12.06	0.82	73736.63
20	8.60	8.98	48.88	0.99	17.11	11.97	0.82	74982.61
21	13.39	8.51	51.97	1.46	16.88	11.73	0.81	79154.05
22	7.09	10.39	48.20	1.17	16.67	12.02	0.80	76403.65
23	9.95	8.17	56.72	1.00	16.87	12.00	0.80	77474.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.08	8.42	49.72	1.46	16.54	11.68	0.81	77605.49
最大值	15.13	10.65	58.61	2.58	18.22	12.13	0.84	80487.33
發生時間	13	0	3	6	4	17		4
最小值	7.09	7.12	38.21	0.83	15.10	10.88	0.79	73736.63
發生時間	22	8	11	4	17	12		19
零點偏移(率)	-0.10 %	-0.12 %	-0.03 %	-0.01 %		-0.09	-0.06	-0.10 %
全幅偏移(率)	1.88 %	-0.92 %	-0.56 %	0.17 %		-0.11	0.31	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.98	11.47	55.55	2.48	18.10	10.06	1.32	76091.12
1	10.12	11.57	51.96	2.84	18.83	9.80	1.31	75928.25
2	8.73	12.23	47.07	1.67	18.81	9.31	1.31	73975.26
3	11.23	11.33	45.19	1.69	19.04	9.20	1.33	75687.61
4	8.58	11.63	48.21	2.74	18.78	9.45	1.33	74606.11
5	9.46	11.62	47.30	3.06	17.89	9.36	1.32	74974.24
6	9.87	10.35	44.81	2.88	17.77	9.33	1.33	74163.00
7	12.03	11.26	38.81	3.39	17.57	9.22	1.34	77006.35
8	8.41	11.38	45.19	2.45	17.58	9.52	1.34	73312.67
9	8.69	11.14	40.45	2.57	18.76	9.15	1.33	74990.42
10	7.93	11.54	32.70	2.52	19.10	9.09	1.32	76725.75
11	10.87	10.61	40.46	3.59	18.38	9.18	1.32	73577.79
12	6.30	10.98	45.21	3.08	18.91	9.35	1.34	70991.12
13	5.30	11.16	41.63	2.89	18.77	9.66	1.28	65326.07
14	6.79	6.48	35.61	2.40	20.04	8.29	1.30	76407.37
15	8.16	7.12	48.30	2.42	19.03	8.90	1.33	75372.01
16	11.19	12.62	40.35	2.16	18.43	8.83	1.29	77222.08
17	9.67	13.16	62.80	1.72	16.76	10.81	1.31	77502.93
18	6.97	13.02	53.57	1.56	16.62	10.73	1.31	77910.02
19	9.91	13.18	49.46	1.72	16.35	10.38	1.29	74423.08
20	7.49	12.47	49.46	1.53	17.86	9.98	1.31	77290.12
21	12.41	12.24	48.35	1.73	18.56	9.74	1.31	78745.49
22	9.00	12.52	52.71	1.71	18.22	10.07	1.31	77008.37
23	9.00	11.62	44.64	2.68	18.73	9.64	1.31	77321.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.05	11.36	46.24	2.40	18.29	9.54	1.32	75273.26
最大值	12.41	13.18	62.80	3.59	20.04	10.81	1.38	78745.49
發生時間	21	19	17	11	14	17		21
最小值	5.30	6.48	32.70	1.53	16.35	8.29	1.27	65326.07
發生時間	13	14	10	20	19	14		13
零點偏移(率)	-0.01 %	0.00 %	-0.05 %	-0.00 %		-0.08	-0.01	0.00 %
全幅偏移(率)	0.02 %	1.22 %	0.87 %	0.86 %		-0.04	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								