

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.15	13.19	50.84	2.51	13.16	12.21	1.25	72044.70
1	9.09	12.70	55.06	1.76	14.03	12.49	1.26	71980.49
2	10.30	14.07	60.82	2.16	13.49	12.92	1.24	68728.75
3	9.31	12.00	51.86	1.85	13.25	12.10	1.24	77597.06
4	16.30	12.00	54.16	1.68	14.64	11.87	1.25	80073.03
5	12.81	13.27	55.66	3.43	14.22	12.25	1.21	75910.68
6	14.55	14.23	60.53	3.92	14.03	12.44	1.19	75973.62
7	8.89	13.95	56.80	4.05	13.42	12.53	1.18	75378.73
8	11.19	14.36	45.96	3.31	13.52	12.29	1.20	76500.22
9	11.15	14.42	52.33	2.31	14.37	12.55	1.25	73100.99
10	10.56	13.31	54.78	2.73	15.06	11.74	1.23	79662.03
11	10.54	13.16	51.08	3.55	14.25	11.92	1.20	77929.34
12	9.78	13.64	46.94	3.31	13.79	11.87	1.20	77482.37
13	9.69	13.73	52.38	3.00	14.15	12.03	1.20	72186.07
14	9.34	13.60	64.80	3.30	13.91	12.18	1.19	71888.69
15	9.47	12.96	57.69	3.27	14.20	11.75	1.19	75665.57
16	12.56	12.95	43.49	4.73	14.67	11.67	1.20	77148.81
17	7.15	14.61	54.40	5.19	13.07	12.71	1.19	69317.18
18	8.85	18.79	56.73	1.25	11.92	14.26	1.18	57857.06
19	9.05	12.43	63.55	1.09	12.77	13.92	1.21	63127.72
20	10.05	10.07	47.85	0.96	14.48	11.74	1.21	80115.69
21	9.37	9.12	57.31	1.18	15.39	11.59	1.22	80751.70
22	10.14	11.86	54.98	2.54	15.75	11.12	1.19	84622.90
23	11.48	14.57	54.94	2.95	14.68	11.97	1.20	78212.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.41	13.29	54.37	2.75	14.01	12.25	1.21	74718.99
最大值	16.30	18.79	64.80	5.19	15.75	14.26	1.27	84622.90
發生時間	4	18	14	17	22	18		22
最小值	7.15	9.12	43.49	0.96	11.92	11.12	1.18	57857.06
發生時間	17	21	16	20	18	22		18
零點偏移(率)	0.07 %	-0.01 %	-0.12 %	-0.01 %		-0.05	-0.01	0.20 %
全幅偏移(率)	1.45 %	-2.25 %	-0.75 %	-1.40 %		0.18	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.30	11.56	49.08	2.00	14.69	10.68	1.04	74797.79
1	12.62	12.08	61.60	2.44	15.12	11.08	1.03	76136.28
2	8.57	11.95	57.84	1.86	14.09	11.10	1.02	73481.23
3	9.09	11.35	40.16	1.68	14.96	10.38	1.01	72106.27
4	6.00	11.10	39.21	2.05	14.68	10.15	1.00	73868.87
5	8.19	11.00	38.65	1.80	14.49	10.12	1.01	73710.94
6	8.06	11.50	40.77	1.88	14.74	10.15	1.02	72794.94
7	7.90	11.35	39.42	1.85	14.83	10.21	1.02	73830.73
8	6.26	11.53	41.46	1.77	14.52	10.64	1.02	74823.92
9	6.68	12.04	54.38	1.68	14.04	11.17	1.06	75380.08
10	7.29	12.17	54.20	1.79	13.95	11.24	1.05	75173.68
11	13.61	12.07	49.48	3.21	13.62	11.24	1.07	74253.01
12	9.03	12.26	51.67	1.59	14.31	11.21	1.06	72538.62
13	12.92	11.59	55.08	3.30	15.21	10.45	1.04	77492.55
14	12.07	11.68	55.62	3.71	14.51	10.58	1.04	77234.88
15	12.19	12.26	57.18	2.57	13.09	11.44	1.03	69495.47
16	11.41	11.58	43.76	1.53	14.49	10.70	1.03	73500.33
17	14.08	11.49	41.83	2.11	13.88	10.67	1.05	74248.70
18	9.75	11.81	43.29	2.12	13.69	11.00	1.04	71694.06
19	10.59	11.54	43.20	2.51	14.13	10.73	1.03	74871.97
20	11.95	12.00	46.17	2.19	14.17	11.14	1.03	74270.74
21	9.30	11.67	46.48	2.18	14.47	10.83	1.02	76650.88
22	11.14	12.15	49.61	2.49	13.56	11.29	1.02	73247.73
23	12.46	11.51	46.34	2.62	15.14	10.59	1.03	78414.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.06	11.72	47.77	2.21	14.35	10.78	1.03	74334.09
最大值	14.08	12.26	61.60	3.71	15.21	11.44	1.08	78414.47
發生時間	17	12	1	14	13	15		23
最小值	6.00	11.00	38.65	1.53	13.09	10.12	0.99	69495.47
發生時間	4	5	5	16	15	5		15
零點偏移(率)	-0.02 %	-0.01 %	-0.04 %	0.00 %		-0.09	-0.01	0.10 %
全幅偏移(率)	1.52 %	0.07 %	0.45 %	0.09 %		-0.02	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.76	10.53	48.32	3.42	15.41	9.37	1.37	71788.35
1	7.66	10.99	48.49	2.59	16.20	9.84	1.38	69758.85
2	9.79	11.40	54.19	3.69	13.97	10.59	1.39	68425.53
3	9.53	10.96	50.67	3.05	15.15	10.11	1.40	72135.13
4	8.91	11.05	52.81	3.45	14.24	10.26	1.41	71200.18
5	8.39	11.17	53.57	3.67	13.43	10.49	1.41	69547.21
6	10.77	10.96	52.78	4.15	13.31	10.19	1.39	70303.49
7	5.63	11.94	54.91	3.58	13.81	10.11	1.42	66229.53
8	6.37	11.77	49.39	3.02	14.34	10.09	1.43	70115.36
9	6.10	11.56	53.77	3.05	14.38	10.25	1.44	70192.60
10	9.08	11.56	57.22	3.26	14.33	9.93	1.43	70186.24
11	9.05	11.20	59.74	2.90	14.78	9.79	1.42	68674.14
12	9.84	12.12	56.11	3.06	15.38	9.22	1.43	70445.12
13	10.53	11.15	61.23	2.90	15.70	9.73	1.41	67507.27
14	9.30	11.49	56.44	2.98	15.80	9.09	1.38	70547.74
15	9.02	11.27	54.89	3.10	14.96	9.59	1.39	67631.92
16	11.18	11.38	50.91	2.96	15.80	9.30	1.43	70179.78
17	8.35	11.30	49.12	2.59	16.36	9.07	1.42	71692.44
18	10.16	11.47	48.36	4.42	14.38	9.37	1.37	68785.01
19	9.23	10.67	54.94	3.00	14.86	9.81	1.41	69381.88
20	12.05	10.51	43.27	2.79	16.06	9.20	1.40	72541.92
21	9.17	10.75	46.71	2.87	15.16	9.68	1.39	70523.79
22	10.62	10.63	48.10	2.90	15.16	9.62	1.41	70673.60
23	9.21	10.74	53.80	3.29	14.12	9.86	1.43	70010.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.28	11.19	52.49	3.20	14.88	9.77	1.41	69936.57
最大值	12.76	12.12	61.23	4.42	16.36	10.59	1.46	72541.92
發生時間	0	12	13	18	17	2		20
最小值	5.63	10.51	43.27	2.59	13.31	9.07	1.36	66229.53
發生時間	7	20	20	1	6	17		7
零點偏移(率)	-0.02 %	-0.01 %	-0.01 %	0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-1.85 %	0.41 %	-0.02 %	-0.06 %		0.15	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								