

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.03	2.63	61.26	0.59	18.54	11.41	1.03	80501.75
1	8.93	4.49	52.36	1.19	18.83	10.87	1.05	85393.40
2	8.97	4.75	62.40	1.02	17.40	11.54	1.05	81333.65
3	8.11	4.50	39.15	1.12	17.01	11.29	1.06	83218.79
4	8.21	5.62	59.61	2.02	14.82	12.06	1.06	77940.34
5	9.56	4.49	52.63	0.56	17.79	11.48	1.04	76396.13
6	8.26	5.01	51.25	1.06	16.19	11.42	1.04	82541.50
7	3.63	6.66	64.93	0.92	16.15	11.64	1.06	80781.84
8	6.51	8.96	47.85	0.92	17.03	11.72	1.06	79431.57
9	9.09	6.93	56.95	2.35	14.76	11.72	1.06	80849.98
10	10.48	5.20	58.60	3.15	14.35	11.85	1.06	78821.16
11	8.08	3.49	53.00	3.15	13.94	11.94	1.05	78296.11
12	6.49	5.28	58.18	2.93	14.03	11.95	1.04	78371.95
13	5.89	3.44	59.41	2.31	14.28	12.25	1.06	76086.00
14	6.29	7.35	64.05	2.47	14.86	11.87	1.04	80386.22
15	7.40	7.50	62.67	2.58	14.72	12.01	1.03	78669.56
16	7.94	4.90	42.22	1.54	16.00	11.38	1.04	83169.58
17	7.91	4.67	43.76	1.96	15.59	11.56	1.06	82151.14
18	9.61	4.29	51.81	1.62	16.30	11.39	1.04	84082.93
19	9.43	4.22	46.91	2.20	15.35	11.38	1.06	83625.00
20	10.94	7.91	45.06	3.18	13.64	11.72	1.06	81323.52
21	7.25	4.59	49.36	2.70	15.59	11.64	1.05	81653.07
22	10.35	4.12	53.47	1.54	16.50	11.62	1.04	81288.68
23	8.03	4.15	59.29	1.40	15.71	12.04	1.04	78351.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.02	5.21	54.01	1.85	15.81	11.66	1.05	80611.08
最大值	10.94	8.96	64.93	3.18	18.83	12.25	1.06	85393.40
發生時間	20	8	7	20	1	13		1
最小值	3.63	2.63	39.15	0.56	13.64	10.87	1.02	76086.00
發生時間	7	0	3	5	20	1		13
零點偏移(率)	-0.03 %	-0.10 %	-0.06 %	-0.01 %		-0.05		0.00 %
全幅偏移(率)	0.00 %	-0.15 %	-0.26 %	-0.50 %		0.11		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.47	4.02	51.10	1.13	19.31	10.30	1.02	83012.90
1	2.62	4.62	50.90	1.35	18.91	11.00	1.02	77923.76
2	3.82	6.31	36.73	1.60	18.47	10.41	1.02	83110.20
3	4.53	3.16	46.65	1.78	16.81	11.62	1.02	75055.22
4	2.67	3.50	55.99	1.81	17.37	11.42	1.02	76931.25
5	1.12	4.18	54.87	2.12	15.81	12.86	1.05	66428.87
6	1.40	3.84	45.08	1.68	17.12	11.65	1.02	76116.54
7	3.50	3.42	44.60	2.20	15.87	11.43	1.02	77793.44
8	2.83	3.74	46.13	2.31	14.92	11.78	1.02	76051.55
9	4.26	3.73	48.76	2.68	14.70	11.75	1.02	76160.07
10	6.18	8.25	48.44	3.10	13.87	11.95	0.99	75306.04
11	6.23	5.71	46.04	3.82	12.86	12.05	0.99	74967.56
12	2.79	2.85	55.69	2.41	13.67	11.85	1.02	76234.84
13	6.15	4.69	45.94	2.98	14.63	11.54	1.02	78096.49
14	8.13	4.72	46.09	3.08	13.99	11.87	1.02	75621.74
15	11.57	3.57	53.45	2.37	15.94	11.36	1.03	77919.11
16	8.16	4.96	43.69	3.30	13.38	11.66	1.02	76906.62
17	4.20	3.80	49.82	3.83	13.64	12.14	1.02	74447.62
18	4.95	2.67	48.96	3.54	13.82	11.95	0.99	75805.54
19	9.95	5.60	52.45	4.63	13.75	11.90	0.98	75897.37
20	8.55	4.38	40.57	4.45	15.06	11.64	1.02	77522.72
21	7.48	3.11	40.27	4.57	15.24	11.41	1.02	79132.58
22	6.78	2.42	31.88	2.88	15.70	11.67	1.02	75623.88
23	0.33	6.33	32.11	3.40	13.88	12.38	1.02	71659.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.03	4.32	46.51	2.79	15.36	11.65	1.02	76405.23
最大值	11.57	8.25	55.99	4.63	19.31	12.86	1.06	83110.20
發生時間	15	10	4	19	0	5		2
最小值	0.33	2.42	31.88	1.13	12.86	10.30	0.97	66428.87
發生時間	23	22	22	0	11	0		5
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	0.00 %		-0.01		-0.10 %
全幅偏移(率)	0.14 %	-0.68 %	0.00 %	0.29 %		-0.08		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.82	3.38	55.58	0.70	16.79	10.72	0.99	79192.62
1	7.14	4.36	56.54	0.81	17.73	10.36	0.99	77529.59
2	8.24	3.41	52.34	0.72	17.49	10.28	0.99	78717.98
3	7.47	3.05	56.16	0.79	17.20	10.20	0.99	78151.74
4	3.91	3.12	55.64	0.48	16.87	10.33	1.00	77762.42
5	5.67	2.80	55.41	0.82	16.06	10.48	0.99	77787.68
6	2.22	3.09	61.02	0.43	16.74	10.79	0.99	76204.14
7	1.78	5.35	49.93	0.26	17.46	9.95	1.02	82547.94
8	1.97	5.19	50.41	0.39	18.14	9.85	1.03	80952.90
9	1.43	6.37	42.99	0.90	15.03	10.94	1.04	75051.54
10	4.82	7.47	43.77	2.18	13.57	11.07	1.04	73146.54
11	3.01	1.81	43.84	1.05	15.00	10.60	1.03	74974.85
12	1.70	9.44	41.23	1.77	13.33	10.89	1.00	70643.17
13	4.60	4.98	54.80	2.19	13.55	10.72	1.02	74294.85
14	2.10	2.50	59.91	1.86	13.29	11.12	1.03	74287.58
15	3.09	2.70	60.13	1.00	14.93	11.02	1.03	78667.61
16	2.18	7.14	59.88	1.61	13.93	10.99	1.02	77982.48
17	6.71	2.63	63.59	0.90	15.96	10.57	1.03	79090.24
18	13.89	2.75	64.44	1.54	15.66	10.33	1.01	82246.25
19	13.19	6.96	56.77	4.50	14.09	10.44	1.03	77744.67
20	9.26	3.07	55.66	6.80	14.19	10.49	1.00	74514.41
21	6.16	3.44	52.85	2.33	15.58	10.31	1.00	75866.08
22	8.64	3.10	56.55	0.93	15.46	10.50	0.99	74532.84
23	5.70	2.21	60.05	0.63	15.38	10.72	1.00	75244.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.40	4.18	54.56	1.48	15.56	10.57	1.01	76963.95
最大值	13.89	9.44	64.44	6.80	18.14	11.12	1.04	82547.94
發生時間	18	12	18	20	8	14		7
最小值	1.43	1.81	41.23	0.26	13.29	9.85	0.98	70643.17
發生時間	9	11	12	7	14	8		12
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	-0.01 %		0.00		-0.10 %
全幅偏移(率)	-0.78 %	-0.14 %	-0.64 %	0.32 %		0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								