

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月30日

報表日期: 114年05月30日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.06	1.65	55.40	0.89	18.30	11.26	1.32	81201.83
1	6.65	4.77	49.98	3.08	16.82	11.30	1.33	82235.83
2	6.08	2.89	55.37	2.11	17.08	11.40	1.33	81130.59
3	5.95	7.25	56.12	2.94	16.18	11.40	1.33	81900.15
4	15.65	3.15	58.16	4.15	15.80	11.57	1.32	81452.95
5	8.22	2.64	59.67	1.32	15.32	11.70	1.30	79350.79
6	11.49	2.82	62.48	1.79	15.83	11.48	1.29	82218.21
7	6.54	2.59	62.36	2.61	15.56	11.59	1.29	81566.10
8	11.62	3.16	58.18	2.25	15.68	11.50	1.30	82425.50
9	10.50	4.64	58.02	3.09	15.18	11.48	1.29	82627.25
10	4.73	4.71	57.16	3.11	14.14	11.73	1.29	82316.91
11	10.34	4.96	59.81	2.80	14.88	11.66	1.29	81163.08
12	6.78	2.67	60.73	2.31	15.56	11.50	1.29	82099.61
13	8.79	3.08	59.16	2.20	16.17	11.54	1.28	81498.84
14	8.10	3.16	55.10	2.53	15.61	11.30	1.27	83826.28
15	10.16	7.19	55.86	2.89	13.48	11.92	1.28	80096.58
16	12.60	6.64	62.88	3.36	14.48	11.63	1.29	80998.44
17	8.33	1.55	63.01	2.06	12.90	11.87	1.29	78519.08
18	6.28	1.42	63.76	1.66	13.23	12.21	1.29	78163.45
19	8.79	2.02	60.71	1.22	15.25	11.64	1.29	79357.32
20	7.42	1.99	58.96	1.19	15.40	11.42	1.29	78698.98
21	11.80	6.47	52.25	1.48	14.79	11.38	1.29	78784.32
22	5.47	5.80	54.51	2.93	14.45	11.46	1.29	77766.59
23	4.84	3.55	68.20	2.48	16.17	11.46	1.29	77986.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.38	3.78	58.66	2.35	15.34	11.56	1.30	80724.37
最 大 值	15.65	7.25	68.20	4.15	18.30	12.21	1.34	83826.28
發生時間	4	3	23	4	0	18		14
最 小 值	4.06	1.42	49.98	0.89	12.90	11.26	1.27	77766.59
發生時間	0	18	1	0	17	0		22
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	0.00 %		-0.02		0.10 %
全幅偏移(率)	0.47 %	-0.23 %	-0.43 %	-0.09 %		0.09		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月30日

報表日期: 114年05月30日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.77	3.17	54.63	2.08	17.08	10.67	1.06	83184.97
1	4.94	2.27	54.97	1.64	17.66	10.55	1.06	83009.16
2	2.73	3.98	54.33	2.17	17.52	10.29	1.06	83670.41
3	0.16	2.62	56.11	2.87	16.15	10.60	1.06	81113.19
4	1.15	8.48	54.56	2.71	15.89	10.65	1.06	82773.46
5	5.97	2.21	65.92	2.46	17.36	10.44	1.06	87122.84
6	5.19	1.74	40.44	1.85	18.31	10.67	1.05	85862.16
7	4.33	3.84	60.07	2.18	16.58	10.64	1.04	83790.97
8	8.28	3.83	54.58	1.83	17.80	10.09	1.03	87451.24
9	3.10	2.22	62.40	1.69	17.07	11.03	1.04	79512.80
10	5.74	1.93	59.18	1.89	16.70	10.73	1.05	83256.67
11	6.52	3.66	60.06	2.38	16.60	10.74	1.04	84907.38
12	3.23	2.49	51.98	1.96	17.71	11.19	1.05	79883.55
13	2.02	2.60	59.88	2.12	18.25	10.41	1.06	85813.07
14	4.15	5.48	53.49	2.99	15.66	10.60	1.05	84038.30
15	1.45	2.26	52.43	2.49	15.99	10.32	1.05	83166.33
16	5.44	4.80	64.75	3.37	14.35	10.87	1.03	81454.56
17	11.41	5.43	63.91	3.57	14.58	10.85	1.03	81500.79
18	5.94	1.58	65.12	2.13	15.98	11.08	1.02	79314.54
19	14.57	4.62	61.88	2.58	16.05	10.57	1.02	85274.58
20	5.25	2.48	58.65	2.12	16.63	10.48	1.02	86374.97
21	8.03	4.00	59.54	2.31	15.81	10.66	1.02	85121.10
22	6.50	3.67	58.26	2.24	15.85	10.53	1.02	85860.67
23	8.83	1.92	60.14	1.87	16.67	10.46	1.02	86051.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.49	3.39	57.80	2.31	16.59	10.63	1.04	83729.57
最 大 值	14.57	8.48	65.92	3.57	18.31	11.19	1.06	87451.24
發生時間	19	4	5	17	6	12		8
最 小 值	0.16	1.58	40.44	1.64	14.35	10.09	1.02	79314.54
發生時間	3	18	6	1	16	8		18
零點偏移(率)	-0.05 %	-0.00 %	-0.22 %	-0.07 %		-0.03		-0.10 %
全幅偏移(率)	0.06 %	0.06 %	-0.05 %	0.29 %		0.12		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月30日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.83	2.94	63.12	2.19	19.99	8.79	1.43	81743.17
1	5.09	9.19	59.54	2.51	19.88	8.98	1.43	81745.72
2	5.55	3.64	57.95	2.32	16.57	10.01	1.44	83358.73
3	5.12	4.03	60.59	2.40	16.01	10.04	1.43	79398.65
4	4.38	4.00	61.42	2.33	16.03	9.76	1.43	78211.24
5	8.14	4.90	63.56	2.95	15.47	10.33	1.43	78707.65
6	4.72	4.50	64.35	2.73	17.08	9.96	1.43	79185.37
7	3.53	5.45	56.95	2.60	16.83	9.30	1.46	77329.10
8	8.40	4.11	59.50	3.12	17.14	9.45	1.46	80158.21
9	12.39	3.42	60.70	3.38	16.65	9.48	1.45	78697.10
10	6.20	6.41	59.33	2.51	17.28	9.31	1.43	78279.03
11	4.49	2.79	60.77	2.45	18.95	9.11	1.47	77489.64
12	1.35	2.23	54.86	2.27	19.31	9.15	1.46	79897.02
13	2.28	3.16	60.18	2.48	18.87	9.30	1.43	79663.01
14	3.80	7.55	56.02	2.79	18.20	9.06	1.43	79716.14
15	4.81	6.55	49.55	2.79	16.01	9.27	1.43	76480.16
16	10.26	7.75	50.83	3.01	16.68	9.14	1.44	79516.67
17	11.29	6.07	55.42	3.12	16.86	9.17	1.45	77616.34
18	7.01	5.39	52.84	2.56	16.89	9.20	1.43	78659.18
19	6.95	4.88	58.98	2.52	18.28	9.17	1.44	81182.83
20	7.37	6.01	51.67	2.86	17.09	9.25	1.44	80916.02
21	5.26	4.97	50.23	2.97	17.44	8.80	1.45	83279.14
22	3.12	3.78	55.86	2.72	19.15	8.61	1.44	79115.76
23	6.20	4.22	65.51	2.96	17.70	9.08	1.46	83635.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.98	4.91	57.91	2.69	17.51	9.32	1.44	79749.21
最 大 值	12.39	9.19	65.51	3.38	19.99	10.33	1.48	83635.20
發生時間	9	1	23	9	0	5		23
最 小 值	1.35	2.23	49.55	2.19	15.47	8.61	1.42	76480.16
發生時間	12	12	15	0	5	22		15
零點偏移(率)	-0.01 %	-0.01 %	-0.06 %	0.01 %		-0.02		-0.10 %
全幅偏移(率)	0.02 %	-0.77 %	-0.28 %	0.05 %		0.41		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								