

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.14	6.74	56.25	0.96	19.67	11.66	1.02	71392.05
1	9.33	8.91	42.89	1.71	18.72	11.65	1.04	72135.61
2	8.62	6.21	48.06	1.04	21.84	10.44	1.02	79036.20
3	8.96	4.15	43.84	1.93	18.36	11.09	1.02	76786.73
4	7.66	5.69	41.96	1.28	19.95	10.82	0.99	77186.88
5	11.64	6.91	44.68	2.14	17.81	11.53	1.01	70631.35
6	8.88	6.04	53.08	2.05	17.68	11.82	1.03	71865.91
7	8.11	6.27	57.09	1.49	17.89	11.86	1.04	71067.05
8	7.69	5.93	53.52	1.23	19.30	11.37	1.02	73727.77
9	8.63	5.32	48.55	1.35	18.98	11.18	1.00	75607.11
10	4.94	6.30	69.04	0.67	18.55	11.63	1.04	72504.03
11	10.00	9.93	32.84	1.04	18.40	11.01	1.03	77022.70
12	8.79	5.58	38.61	1.26	17.75	11.32	1.02	75714.78
13	3.99	5.85	35.77	1.80	15.96	12.03	1.02	70716.20
14	7.97	8.98	38.72	1.61	17.18	11.77	1.02	72449.82
15	3.86	9.32	51.15	1.21	16.59	12.82	1.04	65096.71
16	5.00	6.55	50.24	0.75	18.34	11.27	1.05	75645.19
17	11.13	10.66	45.99	1.70	17.12	11.35	1.03	75617.26
18	8.15	8.80	41.59	1.49	18.00	11.27	1.01	76028.81
19	8.41	6.26	42.39	2.01	16.82	11.85	1.01	72748.59
20	6.92	10.32	44.61	0.99	17.99	11.77	1.02	72511.30
21	10.46	8.74	41.92	1.66	18.20	11.30	1.02	75489.35
22	8.68	8.47	44.64	1.43	17.98	11.50	1.01	74096.71
23	8.05	6.71	58.26	0.71	19.33	11.31	1.03	74133.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.13	7.28	46.90	1.40	18.27	11.48	1.02	73717.14
最大值	11.64	10.66	69.04	2.14	21.84	12.82	1.09	79036.20
發生時間	5	17	10	5	2	15		2
最小值	3.86	4.15	32.84	0.67	15.96	10.44	0.99	65096.71
發生時間	15	3	11	10	13	2		15
零點偏移(率)	-0.29 %	0.00 %	-0.01 %	0.00 %		0.00		0.00 %
全幅偏移(率)	-1.23 %	-0.15 %	-0.06 %	0.08 %		-0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.55	12.83	50.28	2.20	17.10	10.10	0.97	85518.97
1	5.26	3.90	36.88	2.14	17.16	11.00	0.99	78855.39
2	0.10	3.91	45.68	1.65	17.88	11.40	0.98	76730.85
3	0.70	5.89	55.61	0.90	19.42	10.30	0.99	84015.99
4	4.68	8.99	39.32	2.20	16.58	10.25	0.99	87330.10
5	5.76	3.96	45.75	2.17	16.61	10.68	0.99	83699.94
6	10.41	9.03	47.82	1.66	18.80	10.06	1.00	83287.11
7	9.08	1.54	54.15	0.94	20.03	9.87	0.99	85717.83
8	9.65	2.79	40.38	1.30	19.31	9.39	0.99	89556.07
9	8.76	4.40	42.94	1.54	18.91	9.74	1.01	88200.52
10	9.21	4.40	47.12	2.15	16.80	10.57	1.01	83771.66
11	9.64	5.34	51.44	1.51	17.51	10.60	1.02	83092.60
12	8.11	2.02	51.76	1.48	17.11	10.43	1.02	84290.65
13	10.28	3.98	46.65	1.94	17.34	10.17	1.00	85946.06
14	6.62	4.45	57.70	1.54	17.28	10.68	1.02	82436.95
15	9.68	5.20	56.47	2.02	16.62	10.80	1.02	82181.01
16	6.62	2.30	57.02	0.95	18.84	10.20	1.02	84923.79
17	8.02	4.70	46.00	1.40	18.76	9.89	1.02	87623.38
18	7.42	5.57	60.47	1.68	18.01	10.20	1.01	85463.76
19	10.08	6.10	51.02	1.55	17.98	10.12	0.99	86339.66
20	8.60	5.77	53.61	0.99	19.18	9.74	0.98	87771.42
21	8.86	3.09	47.65	1.21	19.69	9.65	0.99	87918.86
22	3.47	6.74	59.97	0.69	19.66	10.33	1.02	83062.98
23	0.54	6.74	48.23	0.92	19.86	10.00	1.02	84436.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.09	5.15	49.75	1.53	18.18	10.26	1.00	84673.83
最大值	10.41	12.83	60.47	2.20	20.03	11.40	1.05	89556.07
發生時間	6	0	18	0	7	2		8
最小值	0.10	1.54	36.88	0.69	16.58	9.39	0.97	76730.85
發生時間	2	7	1	22	4	8		2
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.06 %		0.01		-0.20 %
全幅偏移(率)	0.04 %	-0.21 %	0.26 %	0.16 %		-0.21		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.68	5.78	51.42	1.51	16.67	10.74	1.04	79319.85
1	8.12	4.99	53.85	1.55	16.63	10.90	1.02	77142.22
2	6.30	5.14	46.69	1.53	16.64	10.88	1.01	77198.92
3	4.71	4.59	54.83	1.32	17.51	10.49	1.01	79494.82
4	7.53	7.90	50.42	1.76	17.62	9.95	0.99	82400.66
5	1.78	10.93	45.27	2.00	14.36	11.36	1.00	70947.10
6	7.38	7.90	50.65	1.62	16.00	10.75	1.00	74418.72
7	9.40	7.81	58.89	1.42	16.21	11.35	1.01	68200.70
8	11.23	6.90	44.32	1.67	17.62	10.24	0.99	77253.70
9	8.03	7.32	46.49	1.48	17.04	10.32	1.00	79064.32
10	6.02	5.47	41.02	1.21	16.22	10.53	0.99	76393.24
11	8.24	7.20	51.78	1.72	15.14	10.98	0.99	74167.04
12	7.30	9.50	49.72	1.23	16.59	10.62	0.99	75138.13
13	7.79	19.62	49.86	1.42	16.80	10.58	1.00	71654.83
14	8.07	11.15	50.76	1.95	14.98	10.96	0.98	73576.51
15	7.06	13.99	45.66	1.47	15.70	10.60	0.98	74596.84
16	8.76	7.81	51.46	1.95	15.52	10.05	0.99	79349.72
17	8.30	5.13	50.72	1.24	16.70	10.54	0.98	80869.74
18	8.86	3.93	57.14	1.08	17.41	10.30	0.98	83731.01
19	9.84	6.90	55.95	1.22	17.55	10.37	0.99	86134.63
20	9.22	10.84	48.91	1.29	16.16	10.97	0.99	82328.86
21	9.36	4.82	58.13	1.41	17.21	10.49	1.00	86135.47
22	9.30	6.51	50.62	1.59	16.57	10.45	0.99	83561.33
23	7.30	6.00	64.68	1.08	16.94	10.73	1.00	79762.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.82	7.84	51.22	1.49	16.49	10.63	1.00	78035.05
最大值	11.23	19.62	64.68	2.00	17.62	11.36	1.11	86135.47
發生時間	8	13	23	5	4	5		21
最小值	1.78	3.93	41.02	1.08	14.36	9.95	0.97	68200.70
發生時間	5	18	10	18	5	4		7
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.60 %	-0.21 %	0.00 %		0.16		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								