

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月20日

報表日期: 114年08月20日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.35	9.68	64.21	2.79	13.89	12.67	1.25	64603.22
1	2.08	9.44	58.16	2.02	16.59	12.29	1.25	65701.02
2	2.58	8.97	59.03	2.25	15.38	12.03	1.25	68507.74
3	8.05	8.77	59.72	2.86	15.39	11.76	1.25	70391.13
4	8.86	8.82	60.92	2.64	15.40	11.68	1.24	70984.73
5	5.68	8.95	56.04	2.95	13.94	11.90	1.25	67733.52
6	6.51	8.95	58.80	2.81	13.95	12.11	1.25	68737.15
7	7.52	9.02	60.05	2.75	13.90	12.09	1.25	68591.57
8	5.57	9.02	67.66	2.47	14.68	11.94	1.26	69586.18
9	6.71	9.62	60.94	3.13	13.23	12.16	1.25	68574.34
10	3.69	8.91	55.27	2.99	13.22	12.10	1.25	68954.06
11	5.57	12.89	52.35	3.51	12.91	12.18	1.25	65538.07
12	3.58	9.41	58.76	3.11	13.03	12.24	1.25	63886.60
13	2.33	11.46	55.72	3.40	12.61	12.06	1.25	66259.93
14	1.47	11.28	55.07	3.37	12.12	12.72	1.25	58934.98
15	2.19	11.29	55.47	2.80	13.14	12.55	1.23	61126.58
16	9.58	10.12	62.92	2.65	13.75	11.85	1.24	71019.12
17	8.03	12.55	53.18	3.13	12.90	11.97	1.25	70352.22
18	8.36	8.92	61.88	3.11	13.56	11.95	1.25	70177.76
19	10.33	8.57	63.36	3.00	13.95	11.99	1.25	69797.13
20	9.10	8.83	66.79	2.93	13.25	12.11	1.25	69079.01
21	7.99	9.55	60.95	2.97	12.84	12.18	1.25	69321.76
22	8.17	9.92	68.80	2.99	12.66	12.43	1.27	67621.12
23	7.76	10.20	53.02	3.13	12.41	12.15	1.25	70182.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.04	9.80	59.54	2.91	13.70	12.13	1.25	67735.88
最 大 值	10.33	12.89	68.80	3.51	16.59	12.72	1.28	71019.12
發生時間	19	11	22	11	1	14		16
最 小 值	1.47	8.57	52.35	2.02	12.12	11.68	1.20	58934.98
發生時間	14	19	11	1	14	4		14
零點偏移(率)	-0.13 %	-0.02 %	-0.01 %	-0.06 %		-0.02		0.10 %
全幅偏移(率)	0.00 %	0.86 %	-0.22 %	0.10 %		0.32		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月20日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.42	8.61	61.21	2.48	17.03	11.27	1.06	80026.56
1	8.62	8.35	60.88	2.79	17.97	10.96	1.06	81113.23
2	9.64	8.67	55.68	3.36	16.01	11.31	1.06	79986.96
3	6.08	8.65	57.59	3.47	16.16	11.23	1.06	80225.03
4	7.88	9.20	56.38	3.14	16.03	11.08	1.06	79153.70
5	8.78	7.68	55.87	1.75	16.10	10.87	1.06	78180.08
6	4.55	9.06	61.60	1.68	16.41	11.01	1.03	74841.29
7	9.28	10.49	60.91	2.61	14.93	11.66	1.04	78588.19
8	4.40	9.62	58.81	1.88	14.93	11.53	1.03	78528.93
9	10.68	9.15	53.93	1.95	15.61	10.85	1.03	79266.34
10	14.64	10.27	56.06	3.17	13.94	11.09	1.03	77090.08
11	10.82	9.93	63.46	2.67	13.44	11.59	1.03	78403.70
12	16.13	11.88	60.91	2.26	13.90	11.67	1.02	78299.51
13	5.04	9.84	58.61	1.69	14.48	11.72	1.02	76255.76
14	4.77	12.27	60.54	1.89	14.47	11.77	1.02	73349.98
15	4.63	13.52	63.16	2.15	13.42	12.11	1.02	70872.35
16	10.53	8.46	51.69	2.35	14.15	10.93	1.02	81687.45
17	11.08	12.98	59.84	2.60	13.25	11.49	1.02	80835.32
18	3.47	7.71	55.01	1.35	15.84	10.86	1.02	82837.73
19	13.84	8.92	56.71	3.95	14.45	11.06	1.03	82542.07
20	5.61	10.56	55.50	2.06	15.07	10.90	1.02	83978.67
21	7.20	9.22	63.52	1.76	15.39	10.94	1.02	83861.34
22	3.65	11.15	57.68	1.79	14.04	11.80	1.02	72503.70
23	4.36	12.28	60.64	2.91	14.37	11.86	1.02	71939.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.05	9.94	58.59	2.40	15.06	11.32	1.03	78515.29
最 大 值	16.13	13.52	63.52	3.95	17.97	12.11	1.06	83978.67
發生時間	12	15	21	19	1	15		20
最 小 值	3.47	7.68	51.69	1.35	13.25	10.85	1.01	70872.35
發生時間	18	5	16	18	17	9		15
零點偏移(率)	-0.01 %	-0.00 %	-0.04 %	-0.04 %		-0.07		-0.20 %
全幅偏移(率)	0.14 %	0.16 %	0.18 %	0.33 %		0.16		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月20日

[illegible]